

# Lead in School Drinking Water Report

## George Bush Middle School



Date(s) collected: 2023-01-27, 2023-01-26

Date(s) analyzed: 2023-02-02, 2023-02-03

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
35939	Building A1	Sink	Room B-15	Only sink	Tap	17
35918	Building A1	Sink - Multi-Compartment	Kitchen	Right of dish washer	Tap	15
35950	Building A1	Sink	Room C-7	Only sink	Tap	4
35949	Building A1	Sink	Room C-18	Only sink	Tap	3
35959	Building A1	Sink	Room A-22	Only sinkb	Tap	3
35951	Building A1	Sink	Room C-16	Only sink	Tap	3
35948	Building A1	Sink	Room C-6	Only sink	Tap	3
35954	Building A1	Sink	Room C-13	Only sink	Tap	3
35940	Building A1	Sink	Room B-13	Only sink	Tap	2
35929	Building	Sink	Room B-6	Only sink	Tap	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
35960	Building A1	Sink	Orchestra	Only sink	Tap	2
35919	Building A1	Sink - Multi-Compartment	Kitchen	Right of dish washer	Tap	1
35928	Building A1	Sink	Room B-7	Only sink in room	Tap	1
35932	Building A1	Sink	Room B-1	Only sink	Tap	1
35952	Building A1	Sink	Room C-15	Only sink	Tap	1
35941	Building A1	Sink	Room B-12	Only sink	Tap	1
35935	Building A1	Sink	Room B-19	3rd sink from left	Tap	1
35936	Building A1	Sink	Room B-19	Sink furthest of right	Tap	1
35921	Building A1	Sink	Cafeteria	Corner closest to A-23	Tap	1
35937	Building A1	Sink	Room B-18	Only sink	Tap	1
35938	Building A1	Sink	Room B-16	Only sink	Tap	1
35945	Building A1	Sink	Room C-1	Only sink	Tap	1
35955	Building A1	Sink	Room C-12	Only sink	Tap	1
35958	Building A1	Sink	Room A-61	Only sink	Tap	1
35922	Building A1	Sink	Cafeteria	Corner closest to main gym	Tap	1
35931	Building A1	Sink	Room B-3	Only sink	Tap	1
35942	Building A1	Fountain - Multi-Level with Bottle Filler	Library	Near exit door, left drinking fountain	Water Fountain	<1
35920	Building	Sink - Multi-	Kitchen	Sink closest to	Sprayer	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	A1	Compartment		fridge		
35924	Building A1	Fountain - Multi-Level with Bottle Filler	Hallway	Across from D17	Water Fountain	<1
35946	Building A1	Sink	Room C-3	Sink in kitchen, to the right when walking through entrance	Tap	<1
35917	Building A1	Sink	Kitchen	Right of dish washer	Sprayer	<1
35925	Building A1	Fountain - Multi-Level with Bottle Filler	Hallway	Across from D17, left fountain	Water Fountain	<1
35930	Building A1	Sink	Room B-4	Only sink	Tap	<1
35953	Building A1	Fountain	6th Grade Pod	Outside c14 restrooms	Water Fountain	<1
35956	Building A1	Sink	A-7	Only sink	Tap	<1
35943	Building A1	Fountain - Multi-Level with Bottle Filler	Library	Right fountain	Water Fountain	<1
35933	Building A1	Sink	Room B-19	When entering room sink on far left	Tap	<1
35934	Building A1	Sink	Room B-19	2nd sink from left largest sink	Tap	<1
35923	Building A1	Fountain	Outside Cafeteria	Outside kitchen	Water Fountain	<1
35927	Building A1	Fountain	Pod Seating Area	Outside of B-5	Water Fountain	<1
35944	Building A1	Fountain - Multi-Level with Bottle Filler	Library	Bottle filler	Water Bottle Filler	<1
35947	Building A1	Fountain	6th Grade Pod	Outside C-5 restrooms	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
35926	Building A1	Fountain	7th Grade Wing	Outside of B14 restrooms	Water Fountain	<1
35957	Building A1	Fountain	Hallway	To left of A-33 entrance	Water Fountain	<1

#### EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov)