

# Lead in School Drinking Water Report

## New Market Skills Center



Date(s) collected: 2023-04-28

Date(s) analyzed: 2023-05-08, 2023-05-09

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373482	Building B	Sink - Multi-Compartment	Cosmotology	Sink in classroom next to salon style chairs	Tap	341
373474	Building A	Sink	Room C-A102	Sink next to dish washer	Sprayer	23
373472	Building A	Pot Filler	Kitchen	Next to big dough mixer and big cooking pots	Tap	19
373478	Building B	Sink	Room B10	Only sink	Tap	12
373489	Building D	Sink	Room 414	Sink in classroom	Tap	12
373491	Building D	Sink	Room 414	Eye wash station sink	Tap	12
373492	Building D	Sink	Room 427	Sink next to eye wash station	Tap	9
373471	Building A	Sink	Kitchen	Other food prep sink next to big	Tap	7

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
				dough mixer		
373477	Building B	Sink	Room B1	Only sink	Tap	6
373495	Building D	Sink - Multi-Compartment	Room 443	Only sink	Tap	6
373469	Building A	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink	Tap	5
373493	Building D	Sink	Firefighters Classroom	Only sink	Tap	5
373465	Building A	Sink	Kitchen	Sink with hot and cold water outlets	Tap	4
373460	Building A	Sink - Multi-Compartment	Kitchen	Food prep sink 1 of 4. One in middle. Next to walk in freezer	Tap	3
373462	Building A	Sink - Multi-Compartment	Kitchen	Food prep sink 3 of 4 one on right when looking at freezer	Tap	3
373464	Building A	Sink	Kitchen	Sink with hot and cold water outlets	Tap	3
373496	Building D	Sink - Multi-Compartment	Room 443	Only sink	Tap	3
373461	Building A	Sink - Multi-Compartment	Kitchen	Food prep sink 2 of 4. Looking at freezer one on the left	Tap	2
373463	Building A	Sink	Kitchen	Food prep sink 4 of 4. One across from stove top	Tap	2
373470	Building A	Sink	Kitchen	Next to pizza ovens	Tap	2
373473	Building A	Sink	Room C-A102	Sink on island	Tap	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373486	Building C	Fountain - Multi-Level	Next To Lockers	Higher fountain	Water Fountain	2
373487	Building C	Fountain - Multi-Level	Next To Lockers	Lower fountain	Water Fountain	2
373490	Building D	Sink	Room 414	Next to washer/dryer	Tap	2
373494	Building D	Sink	Room 438	Only sink	Tap	2
373468	Building A	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink	Tap	1
373479	Building B	Fountain - Multi-Level	Hallway	Next to room B2. Higher fountain	Water Fountain	1
373481	Building B	Sink - Multi-Compartment	Cosmotology	Sink next to fridge	Tap	1
373466	Building A	Ice Machine	Kitchen	Close to dish washer	Other	<1
373467	Building A	Sink	Kitchen	Next to dishwasher	Sprayer	<1
373475	Building A	Fountain - Multi-Level	Cafeteria	Higher fountain	Water Fountain	<1
373476	Building A	Fountain - Multi-Level	Cafeteria	Lower fountain	Water Fountain	<1
373480	Building B	Fountain - Multi-Level	Hallway	Next to room B2	Water Fountain	<1
373483	Building B	Sink	Old Cosmotology Room	Sink 1 of 2 sink closest to entrance/exit	Tap	<1
373484	Building C	Fountain - Multi-Level	Next To Restrooms In Shop Area	Higher fountain	Water Fountain	<1
373485	Building C	Fountain - Multi-Level	Shop Area	Lower fountain	Water Fountain	<1
373488	Building D	Fountain - Multi-Level	Pod Area/Foyer	Higher fountain	Water Fountain	<1

#### EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **[leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov)**