



1515 80th St. E.
Tacoma, WA 98404
(253) 531-3121

Lead and Copper
Distribution System - Report of Analyses

Lead and Copper Analysis (LCR)	System Group Type: (circle one) A B <u>Other</u>
Water System ID Number: N/A	System Name: Tumwater SC
Source: S93 (standing distribution samples)	County: Thurston
	Consecutive System? YES NO
Sample Purpose: (check appropriate box) <input type="checkbox"/> RC - Routine/Compliance (satisfies monitoring requirements) <input type="checkbox"/> C - Confirmation (confirmation of chemical result)* <input checked="" type="checkbox"/> I - Investigative (does not satisfy monitoring requirements) <input type="checkbox"/> O - Other (specify - does not satisfy monitoring requirements)	Date Received: 08-09-2023 Date Analyzed: 08-16-2023 Date Reported: 09-19-2023 Supervisor Initials: <i>RL</i>
Sample Composition: (check appropriate box) <input type="checkbox"/> S - Single Source <input type="checkbox"/> B - Blended (list sources in "Source Number" field) <input type="checkbox"/> C - Composite (list sources in "Source Number" field) <input checked="" type="checkbox"/> D - Distribution Sample	Sample Type: (check one) <input type="checkbox"/> Pre-treatment/Untreated (Raw) <input checked="" type="checkbox"/> Post-treatment (Finished) <input type="checkbox"/> Unknown or Other Contact Name: Jim Barr Phone Number: 360-709-7730
Send Report & Bill to: Tumwater School District 2020 80th Ave SW, Tumwater WA 98512	Comments:

ANALYTICAL RESULTS

(DOH #) Analyte	(0009) Lead	(0023) Copper
State Detection Reporting Level (SDRL) (mg/L)	0.001	0.02
Regulatory Action Level (mg/L)**	0.015	1.3
Analytical Method / Analyst's Initials	200.8/CP	200.8/NA

Lab Number / Sample Number ____ / _____	Date Collected	Sample Location:	Lead (mg/L)	Copper (mg/L)
089 / 05927	08-09-2023	Cosmotology	0.0018	NA
089 / 05928	08-09-2023	RM C-A102	0.0082	NA
089 / 05929	08-09-2023	Kitchen	0.0013	NA
089 / 05930	08-09-2023	RM B10 Sink	0.0012	NA
089 / 05931	08-09-2023	RM 414 Sink	<0.0010	NA
089 / 05932	08-09-2023	RM 414 Eye Wash Station	0.0012	NA
089 / 05933	08-09-2023	RM 427 Sink	0.0038	NA
089 / 05934	08-09-2023	Kitchen Prep Sink	0.0012	NA
089 / 05935	08-09-2023	RM B1	0.0070	NA
089 / 05936	08-09-2023	RM 443	0.0068	NA

NOTES:

**Regulatory Action Level for schools and daycare facilities is 0.020 mg/L for Lead

*Confirmation: Include the original lab number, sample number, and collection date of original sample in either comment section.

mg/L: milligrams per liter or parts per million

Regulatory Action level: The concentraion against which the 90th percentile of all distribution samples collected during the monitoring period that, if exceeded, signals the system is in violation.

SDRL (State Detection Reporting Level): The minimum reporting level established by the department.