

# Lead in School Drinking Water Report

## Tumwater High School



Date(s) collected: 2023-06-23

Date(s) analyzed: 2023-07-13

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374065	Building B	Sink	Student Store	Near entrance/exit next to coffee maker	Tap	16
377300	Building C	Sink	Kitchen	Left of dishwasher	Tap	7
377308	Building A	Sink	Band Room	Only sink	Tap	7
377801	Building C	Sink - Multi-Compartment	Kitchen	Next to bathroom	Sprayer	6
374063	Building B	Sink - Multi-Compartment	Student Store	Sink closest to ice machine	Tap	5
377302	Building C	Pot Filler	Kitchen	Next to oven	Other	5
377311	Building A	Fountain - Multi-Level	30s Hallway	Lower fountain	Water Fountain	5
377807	Building E2	Other	Hoses	Track closet. Hoses used for drinking on field	Other	5

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
377817	Building B	Sink - Multi-Compartment	Room B9	Station with long L countertop	Tap	5
377303	Building C	Fountain - Multi-Level	Commons Next To Restrooms	Lower fountain	Water Fountain	4
377318	Building B	Sink - Multi-Compartment	Room B9	West wall facing parking lot. Left station	Tap	4
377800	Building C	Sink - Multi-Compartment	Kitchen	2 compartment sink next to bathroom	Tap	3
377808	Building A	Sink	Band Room	Only sink	Water Fountain	3
377301	Building C	Sink	Kitchen	Across from stove top	Tap	2
377306	Building C	Fountain	Spin Room	Only fountain	Water Fountain	2
377307	Building E2	Fountain	Stadium Hallway	Individual fountain across from S4	Water Fountain	2
377315	Building A	Sink	Room A42	Only sink	Tap	2
377317	Building B	Sink - Multi-Compartment	Room B9	Station closest to washer and dryer	Tap	2
377319	Building B	Sink - Multi-Compartment	Room B9	West wall facing parking lot right station	Tap	2
377803	Building C	Fountain	Hallway Outside Locker Rooms	South fountain	Water Fountain	2
377806	Building E2	Fountain	Stadium Hallway	Lower fountain	Water Fountain	2
377809	Building A	Fountain	Next To Electrical Room A123	Hallway	Water Fountain	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
377810	Building A	Fountain - Multi-Level	Hallway	Next to room A32. Higher fountain	Water Fountain	2
377812	Building A	Sink	Health And Wellness Center	Only sink	Tap	2
377815	Building A	Sink	Room A45	Only sink	Tap	2
374060	Building B	Sink - Multi-Compartment	Room B9	Demonstration	Tap	1
377305	Building C	Sink	Weight Room	Only sink	Tap	1
377309	Building A	Fountain	Band Room	In between A127 and A128	Water Fountain	1
377312	Building A	Sink	Room A37	Only sink	Tap	1
377316	Building B	Fountain	Near Wood Shop	In between restrooms	Water Fountain	1
377804	Building C	Sink	Weight Room	Only sink	Water Fountain	1
377814	Building A	Fountain	Choral Room	Only fountain	Water Fountain	1
374061	Building B	Sink - Multi-Compartment	Life Skills Room B3	Only sink	Tap	<1
374062	Building B	Sink - Multi-Compartment	Student Store	Sink closest to ice machine	Tap	<1
374064	Building B	Ice Machine	Student Store	By eye washing station	Other	<1
377304	Building C	Fountain	Hallway Outside Locker Rooms	South fountain	Water Fountain	<1
377310	Building A	Fountain	Next To A194 Closet	Individual fountain. Hallway	Water Fountain	<1
377313	Building A	Fountain - Multi-Level	40s Hallway	Higher fountain. Across from	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
		with Bottle Filler		security		
377314	Building A	Fountain - Multi-Level with Bottle Filler	40s Hallway	Across from security	Water Bottle Filler	<1
377802	Building C	Fountain - Multi-Level	Commons	Higher fountain next to restroom	Water Fountain	<1
377805	Building C	Water Bottle Filling Station	Weight Room	Next to sink	Water Bottle Filler	<1
377811	Building A	Sink	Room A36	Only sink	Tap	<1
377813	Building A	Fountain - Multi-Level with Bottle Filler	40s Hallway	Lower fountain. Across from security	Water Fountain	<1
377816	Building B	Sink	Drafting Room	Only sink	Tap	<1
377818	Building B	Sink - Multi-Compartment	Room B9	West wall facing parking lot middle station	Tap	<1
377819	Building B	Sink - Multi-Compartment	Room B9	Behind demonstration station	Tap	<1

#### EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov)