



October 24, 2023

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: DCSD Chaparral High School  
15655 Brookstone Drive in Parker, Colorado  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Chaparral High School, located at 15655 Brookstone Drive in Parker, Colorado.

Twenty-four (24) AirChek radon test kits were placed on October 2, 2023, and twenty-three (23) were retrieved on October 4, 2023. One (1) Airchek radon kit was mitting from Room 322 at the rime of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Handwritten signature of Robert A. Woellner in black ink.

Robert A. Woellner  
President/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

Handwritten signature of Anatole (Tony) Konowal in black ink.

Anatole (Tony) Konowal  
Project Manager/Industrial Hygienist

Handwritten signature of Larry Head in black ink.

Larry Head  
CEO

Attachment: Laboratory Report

Radon test result report for:  
**DCSD - CHAPARRAL HS**  
**MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11395581	300	2023-10-02 @ 5:00 pm	2023-10-04 @ 5:00 pm	< 0.3	2023-10-06
11395582	301	2023-10-02 @ 6:00 pm	2023-10-04 @ 6:00 pm	0.7	2023-10-06
11395583	302	2023-10-02 @ 7:00 pm	2023-10-04 @ 7:00 pm	< 0.3	2023-10-06
11395584	303	2023-10-02 @ 8:00 pm	2023-10-04 @ 8:00 pm	< 0.3	2023-10-06
11395585	304	2023-10-02 @ 9:00 pm	2023-10-04 @ 9:00 pm	< 0.3	2023-10-06
11395586	305	2023-10-02 @ 10:00 pm	2023-10-04 @ 10:00 pm	< 0.3	2023-10-06
11395587	305 DUPLICATE	2023-10-02 @ 11:00 pm	2023-10-04 @ 11:00 pm	< 0.3	2023-10-06
11395592	306	2023-10-02 @ 4:00 am	2023-10-04 @ 4:00 am	< 0.3	2023-10-06
11395593	307	2023-10-02 @ 5:00 am	2023-10-04 @ 5:00 am	0.5	2023-10-06
11395594	308	2023-10-02 @ 6:00 am	2023-10-04 @ 6:00 am	0.6	2023-10-06
11395595	309	2023-10-02 @ 7:00 am	2023-10-04 @ 7:00 am	0.7	2023-10-06
11395597	309 BLANK	2023-10-02 @ 9:00 am	2023-10-04 @ 9:00 am	< 0.3	2023-10-06
11395596	309 DUPLICATE	2023-10-02 @ 8:00 am	2023-10-04 @ 8:00 am	0.7	2023-10-06
11395598	310	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.5	2023-10-06
11395599	311	2023-10-02 @ 11:00 am	2023-10-04 @ 11:00 am	< 0.3	2023-10-06
11395600	312	2023-10-02 @ 12:00 pm	2023-10-04 @ 12:00 pm	< 0.3	2023-10-06
11395591	315	2023-10-02 @ 3:00 am	2023-10-04 @ 3:00 am	0.6	2023-10-06
11395590	316	2023-10-02 @ 2:00 am	2023-10-04 @ 2:00 am	0.5	2023-10-06
11395588	319	2023-10-02 @ 12:00 am	2023-10-04 @ 12:00 am	< 0.3	2023-10-06
11395589	320	2023-10-02 @ 1:00 am	2023-10-04 @ 1:00 am	0.7	2023-10-06
11395601	321	2023-10-02 @ 1:00 pm	2023-10-04 @ 1:00 pm	< 0.3	2023-10-06
11395578	323	2023-10-02 @ 2:00 pm	2023-10-04 @ 2:00 pm	0.6	2023-10-06
11395579	SCINCE OFFICE	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	0.6	2023-10-06