



October 24, 2023

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Outdoor Education Center, Building 102
12163 S. Perry Park Road, Larkspur, CO 80118
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Outdoor Education Center, Building 102, located at 12163 S. Perry Park Road in Larkspur, Colorado.

Eighteen (18) AirChek radon test kits were placed on October 2, 2023, and they were retrieved on October 4, 2023. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Handwritten signature of Robert A. Woellner in black ink.

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Handwritten signature of Anatole (Tony) Konowal in black ink.

Anatole (Tony) Konowal
Project Manager/Industrial Hygienist

Handwritten signature of Larry Head in black ink.

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
DCSD - OEC
102

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11395502	10TH BEDROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.9	2023-10-06
11632090	1ST LOFT BUNK ROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	< 0.3	2023-10-06
11632091	2ND LOFT BUNK ROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.0	2023-10-06
11632092	3RD LOFT BUNK ROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.7	2023-10-06
11632093	4TH LOFT BUNK ROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.0	2023-10-06
11632094	5TH LOFT BUNK ROOM	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.7	2023-10-06
11632100	BEAR BUTTE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.8	2023-10-06
11395504	COMMON AREA	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.7	2023-10-06
11395506	COMMON AREA BLANK	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	< 0.3	2023-10-06
11395505	COMMON AREA DUPLICATE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.8	2023-10-06
11632099	DAWSON BUTTE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.8	2023-10-06
11632095	LOCKED END ROOM LEFT	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.8	2023-10-06
11632096	LOCKED END ROOM RIGHT	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.9	2023-10-06
11632089	NURSE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	0.8	2023-10-06
11395503	NURSE OFFICE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.1	2023-10-06
11395501	RASBERRY BUTTE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.1	2023-10-06
11632097	RATTLESNALE BUTTE	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.4	2023-10-06
11632098	RATTLESNALE BUTTE (DUPLICATE)	2023-10-02 @ 10:00 am	2023-10-04 @ 10:00 am	1.4	2023-10-06