



October 24, 2023

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Bridge North
8250 Park Meadows Dr., in Lone Tree, CO
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Bridge North, located at 8250 Park Meadows Drive in Lone Tree, Colorado.

Nine (9) AirChek radon test kits were placed on October 2, 2023, and they were retrieved on October 4, 2023. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "ATK".

Anatole (Tony) Konowal
Project Manager/Industrial Hygienist

Attachment: Laboratory Report

October 20, 2023

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**DCSD - BRIDGE NORTH
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11395636	100 - BLUE WALL	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.2	2023-10-06
11395638	101 - TEAL WALL	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.6	2023-10-06
11395634	BREAK ROOM	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.5	2023-10-06
11395635	COPY ROOM/OFFICE	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.5	2023-10-06
11395643	CUSTODIAL SUPPLY ROOM BLANK	2023-10-02 @ 4:00 pm	2023-10-04 @ 4:00 pm	< 0.3	2023-10-06
11395640	CUSTODIAL SUPPLY ROOM	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.6	2023-10-06
11395641	CUSTODIAL SUPPLY ROOM DUPLICATE	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.2	2023-10-06
11395637	PURPLE WALL	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.2	2023-10-06
11395639	QUIET ROOM IN 101	2023-10-02 @ 3:00 pm	2023-10-04 @ 3:00 pm	1.5	2023-10-06

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498