



BEDFORD CENTRAL SCHOOL DISTRICT
FOX LANE CAMPUS
P.O. BOX 180
MOUNT KISCO, NY 10549

LEAD WATER TESTING

For

Fox Lane Middle School
Fox Lane Campus
Mount Kisco, NY 10549

Date of Assessment: March 23, 2017

Date of Report: March 31, 2017

Completed By: Justin Joe, PhD, CSP
Industrial Hygienist / Building Inspector
BNF Consulting, Inc.
152 Route 202, #404
Lincolndale, NY 10540
bnfjustin@gmail.com

EXECUTIVE SUMMARY

On March 23, 2017, the 2nd lead water retesting was completed for Fox Lane Middle School, a building of the Bedford Central School District (BCSD), located at Fox Lane Campus, Mount Kisco, NY 10549. This clearance testing for lead in water was performed after repair of fixtures, which exceeded the NYS lead action level from the initial testing on October 20, 2016, and then the 1st retest was performed on February 11, 2017. Primarily assisting in the completion of this study was Mr. Robert Gimigliano, Director of Buildings and Grounds, and the maintenance staff at Fox Lane Middle School.

The purpose of this survey is to comply to 10 NYCRR SUBPART 67-4: Lead Testing in School Drinking Water. This subpart requires all school districts and boards of cooperative education services, including those already classified as a public water system under 10 NYCRR Subpart 5-1, to test portable water for lead contamination and to develop and implement a lead remediation plan when applicable. Action Level used in the Subpart means 15 micrograms per liter ($\mu\text{g/L}$) or parts per billion (ppb). Exceedance of the action level requires a response to implement a lead remediation plan.

First-draw water samples were collected from all available water outlets including faucets, sinks and water fountains in and around the building. These areas included conference rooms, restrooms, hallways, the kitchen, custodial closets, the boiler room and the exterior. The sampled water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before the sample collection according to the guideline from the Subpart. The first-draw samples were collected from a cold water outlet before any water was used. The samples were sent to Phoenix Environmental Laboratories, Inc., which is approved to perform lead analyses by the Department's Environmental Laboratory Approval Program (ELAP#: 11715).

Lab results indicate that:

- 0 out of 1 water samples were above the action level.
- No water fountains or kitchen sinks were above the action level.
- No water outlets are listed as being above the action level.

RECOMMENDATIONS

The following is a recommendation from this survey.

None

CONCLUSION

This survey revealed that all of the lead testing from water source fixtures indicated low or non-detectable exposures. 0 out of 1 samples were above the Action Level, 15 micrograms per liter ($\mu\text{g/L}$) or parts per billion (ppb), listed in the report. No water fountains or kitchen sinks were above the action level.

The recommendations in this report are intended to achieve the goal of a safer and more healthful environment. If the recommendations are completed, future health issues should be prevented.

If there are any questions regarding the contents of this report or further assistance is needed for recommendation completion, please feel free to contact Dr. Justin Joe, who can be reached via the following:

Justin H. Joe, PhD, CSP
BNF Consulting, Inc.
152 Route 202, #404
Lincolndale, NY 10540
bnfjustin@gmail.com

A closing Thank You is extended to all who assisted or participated in completion of this Survey.

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any representation contained herein. This information should not be construed as business, risk management, or legal advice or legal opinion.

APPENDIX A

LEAD WATER TESTING LAB RESULTS



Tuesday, March 28, 2017

Attn: Justin Joe
BNF Consulting
152 Route 202 #404
Lincolndale, NY 10540-0404

Project ID: BCSD
Sample ID#s: BX92569

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #MA-CT-007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 28, 2017

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: SW
 Analyzed by: see "By" below

Date

03/22/17
 03/23/17

Time

22:00
 16:42

Laboratory Data

SDG ID: GBX92569
 Phoenix ID: BX92569

Project ID: BCSD
 Client ID: FLMS-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0008	0.0005	1	mg/L	0.015			03/27/17	LK	200.8 5.4
Total Metal Digestion	Completed							03/23/17	AG/BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

March 28, 2017

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



QA/QC Report

March 28, 2017

QA/QC Data

SDG I.D.: GBX92569


Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 380340 (mg/L), QC Sample No: BX91701 (BX92569)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.001	0.0005	<0.001	NC	90.8			88.2			85 - 115	20

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 70-130%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference


 Phyllis Shiller, Laboratory Director
 March 28, 2017

Tuesday, March 28, 2017

Criteria: None

State: NY

Sample Criteria Exceedances Report

GBX92569 - BNFCNSLT

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



NY Temperature Narration

March 28, 2017

SDG I.D.: GBX92569

The samples in this delivery group were received at 3°C.
(Note acceptance criteria is above freezing up to 6°C)

30014

BCSD Lead Water Sampling COC

NO	Flush		Drew at		Location	Remark
	Date	Time	Date	Time		
FLMS - 01	3/22	2200	3/23	0830	See the floor plan	Sink in the gym 104 (Left)
						92569
Total 1 samples						

Jan [Signature]

3/23/17 12:55

[Signature]

3-23-17 15:05



BNF Consulting, Inc


Wm [Signature] 3/23/17 16:42

30015

BCSD Lead Water Sampling COC

NO	Flush at		Draw at		Location	Remark
	Date	Time	Date	Time		
FLMS - 01	3/22	2200	3/23	08:30	See the floor plan	Sink in the gym 104 (Left) 92569
Total 1 samples						

 3/23/17 12:55


 3-23-17 15:05
 BNF Consulting, Inc

 3/23/17 6:42