



BEDFORD CENTRAL SCHOOL DISTRICT  
FOX LANE CAMPUS  
P.O. BOX 180  
MOUNT KISCO, NY 10549

## LEAD WATER TESTING

For

Fox Lane High School  
Fox Lane Campus  
Mount Kisco, NY 10549

Date of Assessment: October 15, 2016

Date of Report: November 9, 2016

Completed By: Justin Joe, PhD, CSP  
Industrial Hygienist / Building Inspector  
BNF Consulting, Inc.  
152 Route 202, #404  
Lincolndale, NY 10540  
[bnfjustin@gmail.com](mailto:bnfjustin@gmail.com)

**EXECUTIVE SUMMARY**

On October 15, 2016, lead water testing was completed for Fox Lane High School (FLHS), one of the Bedford Central School District (BCSD) schools, located at Fox Lane Campus, Mount Kisco, NY 10549. Primarily assisting in completion of this study were Mr. Gregory Sullivan, Interim Assistant Superintendent, Mr. Shawn Pitulle, Interim Director of Buildings and Grounds, and maintenance staff in FLHS.

The purpose of this survey is to comply to 10 NYCRR SUBPART 67-4: Lead Testing in School Drinking Water. This subpart requires all school districts and boards of cooperative education services, including those already classified as a public water system under 10 NYCRR Subpart 5-1, to test portable water for lead contamination and to develop and implement a lead remediation plan when applicable. Action Level used in the Subpart means 15 micrograms per liter ( $\mu\text{g/L}$ ) or parts per billion (ppb). Exceedance of the action level requires a response to implement a lead remediation plan.

First-draw water samples were collected from all available water outlets including faucets, sinks and water fountains in and around the building. These areas included classrooms, restrooms, hallways, the kitchen, custodial closets, the boiler room and the exterior. The sampled water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before the sample collection according to the guideline from the Subpart. The first-draw samples were collected from a cold water outlet before any water was used. The samples were sent to Phoenix Environmental Laboratories, Inc., which is approved to perform lead analyses by the Department's Environmental Laboratory Approval Program (ELAP#: 11715).

Lab results indicate that:

- 11 out of 245 water outlets were above the action level.
- No water fountains and kitchen sinks were above the action level.
- The following water outlets were above the action level as:
  1. Sink in Rm B-104B
  2. Sink in the custodial closet by Rm C-213
  3. Sink in the custodial closet by Rm C-313
  4. Exterior by Rm A-112
  5. Exterior by Rm A-105
  6. Exterior by Rm A-119
  7. Garage
  8. Sink in Rm G-11 Girls Green Rm (Right)
  9. Sink in Rm F-113 Boys Green Rm (Right)
  10. Sink in Rm F-113 Boys Green Rm (Left)
  11. Sink in Rm F-115 (Left)

## RECOMMENDATIONS

The following is a recommendation from this survey.

- 2016-10-01 Install carbon filters to reduce the lead content from the water outlet fixtures tested above the action level, or the allowable limits.
- 2016-10-02 Check for plumbing work. If copper pipes are joined with lead solder that has been installed, notify a qualified plumber to replace the lead solder with lead-free solder. Lead solder looks dull gray and when scratched with a key, looks shiny.
- 2016-10-03 Check type of piping used to connect to water main. Determine whether or not the service line that connects the building to the water line is made of lead.

## CONCLUSION

This survey revealed most of lead testing from water source fixtures indicated low or non-detectable exposures. However, 11 out of 245 samples were above the Action Level, 15 micrograms per liter ( $\mu\text{g/L}$ ) or parts per billion (ppb), listed in the report. No water fountains or kitchen sinks were above the action level.

The recommendations in this report are intended to achieve the goal of a safer and more healthful environment. If the recommendations are completed, future health issues should be prevented.

If there are any questions regarding the contents of this report or further assistance is needed for recommendation completion, please feel free to contact Dr. Justin Joe, who can be reached via the following:

Justin H. Joe, PhD, CSP  
BNF Consulting, Inc.  
152 Route 202, #404  
Lincolndale, NY 10540  
[bnfjustin@gmail.com](mailto:bnfjustin@gmail.com)

A closing Thank You is extended to all who assisted or participated in completion of this Survey.

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any representation contained herein. This information should not be construed as business, risk management, or legal advice or legal opinion.

APPENDIX A

LEAD WATER TESTING LAB RESULTS



Tuesday, October 25, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56447 - BV56480

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:40  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56447

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 635 A104 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:40  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56448

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 636 A104 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:40  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56449

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 637 A104 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:43  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56450

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 638 A106 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      10:43  
 10/18/16      16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56451

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 639 A106 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:43  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56452

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 640 A106 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:45  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56453

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 641 A118

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:45  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56454

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 642 A122

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0026	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:50  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56455

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 643 WF BY B105 HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:50  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56456

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 644 WF BY B105 LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:52  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56457

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 645 B105

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:52  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56458

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 646 B101A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:56  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56459

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 647 B101 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:56  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56460

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 648 B101 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:57  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56461

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 649 B101B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0042	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56462

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 650 B111A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0008	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      10:59  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56463

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 651 B111 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0009	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56464

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 652 B111 WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0084	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56465

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 653 B111 WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56466

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 654 B111 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56467

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 655 B111 LAUNDRY ROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

10:59  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56468

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 656 B111C

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      10:59  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56469

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 657 B111B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:08  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56470

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 658 B109

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:08  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56471

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 659 B104A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0034	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:08  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56472

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 660 B104B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0249	0.0020	4	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:08  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56473

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 661 B104C

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:08  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56474

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 662 B104D

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:13  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56475

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 663 C106 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:13  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56476

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 664 C106 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0026	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:13  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56477

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 665 C106 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      11:15  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56478

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 666 C102 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0101	0.0020	4	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:15  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56479

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 667 C102 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0030	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:15  
 16:10

## Laboratory Data

SDG ID: GBV56447  
 Phoenix ID: BV56480

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 668 C102 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0102	0.0020	4	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

October 25, 2016


## QA/QC Data

SDG I.D.: GBV56447

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 363443 (mg/L), QC Sample No: BV36548 (BV56469, BV56470, BV56471, BV56472, BV56473, BV56474)													
Lead	BRL	0.001	0.0647	0.064	1.10	89.2			96.4			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363354A (mg/L), QC Sample No: BV56240 (BV56447, BV56448)													
Lead	BRL	0.001				93.1			87.0			85 - 115	20
Comment: This batch does not include a duplicate. Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363362 (mg/L), QC Sample No: BV56449 (BV56449, BV56450, BV56451, BV56452, BV56453, BV56454, BV56455, BV56456, BV56457, BV56458)													
Lead	BRL	0.001	0.0024	0.0024	NC	85.7			80.8			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363362A (mg/L), QC Sample No: BV56459 (BV56459, BV56460, BV56461, BV56462, BV56463, BV56464, BV56465, BV56466, BV56467, BV56468)													
Lead	BRL	0.001				85.7			92.0			85 - 115	20
Comment: This batch does not include a duplicate. Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363443A (mg/L), QC Sample No: BV56475 (BV56475, BV56476, BV56477, BV56478, BV56479, BV56480)													
Lead	BRL	0.001				89.2			93.4			85 - 115	20
Comment: This batch does not include a duplicate. Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 October 25, 2016



Criteria: None

State: NY

# Sample Criteria Exceedances Report

## GBV56447 - BNFCNSLT

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV56472	PB-DW	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0249	0.0020	0.015	0.001	mg/L
BV56472	PB-DW	Lead	NY / NY Residential DW / Lead & Copper Als	0.0249	0.0020	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

October 25, 2016

SDG I.D.: GBV56447

---

The samples in this delivery group were received at 20°C.  
(Note acceptance criteria is above freezing up to 6°C)

BNP

1 of 8

## BCSD Lead Water Sampling COC - Fox Lane High School

20<sup>ac</sup>  
NC

635	10/14	2030	10/15	1040	FLHS	See the floor plan	A104 sink left	56447
636	10/14	2031	10/15	1040	FLHS	See the floor plan	A104 sink middle	56448
637	10/14	2032	10/15	1040	FLHS	See the floor plan	A104 sink right	56449
638	10/14	2033	10/15	1043	FLHS	See the floor plan	A106 sink left	56450
639	10/14	2033	10/15	1043	FLHS	See the floor plan	A106 sink middle	56451
640	10/14	2033	10/15	1043	FLHS	See the floor plan	A106 sink right	56452
641	10/14	2034	10/15	1045	FLHS	See the floor plan	A118	56453
642	10/14	2035	10/15	1045	FLHS	See the floor plan	A122	56454
643	10/14	2036	10/15	1050	FLHS	See the floor plan	WF by B105 high	56455
644	10/14	2037	10/15	1050	FLHS	See the floor plan	WF by B105 low	56456
645	10/14	2038	10/15	1052	FLHS	See the floor plan	B105	56457
646	10/14	2039	10/15	1052	FLHS	See the floor plan	B101a	56458
647	10/14	2040	10/15	1056	FLHS	See the floor plan	B101 sink left	56459
648	10/14	2040	10/15	1056	FLHS	See the floor plan	B101 sink right	56460
649	10/14	2040	10/15	1057	FLHS	See the floor plan	B101b	56461
650	10/14	2041	10/15	1059	FLHS	See the floor plan	B111a	56462
651	10/14	2041	10/15	1059	FLHS	See the floor plan	B111 sink left	56463
652	10/14	2041	10/15	1059	FLHS	See the floor plan	B111 WF left	56464
653	10/14	2041	10/15	1059	FLHS	See the floor plan	B111 WF right	56465
654	10/14	2041	10/15	1059	FLHS	See the floor plan	B111 sink right	56466
655	10/14	2041	10/15	1059	FLHS	See the floor plan	B111 laundry room	56467
656	10/14	2041	10/15	1059	FLHS	See the floor plan	B111c	56468
657	10/14	2041	10/15	1059	FLHS	See the floor plan	B111b	56469
658	10/14	2042	10/15	1108	FLHS	See the floor plan	B109	56470
659	10/14	2042	10/15	1108	FLHS	See the floor plan	B104a	56471
660	10/14	2042	10/15	1108	FLHS	See the floor plan	B104b	56472
661	10/14	2042	10/15	1108	FLHS	See the floor plan	B104c	56473
662	10/14	2042	10/15	1108	FLHS	See the floor plan	B104d	56474
663	10/14	2042	10/15	1113	FLHS	See the floor plan	C106 sink left	56475
664	10/14	2042	10/15	1113	FLHS	See the floor plan	C106 sink middle	56476
665	10/14	2042	10/15	1113	FLHS	See the floor plan	C106 sink right	56477
666	10/14	2043	10/15	1115	FLHS	See the floor plan	C102 sink left	56478
667	10/14	2043	10/15	1115	FLHS	See the floor plan	C102 sink middle	56479
668	10/14	2043	10/15	1115	FLHS	See the floor plan	C102 sink right	56480

BNP

BNF Consulting

BNP

10-18-16 14:40

10.18.16 16:10

# BCSD Lead Water Sampling COC - Fox Lane High School

2  
20<sup>00</sup>  
NC

669	10/14	2043	10/15	1118	FLHS	See the floor plan	WF by A204 High	56181
670	10/14	2043	10/15	1118	FLHS	See the floor plan	WF by A204 Low	56180
671	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink left	56181
672	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink middle	56182
673	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink right	56183
674	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink left	56184
675	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink middle	56185
676	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink right	56186
677	10/14	2047	10/15	1124	FLHS	See the floor plan	A218	56187
678	10/14	2047	10/15	1124	FLHS	See the floor plan	A222	56188
679	10/14	2047	10/15	1130	FLHS	See the floor plan	WF by A304 High	56189
680	10/14	2047	10/15	1130	FLHS	See the floor plan	WF by A304 Low	56190
681	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink left	56191
682	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink middle	56192
683	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink right	56193
684	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink left	56194
685	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink middle	56195
686	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink right	56196
687	10/14	2049	10/15	1134	FLHS	See the floor plan	A318	56197
688	10/14	2049	10/15	1134	FLHS	See the floor plan	A322	56198
689	10/14	2050	10/15	1140	FLHS	See the floor plan	C108	56199
690	10/14	2050	10/15	1140	FLHS	See the floor plan	C110	56200
691	10/14	2051	10/15	1142	FLHS	See the floor plan	C112	56201
692	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 left	56202
693	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 middle 1	56203
694	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 middle 2	56204
695	10/14	2054	10/15	1144	FLHS	See the floor plan	C111 right	56205
696	10/14	2055	10/15	1146	FLHS	See the floor plan	WF by C111	56206
697	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 left	56207
698	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 middle 1	56208
699	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 middle 2	56209
700	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 right	56210
701	10/14	2058	10/15	1148	FLHS	See the floor plan	C114	56211
702	10/14	2059	10/15	1150	FLHS	See the floor plan	C115 left	56212

Bank

BNF Consulting

Bank  
Yo

10-18-16 14:48

10-18-16 12:10

BNF

1 of 8

## BCSD Lead Water Sampling COC - Fox Lane High School

20<sup>th</sup>  
Nov

No	Flus	Flus	Flus	School	Location	Remark
635	10/14	2030	10/15	1040	FLHS	See the floor plan A104 sink left 56447
636	10/14	2031	10/15	1040	FLHS	See the floor plan A104 sink middle 56448
637	10/14	2032	10/15	1040	FLHS	See the floor plan A104 sink right 56449
638	10/14	2033	10/15	1043	FLHS	See the floor plan A106 sink left 56450
639	10/14	2033	10/15	1043	FLHS	See the floor plan A106 sink middle 56451
640	10/14	2033	10/15	1043	FLHS	See the floor plan A106 sink right 56452
641	10/14	2034	10/15	1045	FLHS	See the floor plan A118 56453
642	10/14	2035	10/15	1045	FLHS	See the floor plan A122 56454
643	10/14	2036	10/15	1050	FLHS	See the floor plan WF by B105 high 56455
644	10/14	2037	10/15	1050	FLHS	See the floor plan WF by B105 low 56456
645	10/14	2038	10/15	1052	FLHS	See the floor plan B105 56457
646	10/14	2039	10/15	1052	FLHS	See the floor plan B101a 56458
647	10/14	2040	10/15	1056	FLHS	See the floor plan B101 sink left 56459
648	10/14	2040	10/15	1056	FLHS	See the floor plan B101 sink right 56460
649	10/14	2040	10/15	1057	FLHS	See the floor plan B101b 56461
650	10/14	2041	10/15	1059	FLHS	See the floor plan B111a 56462
651	10/14	2041	10/15	1059	FLHS	See the floor plan B111 sink left 56463
652	10/14	2041	10/15	1059	FLHS	See the floor plan B111 WF left 56464
653	10/14	2041	10/15	1059	FLHS	See the floor plan B111 WF right 56465
654	10/14	2041	10/15	1059	FLHS	See the floor plan B111 sink right 56466
655	10/14	2041	10/15	1059	FLHS	See the floor plan B111 laundry room 56467
656	10/14	2041	10/15	1059	FLHS	See the floor plan B111c 56468
657	10/14	2041	10/15	1059	FLHS	See the floor plan B111b 56469
658	10/14	2042	10/15	1108	FLHS	See the floor plan B109 56470
659	10/14	2042	10/15	1108	FLHS	See the floor plan B104a 56471
660	10/14	2042	10/15	1108	FLHS	See the floor plan B104b 56472
661	10/14	2042	10/15	1108	FLHS	See the floor plan B104c 56473
662	10/14	2042	10/15	1108	FLHS	See the floor plan B104d 56474
663	10/14	2042	10/15	1113	FLHS	See the floor plan C106 sink left 56475
664	10/14	2042	10/15	1113	FLHS	See the floor plan C106 sink middle 56476
665	10/14	2042	10/15	1113	FLHS	See the floor plan C106 sink right 56477
666	10/14	2043	10/15	1115	FLHS	See the floor plan C102 sink left 56478
667	10/14	2043	10/15	1115	FLHS	See the floor plan C102 sink middle 56479
668	10/14	2043	10/15	1115	FLHS	See the floor plan C102 sink right 56480

BNF

BNF Consulting

BNF

10-18-16 14:40

10-18-16 16:10



Tuesday, October 25, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56180 - BV56212, BV56481

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

11:18  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56180

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 670 WF BY A204 LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

October 25, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:20  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56181

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 671 A204 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:20  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56182

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 672 A204 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:20  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56183

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 673 A204 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:22  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56184

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 674 A206 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      11:22  
 10/18/16      16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56185

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 675 A206 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**  
**October 25, 2016**  
**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:22  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56186

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 676 A206 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:24  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56187

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 677 A218

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:24  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56188

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 678 A222

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date                      Time  
 10/15/16                      11:30  
 10/18/16                      16:10

Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56189

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 679 WF BY A304 HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/W	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:30  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56190

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 680 WGF BY A304 LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:32  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56191

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 681 A304 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0009	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:32  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56192

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 682 A304 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:32  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56193

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 683 A304 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:32  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56194

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 684 A306 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:32  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56195

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 685 A306 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      11:32  
 10/18/16      0:00

Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56196

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 686 A306 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:34  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56197

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 687 A318

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:34  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56198

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 688 A322

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:40  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56199

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 689 C108

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0009	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:40  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56200

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 690 C110

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:42  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56201

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 691 C112

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0043	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:44  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56202

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 692 C111 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0030	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:44  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56203

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 693 C111 MIDDLE 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:44  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56204

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 694 C111 MIIDLE 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:44  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56205

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 695 C111 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:46  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56206

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 696 WF BY C111

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

11:47  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56207

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 697 C113 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:47  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56208

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 698 C113 MIDDLE 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:47  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56209

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 699 C113 MIDDLE 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:47  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56210

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 700 C113 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:48  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56211

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 701 C114

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

11:50  
 0:00

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56212

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 702 C115 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0069	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:18  
 16:10

## Laboratory Data

SDG ID: GBV56180  
 Phoenix ID: BV56481

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 669 WF BY A204 HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/19/16	:B/CB/B/BE200.9	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

October 25, 2016


## QA/QC Data

SDG I.D.: GBV56180

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 363351A (mg/L), QC Sample No: BV56180 (BV56180, BV56181, BV56182, BV56183, BV56184, BV56185, BV56186, BV56187, BV56188, BV56189)													
Lead	BRL	0.001				95.5			104			85 - 115	20
Comment: This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363352 (mg/L), QC Sample No: BV56190 (BV56190, BV56191, BV56192, BV56193, BV56194, BV56195, BV56196, BV56197, BV56198, BV56199)													
Lead	BRL	0.001	<0.0005	<0.001	NC	93.2			93.7			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363352A (mg/L), QC Sample No: BV56200 (BV56200, BV56201, BV56202, BV56203, BV56204, BV56205, BV56206, BV56207, BV56208, BV56209)													
Lead	BRL	0.001				93.2			102			85 - 115	20
Comment: This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363353 (mg/L), QC Sample No: BV56210 (BV56210, BV56211, BV56212)													
Lead	BRL	0.001	<0.0005	<0.001	NC	91.6			91.5			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363443A (mg/L), QC Sample No: BV56475 (BV56481)													
Lead	BRL	0.001				89.2			93.4			85 - 115	20
Comment: This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 October 25, 2016

# Sample Criteria Exceedances Report

Criteria: None

**GBV56180 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

---

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.





**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

October 25, 2016

SDG I.D.: GBV56180

---

The samples in this delivery group were received at 20°C.  
(Note acceptance criteria is above freezing up to 6°C)

BCSD Lead Water Sampling COC - Fox Lane High School

2  
30°C  
NC

No.	Date	Year	Time	Room	Location	Notes	Sample ID
669	10/14	2043	10/15	1118	FLHS	See the floor plan	WF by A204 High 56181
670	10/14	2043	10/15	1118	FLHS	See the floor plan	WF by A204 Low 56180
671	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink left 56181
672	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink middle 56182
673	10/14	2044	10/15	1120	FLHS	See the floor plan	A204 sink right 56183
674	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink left 56184
675	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink middle 56185
676	10/14	2046	10/15	1122	FLHS	See the floor plan	A206 sink right 56186
677	10/14	2047	10/15	1124	FLHS	See the floor plan	A218 56187
678	10/14	2047	10/15	1124	FLHS	See the floor plan	A222 56188
679	10/14	2047	10/15	1130	FLHS	See the floor plan	WF by A304 High 56189
680	10/14	2047	10/15	1130	FLHS	See the floor plan	WF by A304 Low 56190
681	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink left 56191
682	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink middle 56192
683	10/14	2048	10/15	1132	FLHS	See the floor plan	A304 sink right 56193
684	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink left 56194
685	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink middle 56195
686	10/14	2049	10/15	1132	FLHS	See the floor plan	A306 sink right 56196
687	10/14	2049	10/15	1134	FLHS	See the floor plan	A318 56197
688	10/14	2049	10/15	1134	FLHS	See the floor plan	A322 56198
689	10/14	2050	10/15	1140	FLHS	See the floor plan	C108 56199
690	10/14	2050	10/15	1140	FLHS	See the floor plan	C110 56200
691	10/14	2051	10/15	1142	FLHS	See the floor plan	C112 56201
692	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 left 56202
693	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 middle 1 56203
694	10/14	2053	10/15	1144	FLHS	See the floor plan	C111 middle 2 56204
695	10/14	2054	10/15	1144	FLHS	See the floor plan	C111 right 56205
696	10/14	2055	10/15	1146	FLHS	See the floor plan	WF by C111 56206
697	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 left 56207
698	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 middle 1 56208
699	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 middle 2 56209
700	10/14	2057	10/15	1147	FLHS	See the floor plan	C113 right 56210
701	10/14	2058	10/15	1148	FLHS	See the floor plan	C114 56211
702	10/14	2059	10/15	1150	FLHS	See the floor plan	C115 left 56212

*BNF*

BNF Consulting  
 10-18-16 14:48  
 10-18-16 16:10



Tuesday, October 25, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56213 - BV56246

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:50  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56213

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 703 C115 SINK MIDDLE 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:50  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56214

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 704 C115 SINK MIDDLE 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:50  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56215

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 705 C115 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:52  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56216

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 706 C116 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:52  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56217

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 707 C116 SINK MIDDLE 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:52  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56218

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 708 C116 SINK MIDDLE 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:52  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56219

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 709 C116 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:54  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56220

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 710 C213 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

11:54  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56221

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 711 C213 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:00  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56222

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 712 WF BY C213

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:08  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56223

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 713 C211 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0005	1	mg/L	0.015			10/23/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:08  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56224

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 714 C211 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

12:10  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56225

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 715 CUSTODIAL CLOSET BY C213

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0155	0.0020	4	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:12  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56226

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 716 C210 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0034	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:12  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56227

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 717 C210 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0050	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:12  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56228

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 718 C210 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0036	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:12  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56229

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 719 C210 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:12  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56230

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 720 C210 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:12  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56231

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 721 C210 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0026	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:12  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56232

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 722 C210 SINK FRONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0007	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56233

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 723 C215 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56234

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 724 C215 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56235

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 725 C215 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56236

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 726 C215 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

## Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

## Date

10/15/16  
 10/18/16

## Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56237

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 727 C215 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56238

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 728 C215 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0009	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:15  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56239

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 729 C215 SINK FRONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:18  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56240

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 730 C212

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0005	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:19  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56241

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 731 C214 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:19  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56242

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 732 C214 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:19  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56243

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 733 C214 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:19  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56244

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 734 C214 SINK MIIDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0009	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:19  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56245

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 735 C214 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 25, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

12:19  
 16:10

## Laboratory Data

SDG ID: GBV56213  
 Phoenix ID: BV56246

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 736 C214 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	1	mg/L	0.015			10/24/16	RS	E200.9/SM3113B-10
Total Metal Digestion	Completed							10/18/16	/CB	E200.9

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 25, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

October 25, 2016


## QA/QC Data

SDG I.D.: GBV56213

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 363353 (mg/L), QC Sample No: BV56210 (BV56213, BV56214, BV56215, BV56216, BV56217, BV56218, BV56219)													
Lead	BRL	0.001	<0.0005	<0.001	NC	91.6			91.5			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363353A (mg/L), QC Sample No: BV56220 (BV56220, BV56221, BV56222, BV56223, BV56224, BV56225, BV56226, BV56227, BV56228, BV56229)													
Lead	BRL	0.001				91.6			100			85 - 115	20
Comment: This batch does not include a duplicate. Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363354 (mg/L), QC Sample No: BV56230 (BV56230, BV56231, BV56232, BV56233, BV56234, BV56235, BV56236, BV56237, BV56238, BV56239)													
Lead	BRL	0.001	0.0018	0.0018	NC	93.1			83.3			85 - 115	20
Comment: Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 363354A (mg/L), QC Sample No: BV56240 (BV56240, BV56241, BV56242, BV56243, BV56244, BV56245, BV56246)													
Lead	BRL	0.001				93.1			87.0			85 - 115	20
Comment: This batch does not include a duplicate. Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 October 25, 2016



Criteria: None

State: NY

# Sample Criteria Exceedances Report

## GBV56213 - BNFCNSLT

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV56225	PB-DW	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0155	0.0020	0.015	0.001	mg/L
BV56225	PB-DW	Lead	NY / NY Residential DW / Lead & Copper Als	0.0155	0.0020	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.

# BCSD Lead Water Sampling COC - Fox Lane High School

3  
2000 NC

No.	Date	ID	Date	ID	Site	Location	Remark
703	10/14	2059	10/15	1150	FLHS	See the floor plan	C115 sink middle 1 56213
704	10/14	2059	10/15	1150	FLHS	See the floor plan	C115 sink middle 2 56214
705	10/14	2059	10/15	1150	FLHS	See the floor plan	C115 sink right 56215
706	10/14	2059	10/15	1152	FLHS	See the floor plan	C116 sink left 56216
707	10/14	2059	10/15	1152	FLHS	See the floor plan	C116 sink middle 1 56217
708	10/14	2059	10/15	1152	FLHS	See the floor plan	C116 sink middle 2 56218
709	10/14	2059	10/15	1152	FLHS	See the floor plan	C116 sink right 56219
710	10/14	2103	10/15	1154	FLHS	See the floor plan	C213 sink left 56220
711	10/14	2103	10/15	1154	FLHS	See the floor plan	C213 sink right 56221
712	10/14	2104	10/15	1200	FLHS	See the floor plan	WF by C213 56222
713	10/14	2105	10/15	1208	FLHS	See the floor plan	C211 sink left 56223
714	10/14	2105	10/15	1208	FLHS	See the floor plan	C211 sink right 56224
715	10/14	2106	10/15	1210	FLHS	See the floor plan	Custodial closet by C213 56225
716	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink window side 56226
717	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink window side 56227
718	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink middle 56228
719	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink middle 56229
720	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink hallway side 56230
721	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink hallway side 56231
722	10/14	2107	10/15	1212	FLHS	See the floor plan	C210 sink front desk 56232
723	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink window side 56233
724	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink window side 56234
725	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink middle 56235
726	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink middle 56236
727	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink hallway side 56237
728	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink hallway side 56238
729	10/14	2111	10/15	1215	FLHS	See the floor plan	C215 sink front desk 56239
730	10/14	2113	10/15	1218	FLHS	See the floor plan	C212 56240
731	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink window side 56241
732	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink window side 56242
733	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink middle 56243
734	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink middle 56244
735	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink hallway side 56245
736	10/14	2114	10/15	1219	FLHS	See the floor plan	C214 sink hallway side 56246

*Bank*

BNF Consulting

*Bank* 10/18/16 14:40  
*yz* 10/18/16 16:10



Tuesday, November 08, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56247 - BV56280

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:19  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56247

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 737 C214 SINK FRONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:22  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56248

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 738 C217

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:23  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56249

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 739 C219

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56250

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 740 C221 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56251

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 741 C221 SINK WINDOW SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56252

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 742 C221 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56253

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 743 C221 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0052	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56254

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 744 C221 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0065	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56255

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 745 C221 SINK HALLWAY SIDE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56256

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 746 C221 SINK FRONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:29  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56257

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 747 C216/C218

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:29  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56258

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 748 E109 WF HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:29  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56259

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 749 E109 EF LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56260

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 750 KITCHEN FRONT ROW SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        13:35  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56261

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 751 KITCHEN SINK SIDE WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0013	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56262

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 752 KITCHEN SINK REAR LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date                      Time  
 10/15/16                      13:35  
 10/18/16                      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56263

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 753 KITCHEN SINK REAR MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56264

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 754 KITCHEN SINK REAR RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56265

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 755 KITCHEN STEAMER

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56266

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 756 KITCHEN SINK CENTER LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56267

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 757 KITCHEN SINK CENTER RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56268

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 758 KITCHEN BATHROOM LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			11/04/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56269

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 759 KITCHEN BATHROOM RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0071	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56270

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 760 KITCHEN CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        13:51  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56271

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 761 E108

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0028	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:51  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56272

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 762 E124

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:53  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56273

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 763 F103 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:53  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56274

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 764 F103 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:53  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56275

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 765 F103 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56276

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 766 F105 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/07/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56277

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 767 F105 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56278

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 768 F105 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56279

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 769 F105 CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 08, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:00  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56247  
 Phoenix ID: BV56280

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 770 F109

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 08, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 08, 2016

## QA/QC Data

SDG I.D.: GBV56247

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 363971 (mg/L), QC Sample No: BV56162 (BV56247)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0037	0.0038	NC	99.2			98.4			85 - 115	20
------	-----	--------	--------	--------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363971A (mg/L), QC Sample No: BV56248 (BV56248, BV56249, BV56250, BV56251, BV56252, BV56253, BV56254, BV56255, BV56256, BV56257)

### ICP Metals - Aqueous

Lead	BRL	0.0010				99.2			96.1			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363972 (mg/L), QC Sample No: BV56258 (BV56258, BV56259, BV56260, BV56261, BV56262, BV56263, BV56264, BV56265, BV56266, BV56267)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0011	<0.0010	NC	97.1			99.1			85 - 115	20
------	-----	--------	--------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363972A (mg/L), QC Sample No: BV56268 (BV56268, BV56269, BV56270, BV56271, BV56272, BV56273, BV56274, BV56275, BV56276, BV56277)

### ICP Metals - Aqueous

Lead	BRL	0.0010				97.1			97.2			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363973 (mg/L), QC Sample No: BV56278 (BV56278, BV56279, BV56280)

### ICP Metals - Aqueous


Lead	BRL	0.0010	0.0022	0.0015	NC	99.3			95.8			85 - 115	20
------	-----	--------	--------	--------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 November 08, 2016

# Sample Criteria Exceedances Report

Criteria: None

**GBV56247 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

---

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

November 08, 2016

SDG I.D.: GBV56247

---

The samples in this delivery group were received at 20°C.  
(Note acceptance criteria is above freezing up to 6°C)



BCSD Lead Water Sampling COC - Fox Lane High School

4 70°C  
NC

737	10/14	214	10/15	1219	FLHS	See the floor plan	C214 sink front desk	56247
738	10/14	216	10/15	1222	FLHS	See the floor plan	C217	56248
739	10/14	216	10/15	123	FLHS	See the floor plan	C219	56249
740	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink window side	56250
741	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink window side	56251
742	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink middle	56252
743	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink middle	56253
744	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink hallway side	56254
745	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink hallway side	56255
746	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink front desk	56256
747	10/14	2119	10/15	1229	FLHS	See the floor plan	C216/C218	56257
748	10/14	2145	10/15	1329	FLHS	See the floor plan	E109 WF High	56258
749	10/14	2145	10/15	1329	FLHS	See the floor plan	E109 WF Low	56259
750	10/14	2147	10/15	1335	FLHS	See the floor plan	Kitchen front row sink	56260
751	10/14	2147	10/15	1335	FLHS	See the floor plan	Kitchen sink side wall	56261
752	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear left	56262
753	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear middle	56263
754	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear right	56264
755	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen steamer	56265
756	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink center left	56266
757	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink center right	56267
758	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen bathroom left	56268
759	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen bathroom right	56269
760	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen custodial closet	56270
761	10/14	2149	10/15	1351	FLHS	See the floor plan	E108	56271
762	10/14	2149	10/15	1351	FLHS	See the floor plan	E124	56272
763	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink left	56273
764	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink middle	56274
765	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink right	56275
766	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink left	56276
767	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink middle	56277
768	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink right	56278
769	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 custodial closet	56279
770	10/14	2153	10/15	1400	FLHS	See the floor plan	F109	56280

Blank 10-18-16 14:40

Blank

BCSD Lead Water Sampling COC - Fox Lane High School

5 20<sup>00</sup>  
NC

771	10/14	2155	10/15	1400	FLHS	See the floor plan	F11 Girls green room left	56281
772	10/14	2155	10/15	1400	FLHS	See the floor plan	F11 Girls green room right	56282
773	10/14	2157	10/15	1402	FLHS	See the floor plan	F113	56283
774	10/14	2157	10/15	1402	FLHS	See the floor plan	F113 Boys green room left	56284
775	10/14	2157	10/15	1402	FLHS	See the floor plan	F113 Boys green room right	56285
776	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink left	56286
777	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink middle	56287
778	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink right	56288
779	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 1	56289
780	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 2	56290
781	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 3	56291
782	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink right 1	56292
783	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink right 2	56293
784	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink left	56294
785	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink middle	56295
786	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink right	56296
787	10/14	2205	10/15	1410	FLHS	See the floor plan	F123 WF	56297
788	10/14	2206	10/15	1410	FLHS	See the floor plan	Faculty room sink by F123	56298
789	10/14	2208	10/15	1415	FLHS	See the floor plan	F127	56299
790	10/14	2209	10/15	1416	FLHS	See the floor plan	Custodial closet by F129	56300
791	10/14	2215	10/15	1420	FLHS	See the floor plan	D147 sink left	56301
792	10/14	2215	10/15	1420	FLHS	See the floor plan	D147 sink right	56302
793	10/14	2217	10/15	1421	FLHS	See the floor plan	D140	56303
794	10/14	2218	10/15	1422	FLHS	See the floor plan	D137d	56304
795	10/14	2220	10/15	1424	FLHS	See the floor plan	D150 sink left	56305
796	10/14	2220	10/15	1424	FLHS	See the floor plan	D150 sink right	56306
797	10/14	2222	10/15	1435	FLHS	See the floor plan	D117 sink left	56307
798	10/14	2222	10/15	1435	FLHS	See the floor plan	D117 sink right	56308
799	10/14	2224	10/15	1435	FLHS	See the floor plan	D123 sink left	56309
800	10/14	2224	10/15	1435	FLHS	See the floor plan	D123 sink right	56310
801	10/14	2121	10/15	1325	FLHS	See the floor plan	C311	56311
802	10/14	2121	10/15	1325	FLHS	See the floor plan	C311	56312
803	10/14	2122	10/15	1330	FLHS	See the floor plan	WF by C313	56313
804	10/14	2123	10/15	1330	FLHS	See the floor plan	C313 L	56314

Band

BNF Consulting

Band 10/18/16 14:40

yz 10/18/16 16:10

BCSD Lead Water Sampling COC - Fox Lane High School

4 70°C  
NC

NO	Flushed At	Sample ID	Date	Time	School	Location	Remark
737	10/14	214	10/15	1219	FLHS	See the floor plan	C214 sink front desk 56247
738	10/14	216	10/15	1222	FLHS	See the floor plan	C217 56248
739	10/14	216	10/15	123	FLHS	See the floor plan	C219 56249
740	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink window side 56250
741	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink window side 56251
742	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink middle 56252
743	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink middle 56253
744	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink hallway side 56254
745	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink hallway side 56255
746	10/14	2117	10/15	1225	FLHS	See the floor plan	C221 sink front desk 56256
747	10/14	2119	10/15	1229	FLHS	See the floor plan	C216/C218 56257
748	10/14	2145	10/15	1329	FLHS	See the floor plan	E109 WF High 56258
749	10/14	2145	10/15	1329	FLHS	See the floor plan	E109 WF Low 56259
750	10/14	2147	10/15	1335	FLHS	See the floor plan	Kitchen front row sink 56260
751	10/14	2147	10/15	1335	FLHS	See the floor plan	Kitchen sink side wall 56261
752	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear left 56262
753	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear middle 56263
754	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink rear right 56264
755	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen steamer 56265
756	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink center left 56266
757	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen sink center right 56267
758	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen bathroom left 56268
759	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen bathroom right 56269
760	10/14	2147	10/15	1335	FLHS	See the floor plan	kitchen custodial closet 56270
761	10/14	2149	10/15	1351	FLHS	See the floor plan	E108 56271
762	10/14	2149	10/15	1351	FLHS	See the floor plan	E124 56272
763	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink left 56273
764	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink middle 56274
765	10/14	2151	10/15	1353	FLHS	See the floor plan	F103 sink right 56275
766	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink left 56276
767	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink middle 56277
768	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 sink right 56278
769	10/14	2151	10/15	1355	FLHS	See the floor plan	F105 custodial closet 56279
770	10/14	2153	10/15	1400	FLHS	See the floor plan	F109 56280

Blank 10-18-16 14:48

*Blank*



Monday, November 07, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56281 - BV56314

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:00  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56281

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 771 F11 GIRLS GREEN ROOM LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0148	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:00  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56282

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 772 G11 GIRLS GREEN ROOM RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.94	0.010	10	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:02  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56283

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 773 F113

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0042	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

14:02  
 15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56284

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 774 F113 BOYS GREEN ROOM LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0194	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date

10/15/16  
 10/18/16

Time

14:02  
 15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56285

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 775 F113 BOYS GREEN ROOM RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0190	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:04  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56286

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 776 F115 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0152	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:04  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56287

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 777 F115 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:04  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56288

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 778 F115 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0028	0.0010	1	mg/L	0.015			11/05/16	TH	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:06  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56289

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 779 F117 SINK LEFT 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0050	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:06  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56290

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 780 F117 SINK LEFT 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:06  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56291

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 781 F117 SINK LEFT 3

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0036	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:06  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56292

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 782 F117 SINK RIGHT 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:06  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56293

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 783 F117 SINK RIGHT 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:08  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56294

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 784 F119 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:08  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56295

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 785 F119 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:08  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56296

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 786 F119 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:10  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56297

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 787 F123 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:10  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56298

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 788 FACULTY ROOM SINK BY F123

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:15  
 10/18/16        16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56299

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 789 F127

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:16  
 10/18/16        16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56300

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 790 CUSTODIAL CLOSET BY F129

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56301

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 791 D147 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56302

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 792 D147 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:21  
 10/18/16        16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56303

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 793 D140

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:22  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56304

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 794 D137D

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:24  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56305

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 795 D150 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:24  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56306

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 796 D150 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:35  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56307

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 797 D117 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:35  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56308

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 798 D117 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:35  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56309

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 799 D123 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:35  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56310

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 800 D123 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:25  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56311

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 801 C311

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:25  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56312

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 802 C311

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:30  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56313

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 803 WF BY C313

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:30  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56281  
 Phoenix ID: BV56314

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 804 C313 L

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 07, 2016

## QA/QC Data

SDG I.D.: GBV56281

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 363973 (mg/L), QC Sample No: BV56278 (BV56281, BV56282, BV56283, BV56284, BV56285, BV56286, BV56287)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0022	0.0015	NC	99.3			95.8			85 - 115	20
------	-----	--------	--------	--------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363973A (mg/L), QC Sample No: BV56288 (BV56288, BV56289, BV56290, BV56291, BV56292, BV56293, BV56294, BV56295, BV56296, BV56297)

### ICP Metals - Aqueous

Lead	BRL	0.0010				99.3			96.9			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363974 (mg/L), QC Sample No: BV56298 (BV56298, BV56299, BV56300, BV56301, BV56302, BV56303, BV56304, BV56305, BV56306, BV56307)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0018	<0.0010	NC	98.2			95.9			85 - 115	20
------	-----	--------	--------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363974A (mg/L), QC Sample No: BV56308 (BV56308, BV56309, BV56310, BV56311, BV56312, BV56313, BV56314)

### ICP Metals - Aqueous

Lead	BRL	0.0010				98.2			92.9			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----


Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 November 07, 2016

# Sample Criteria Exceedances Report

Criteria: None

## GBV56281 - BNFCNSLT

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV56282	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	1.94	0.010	0.015	0.001	mg/L
BV56282	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	1.94	0.010	0.015	0.015	mg/L
BV56284	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0194	0.0010	0.015	0.001	mg/L
BV56284	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0194	0.0010	0.015	0.015	mg/L
BV56285	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0190	0.0010	0.015	0.001	mg/L
BV56285	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0190	0.0010	0.015	0.015	mg/L
BV56286	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0152	0.0010	0.015	0.001	mg/L
BV56286	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0152	0.0010	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



BCSD Lead Water Sampling COC - Fox Lane High School

5 20<sup>00</sup>  
NC

NO	Flushed at		Draw at		School	Location	Remark
	Day	Time	Day	Time			
771	10/14	2155	10/15	1400	FLHS	See the floor plan	F11 Girls green room left 56281
772	10/14	2155	10/15	1400	FLHS	See the floor plan	F11 Girls green room right 56282
773	10/14	2157	10/15	1402	FLHS	See the floor plan	F113 56283
774	10/14	2157	10/15	1402	FLHS	See the floor plan	F113 Boys green room left 56284
775	10/14	2157	10/15	1402	FLHS	See the floor plan	F113 Boys green room right 56285
776	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink left 56286
777	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink middle 56287
778	10/14	2159	10/15	1404	FLHS	See the floor plan	F115 Sink right 56288
779	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 1 56289
780	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 2 56290
781	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink left 3 56291
782	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink right 1 56292
783	10/14	2201	10/15	1406	FLHS	See the floor plan	F117 sink right 2 56293
784	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink left 56294
785	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink middle 56295
786	10/14	2204	10/15	1408	FLHS	See the floor plan	F119 sink right 56296
787	10/14	2205	10/15	1410	FLHS	See the floor plan	F123 WF 56297
788	10/14	2206	10/15	1410	FLHS	See the floor plan	Faculty room sink by F123 56298
789	10/14	2208	10/15	1415	FLHS	See the floor plan	F127 56299
790	10/14	2209	10/15	1416	FLHS	See the floor plan	Custodial closet by F129 56300
791	10/14	2215	10/15	1420	FLHS	See the floor plan	D147 sink left 56301
792	10/14	2215	10/15	1420	FLHS	See the floor plan	D147 sink right 56302
793	10/14	2217	10/15	1421	FLHS	See the floor plan	D140 56303
794	10/14	2218	10/15	1422	FLHS	See the floor plan	D137d 56304
795	10/14	2220	10/15	1424	FLHS	See the floor plan	D150 sink left 56305
796	10/14	2220	10/15	1424	FLHS	See the floor plan	D150 sink right 56306
797	10/14	2222	10/15	1435	FLHS	See the floor plan	D117 sink left 56307
798	10/14	2222	10/15	1435	FLHS	See the floor plan	D117 sink right 56308
799	10/14	2224	10/15	1435	FLHS	See the floor plan	D123 sink left 56309
800	10/14	2224	10/15	1435	FLHS	See the floor plan	D123 sink right 56310
801	10/14	2121	10/15	1325	FLHS	See the floor plan	C311 56311
802	10/14	2121	10/15	1325	FLHS	See the floor plan	C311 56312
803	10/14	2122	10/15	1330	FLHS	See the floor plan	WF by C313 56313
804	10/14	2123	10/15	1330	FLHS	See the floor plan	C313 L 56314

Blank

BNF Consulting

Blank 10/18/16 14:40

yz 10/18/16 16:10



Monday, November 07, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56315 - BV56348

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:30  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56315

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 805 C313 R

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0051	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56316

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 806 C315 SINK WINDOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0044	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56317

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 807 C315 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0030	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56318

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 808 C315 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0053	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56319

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 809 C315 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0037	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56320

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 810 C315 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0012	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56321

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 811 C315 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56322

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 812 C315 SINK WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:20  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56323

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 813 C315 SINK FRONT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0046	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56324

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 814 C310 SINK WINDOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56325

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 815 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56326

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 816 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56327

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 817 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0028	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56328

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 818 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56329

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 819 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0035	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56330

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 820 C310 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:08  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56331

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 821 C310 SINK WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0047	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:05  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56332

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 822 C312

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56333

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 823 C314 SINK WINDOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56334

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 824 C314 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        12:58  
 10/18/16        16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56335

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 825 C314 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56336

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 826 C314 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56337

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 827 C314 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56338

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 828 C314 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0013	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56339

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 829 C314 SINK WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:58  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56340

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 830 C314 SINK FRONT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:05  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56341

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 831 C317

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0018	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:05  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56342

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 832 C319

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56343

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 833 C321 SINK WINDOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        12:48  
 10/18/16        16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56344

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 834 C321 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56345

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 835 C321 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56346

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 836 C321 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0061	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56347

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 837 C321 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0031	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      16:10

Laboratory Data

SDG ID: GBV56315  
 Phoenix ID: BV56348

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 838 C321 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0034	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 07, 2016

## QA/QC Data

SDG I.D.: GBV56315

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 363974A (mg/L), QC Sample No: BV56308 (BV56315, BV56316, BV56317)

### ICP Metals - Aqueous

Lead	BRL	0.0010				98.2			92.9			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363976 (mg/L), QC Sample No: BV56318 (BV56318, BV56319, BV56320, BV56321, BV56322, BV56323, BV56324, BV56325, BV56326, BV56327)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0053	0.0052	1.90	92.3			94.0			85 - 115	20
------	-----	--------	--------	--------	------	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363976A (mg/L), QC Sample No: BV56328 (BV56328, BV56329, BV56330, BV56331, BV56332, BV56333, BV56334, BV56335, BV56336, BV56337)

### ICP Metals - Aqueous

Lead	BRL	0.0010				92.3			95.9			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363977 (mg/L), QC Sample No: BV56338 (BV56338, BV56339, BV56340, BV56341, BV56342, BV56343, BV56344, BV56345, BV56346, BV56347)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0013	<0.0010	NC	98.1			92.9			85 - 115	20
------	-----	--------	--------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363977A (mg/L), QC Sample No: BV56348 (BV56348)

### ICP Metals - Aqueous

Lead	BRL	0.0010				98.1			97.2			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

# QA/QC Data


SDG I.D.: GBV56315

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

---

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference



Phyllis Shiller, Laboratory Director  
November 07, 2016

# Sample Criteria Exceedances Report

Criteria: None

**GBV56315 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.

# BCSD Lead Water Sampling COC - Fox Lane High School

6 20°C  
NC

NO	Flushed at		Drew at		School	Location	Remark
	Date	Time	Date	Time			
805	10/14	2123	10/15	1330	FLHS	See the floor plan	C313 R 56315
806	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink window 56316
807	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink middle 56317
808	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink middle 56318
809	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink middle 56319
810	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink middle 56320
811	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink middle 56321
812	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink wall 56322
813	10/14	2125	10/15	1320	FLHS	See the floor plan	C315 sink front 56323
814	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink window 56324
815	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56325
816	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56326
817	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56327
818	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56328
819	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56329
820	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink middle 56330
821	10/14	2127	10/15	1308	FLHS	See the floor plan	C310 sink wall 56331
822	10/14	2129	10/15	1305	FLHS	See the floor plan	C312 56332
823	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink window 56333
824	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink middle 56334
825	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink middle 56335
826	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink middle 56336
827	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink middle 56337
828	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink middle 56338
829	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink wall 56339
830	10/14	2131	10/15	1258	FLHS	See the floor plan	C314 sink front 56340
831	10/14	2132	10/15	1305	FLHS	See the floor plan	C317 56341
832	10/14	2133	10/15	1305	FLHS	See the floor plan	C319 56342
833	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink window 56343
834	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink middle 56344
835	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink middle 56345
836	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink middle 56346
837	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink middle 56347
838	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 sink middle 56348

*BAK*

BNF Consulting

*BAK* 10-18-16 14:40  
*yz* 10-18-16 16:10





Monday, November 07, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: FOX LANE HIGH SCHOOL  
Sample ID#s: BV56349 - BV56389

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:48  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56349

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 839 C321 SINK WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        12:48  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56350

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 840 C321 SINK FRONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0026	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56351

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 841 C316 SINK WINDOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0072	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        12:55  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56352

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 842 C316 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0030	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56353

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 843 C316 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56354

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 844 C316 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56355

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 845 C316 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56356

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 846 C316 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56357

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 847 C316 SINK WALL

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/RWR/AGE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      12:55  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56358

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 848 C316 SINK FONT DESK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      13:34  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56359

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 849 C313 CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0238	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:39  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56360

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 850 WF BY D105

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:39  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56361

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 851 D101

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:42  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56362

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 852 E101

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:24  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56363

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 853 D146 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0039	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date                      Time  
 10/15/16                      14:24  
 10/18/16                      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56364

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 854 D146 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0032	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:24  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56365

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 855 D146 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0058	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:38  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56366

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 856 D142 LEFT (DARK ROOM)

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:38  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56367

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 857 D142 RIGHT (DARK ROOM)

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0012	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:34  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56368

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 858 EF BY D153

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0012	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:32  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56369

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 859 D153 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:32  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56370

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 860 D153 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:30  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56371

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 861 D159 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0037	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:30  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56372

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 862 D159 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0038	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:24  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56373

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 863 D146 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0047	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:47  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56374

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 864 D105

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        14:47  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56375

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 865 D107

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      14:58  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56376

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 866 EXTERIOR BY A112

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.149	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:00  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56377

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 867 EXTERIOR BY D127

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0092	0.0010	1	mg/L	0.015			11/05/16	LK	E200.5
Total Metal Digestion	Completed							10/22/16	/AG/RWRE200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:15  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56378

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 868 EXTERIOR BY A105

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0195	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:19  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56379

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 869 EXTERIOR BY A119

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0303	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:20  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56380

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 870 EXTERIOR BY MAINTENANCE SHOP

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:21  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56381

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 871 HEAD CUSTODIANS OFFICE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:22  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56382

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 872 B021

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:24  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56383

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 873 B020 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:24  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56384

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 874 B020 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:25  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56385

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 875 WF BY B02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:30  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56386

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 876 BREAKROOM BY B020

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:35  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56387

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 877 MAINTENANCE SHOP OFFICE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date      Time  
 10/15/16      15:40  
 10/18/16      15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56388

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 878 GARAGE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0164	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 07, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: LK  
 Analyzed by: see "By" below

Date            Time  
 10/15/16        12:03  
 10/18/16        15:49

Laboratory Data

SDG ID: GBV56349  
 Phoenix ID: BV56389

Project ID: FOX LANE HIGH SCHOOL  
 Client ID: 709A RM C117 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/23/16	G/Q/G/M	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 07, 2016**

**Reviewed and Released by: Kathleen Cressia, QA/QC Officer**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 07, 2016

## QA/QC Data

SDG I.D.: GBV56349

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 363977A (mg/L), QC Sample No: BV56348 (BV56349, BV56350, BV56351, BV56352, BV56353, BV56354, BV56355, BV56356, BV56357)

### ICP Metals - Aqueous

Lead	BRL	0.0010				98.1			97.2			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363978 (mg/L), QC Sample No: BV56358 (BV56358, BV56359, BV56360, BV56361, BV56362, BV56363, BV56364, BV56365, BV56366, BV56367)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0011	<0.0010	NC	94.0			96.7			85 - 115	20
------	-----	--------	--------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363978A (mg/L), QC Sample No: BV56368 (BV56368, BV56369, BV56370, BV56371, BV56372, BV56373, BV56374, BV56375, BV56376, BV56377)

### ICP Metals - Aqueous

Lead	BRL	0.0010				94.0			95.6			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363986 (mg/L), QC Sample No: BV56378 (BV56378, BV56379, BV56380, BV56381, BV56382, BV56383, BV56384, BV56385, BV56386, BV56387)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0195	0.0182	6.90	98.9			93.5			85 - 115	20
------	-----	--------	--------	--------	------	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363986A (mg/L), QC Sample No: BV56388 (BV56388, BV56389)

### ICP Metals - Aqueous

Lead	BRL	0.0010				98.9			97.5			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

# QA/QC Data


SDG I.D.: GBV56349

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

---

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference



Phyllis Shiller, Laboratory Director  
November 07, 2016

**Sample Criteria Exceedances Report**

Criteria: None

**GBV56349 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV56359	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0238	0.0010	0.015	0.001	mg/L
BV56359	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0238	0.0010	0.015	0.015	mg/L
BV56376	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.149	0.0010	0.015	0.001	mg/L
BV56376	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.149	0.0010	0.015	0.015	mg/L
BV56378	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0195	0.0010	0.015	0.001	mg/L
BV56378	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0195	0.0010	0.015	0.015	mg/L
BV56379	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0303	0.0010	0.015	0.001	mg/L
BV56379	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0303	0.0010	0.015	0.015	mg/L
BV56388	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0164	0.0010	0.015	0.001	mg/L
BV56388	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0164	0.0010	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.

BCSD Lead Water Sampling COC - Fox Lane High School

7 20°C  
NC

839	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 Sink wall 56349
840	10/14	2135	10/15	1248	FLHS	See the floor plan	C321 Sink front desk 56350
841	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink window 56351
842	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink middle 56352
843	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink middle 56353
844	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink middle 56354
845	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink middle 56355
846	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink middle 56356
847	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink wall 56357
848	10/14	2137	10/15	1255	FLHS	See the floor plan	C316 Sink front desk 56358
849	10/14	2139	10/15	1334	FLHS	See the floor plan	C313 custodial closet 56359
850	10/14	2226	10/15	1439	FLHS	See the floor plan	WF by D105 56360
851	10/14	2227	10/15	1439	FLHS	See the floor plan	D101 56361
852	10/14		10/15	1442	FLHS	See the floor plan	E101 56362
853	10/14	2229	10/15	1424	FLHS	See the floor plan	D146 sink left 56363
854	10/14	2229	10/15	1424	FLHS	See the floor plan	D146 sink middle 56364
855	10/14	2231	10/15	1424	FLHS	See the floor plan	D146 sink middle 56365
856	10/14	2233	10/15	1438	FLHS	See the floor plan	D142 left (Dark room) 56366
857	10/14	2233	10/15	1438	FLHS	See the floor plan	D142 right (Dark room) 56367
858	10/14	2236	10/15	1434	FLHS	See the floor plan	WF by D153 56368
859	10/14	2238	10/15	1432	FLHS	See the floor plan	D153 Left 56369
860	10/14	2238	10/15	1432	FLHS	See the floor plan	D153 Right 56370
861	10/14	2240	10/15	1430	FLHS	See the floor plan	D159 Left 56371
862	10/14	2240	10/15	1430	FLHS	See the floor plan	D159 Right 56372
863	10/14	2242	10/15	1424	FLHS	See the floor plan	D146 Right 56373
864	10/14	2245	10/15	1447	FLHS	See the floor plan	D105 56374
865	10/14	2246	10/15	1447	FLHS	See the floor plan	D107 56375
866	10/14	2308	10/15	1458	FLHS	See the floor plan	Exterior by A112 56376
867	10/14	2310	10/15	1500	FLHS	See the floor plan	Exterior by D127 56377
868	10/14	2312	10/15	1515	FLHS	See the floor plan	Exterior by A105 56378
869	10/14	2304	10/15	1519	FLHS	See the floor plan	Exterior by A119 56379
870	10/14	2250	10/15	1520	FLHS	See the floor plan	Exterior by maintenance shop 56380
871	10/14	2252	10/15	1521	FLHS	See the floor plan	Head custodian's office 56381
872	10/14	2254	10/15	1522	FLHS	See the floor plan	B021 56382

BAK

BNF Consulting

BAK 10-18-16 14:40  
GZ 10.18.16 16:10

