



BEDFORD CENTRAL SCHOOL DISTRICT
FOX LANE CAMPUS
P.O. BOX 180
MOUNT KISCO, NY 10549

LEAD WATER TESTING

For

Mount Kisco Elementary School
47 West Hyatt Ave
Mount Kisco, NY 10549

Date of Assessment: October 12, 2016

Date of Report: November 4, 2016

Completed By: Justin Joe, PhD, CSP
Industrial Hygienist / Building Inspector
BNF Consulting, Inc.
152 Route 202, #404
Lincolndale, NY 10540
bnfjustin@gmail.com

EXECUTIVE SUMMARY

On October 12, 2016, lead water testing was completed for Mount Kisco Elementary School, one of the Bedford Central School District (BCSD) schools, located at 47 West Hyatt Ave, Mount Kisco, NY 10549. Primarily assisting in the completion of this study were Mr. Gregory Sullivan, Interim Assistant Superintendent; Mr. Shawn Pitruille, Interim Director of Buildings and Grounds; and the maintenance staff in MKES.

The purpose of this survey is to comply to 10 NYCRR SUBPART 67-4: Lead Testing in School Drinking Water. This subpart requires all school districts and boards of cooperative education services, including those already classified as a public water system under 10 NYCRR Subpart 5-1, to test portable water for lead contamination and to develop and implement a lead remediation plan when applicable. Action Level used in the Subpart means 15 micrograms per liter ($\mu\text{g/L}$) or parts per billion (ppb). Exceedance of the action level requires a response to implement a lead remediation plan.

First-draw water samples were collected from all available water outlets including faucets, sinks and water fountains in and around the building. These areas included classrooms, restrooms, hallways, the kitchen, custodial closets, the boiler room and the exterior. The sampled water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before the sample collection according to the guideline from the Subpart. The first-draw samples were collected from a cold water outlet before any water was used. The samples were sent to Phoenix Environmental Laboratories, Inc., which is approved to perform lead analyses by the Department's Environmental Laboratory Approval Program (ELAP#: 11715).

Lab results indicate that:

- 11 out of 127 water outlets were above the action level.
- 1 water fountain was above the action level.
- No kitchen sinks were above the action level.
- The following water outlets are listed as being above the action level:
 1. Sink in Rm 018 (Left)
 2. Water fountain in Rm 018
 3. Sink in Rm 018 (Right)
 4. Sink in custodial closet (See the floor plan, sample no. 336)
 5. Sink in Rm 003 (Left)
 6. Sink in Rm 003 (Right)
 7. Sink in Rm 232 (Right)
 8. Sink in Rm 233 (Right)
 9. Sink in exterior by Rm 016
 10. Sink in exterior by Rm 008
 11. Sink in Custodial closet (Right) (See the floor plan, sample no. 336A)

RECOMMENDATIONS

The following is a recommendation from this survey.

- 2016-10-01 Install carbon filters to reduce the lead content from the water outlet fixtures tested above the action level, or the allowable limits.
- 2016-10-02 Check for plumbing work. If copper pipes are joined with lead solder that has been installed, notify a qualified plumber to replace the lead solder with lead-free solder. Lead solder looks dull gray and when scratched with a key, looks shiny.
- 2016-10-03 Check type of piping used to connect to water main. Determine whether or not the service line that connects the building to the water line is made of lead.

CONCLUSION

This survey revealed that most of the lead testing from water source fixtures indicated low or non-detectable exposures. However, 11 out of 127 samples were above the Action Level, 15 micrograms per liter ($\mu\text{g/L}$) or parts per billion (ppb), listed in the report. One water fountain was above the action level. No kitchen sinks were above the action level.

The recommendations in this report are intended to achieve the goal of a safer and more healthful environment. If the recommendations are completed, future health issues should be prevented.

If there are any questions regarding the contents of this report or further assistance is needed for recommendation completion, please feel free to contact Dr. Justin Joe, who can be reached via the following:

Justin H. Joe, PhD, CSP
BNF Consulting, Inc.
152 Route 202, #404
Lincolndale, NY 10540
bnfjustin@gmail.com

A closing Thank You is extended to all who assisted or participated in completion of this Survey.

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any representation contained herein. This information should not be construed as business, risk management, or legal advice or legal opinion.

APPENDIX A

LEAD WATER TESTING LAB RESULTS



Thursday, November 03, 2016

Attn: Justin Joe
BNF Consulting
152 Route 202 #404
Lincolndale, NY 10540-0404

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
Sample ID#s: BV47798 - BV47924

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #MA-CT-007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:29
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47798

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 288 FRONT HALLWAY WF HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:29
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47799

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 289 FRONT HALLWAY WF LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:31
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47800

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 290 MAIN HALLWAY WF HIGH

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:31
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47801

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 291 MAIN HALLWAY WF LOW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:32
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47802

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 292 RM 130 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:32
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47803

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 293 RM 130 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:33
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47804

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 294 CUSTODIAL CLOSET #1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:33
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47805

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 295 STAFF RESTROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:34
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47806

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 296 RM 129 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:34
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47807

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 297 RM 129 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47808

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 298 RM 127 RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47809

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 299 RM 127 MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0034	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/AG/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47810

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 300 RM 127 LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47811

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 301 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47812

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 302 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0013	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47813

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 303 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0088	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47814

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 304 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47815

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 305 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47816

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 306 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47817

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 307 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47818

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 308 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0078	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:37
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47819

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 309 RM 127 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:44
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47820

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 310 RM 128 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:44
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47821

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 311 RM 128 BATHROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:44
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47822

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 312 RM 128 PATIENT ROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0037	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:49
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47823

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 313 RM 001

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0045	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

21:51
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47824

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 314 RM 018 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0376	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

21:51
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47825

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 315 RM 018 WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0207	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:51
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47826

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 316 RM 018 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0852	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:51
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47827

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 317 RM 018 WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0085	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:52
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47828

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 318 SINK BY RM 018

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:55
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47829

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 319 WF BY CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0034	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:55
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47830

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 320 CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:57
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47831

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 321 RM 015

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 21:59
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47832

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 322 RM 014

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0040	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:00
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47833

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 323 CLOSET/MULTI PURPOSE ROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0060	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:01
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47834

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 324 RM 011

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:01
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47835

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 325 RM 011 BATHROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:02
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47836

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 326 RM 012 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:02
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47837

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 327 RM 012 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0012	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:02
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47838

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 328 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:02
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47839

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 329 STAFF RESTROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:04
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47840

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 330 RM 010 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:04
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47841

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 331 RM 010 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:05
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47842

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 332 WF BY RM 007

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:07
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47843

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 333 RM 005 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

22:07
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47844

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 334 RM 005 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:10
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47845

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 335 CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0047	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:10
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47846

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 336 CUSTODIAL CLOSET SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0152	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:12
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47847

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 337 RM 004 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:12
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47848

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 338 RM 004 SINK RGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:14
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47849

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 339 WF BY RM 003

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

22:16
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47850

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 340 RM 003 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0444	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:16
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47851

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 341 RM 003 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0159	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:17
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47852

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 342 RM 002

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:18
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47853

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 343 RM 101

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:19
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47854

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 344 RM 103

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:19
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47855

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 345 WF BY RM 103

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:20
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47856

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 346 RM 105

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:21
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47857

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 347 RM 104

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0032	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:22
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47858

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 348 RM 106 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:22
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47859

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 349 RM 106 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:22
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47860

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 350 RM 106 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:24
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47861

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 351 RM 107

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:26
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47862

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 352 CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:27
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47863

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 353 RM 108 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:27
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47864

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 354 RM 108 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:29
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47865

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 355 RM 109

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:30
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47866

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 356 RM 110 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:30
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47867

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 357 RM 110 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0032	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:32
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47868

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 358 RM 111

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0037	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:34
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47869

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 359 RM 112 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0035	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:34
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47870

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 360 RM 112 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0054	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47871

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 361 WF BY RM 114

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47872

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 362 RM 114

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0048	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:36
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47873

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 363 SINK BY RM 116

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:38
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47874

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 364 RM 117

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0093	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:38
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47875

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 365 RM 118

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0033	0.0010	1	mg/L	0.015			10/28/16	LK	E200.5
Total Metal Digestion	Completed							10/14/16		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:40
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47876

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 366 WF BY RM 118

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:41
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47877

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 367 RM 123

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:42
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47878

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 368 SINK BY RM 121

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:44
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47879

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 369 RM 227 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:44
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47880

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 370 RM 227 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:45
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47881

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 371 RM 228 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:45
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47882

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 372 RM 228 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:46
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47883

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 373 RM 229 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:46
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47884

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 374 RM 229 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:47
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47885

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 375 RM 230 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:47
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47886

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 376 RM 230 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:49
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47887

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 377 RM 231 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:49
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47888

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 378 RM 231 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:50
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47889

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 379 STAFF RESTROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/30/16	LK	E200.5
Total Metal Digestion	Completed							10/13/16	B/T/BF/W	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:52
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47890

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 380 RM 232 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			10/16/16	LK	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:52
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47891

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 381 RM 223 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			10/16/16	LK	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:52
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47892

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 382 RM 232 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.271	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

22:56
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47893

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 383 WF HIGH BY RM 232

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:56
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47894

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 384 WF LOW BY RM 232

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:00
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47895

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 385 RM 233 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:00
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47896

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 386 RM 233 SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:00
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47897

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 387 RM 233 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.852	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:02
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47898

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 388 CUSTORDIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:04
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47899

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 389 RM 201 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:04
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47900

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 390 RM 201 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0043	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:06
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47901

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 391 RM 202 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:06
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47902

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 392 RM 202 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:08
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47903

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 393 RM 203 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:08
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47904

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 394 RM 203 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0031	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:10
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47905

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 395 RM 204 SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0072	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:10
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47906

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 396 RM 204 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0049	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:11
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47907

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 397 WF BY RM 205

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:12
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47908

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 398 RM 207

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0023	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:12
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47909

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 399 RM 209

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0012	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:13
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47910

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 400 RM 208

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:14
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47911

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 401 RM 210

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:15
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47912

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 402 RM 212

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:16
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47913

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 403 WF BY EXIT C

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:17
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47914

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 404 SINK BY RM 217

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:17
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47915

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 405 RM 218

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/01/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:17
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47916

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 406 RM 219

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:19
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47917

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 407 WF BY RM 119

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:20
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47918

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 408 SINK BY RM 217

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:22
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47919

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 409 EXTERIOR BY RM 016

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0212	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 23:24
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47920

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 410 EXTERIOR BY RM 003

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0077	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date

10/12/16
 10/13/16

Time

23:26
 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47921

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 411 EXTERIOR BY RM 008

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0208	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:07
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47922

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 334A RM 005 SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:10
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47923

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 336A CUSTODIAL CLOSET SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0366	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 November 03, 2016

FOR: Attn: Justin Joe
 BNF Consulting
 152 Route 202 #404
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER
 Location Code: BNFCNSLT
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: LB
 Analyzed by: see "By" below

Date Time
 10/12/16 22:35
 10/13/16 15:32

Laboratory Data

SDG ID: GBV47798
 Phoenix ID: BV47924

Project ID: MOUNT KISCO ELEMENTARY SCHOOL
 Client ID: 355A WF BY RM 109

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0039	0.0010	1	mg/L	0.015			11/02/16	TH	E200.5
Total Metal Digestion	Completed							10/14/16	G/RVM	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

November 03, 2016

Reviewed and Released by: Bobbi Aloisa, Vice President



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823



QA/QC Report

November 03, 2016

QA/QC Data

SDG I.D.: GBV47798

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 362863A (mg/L), QC Sample No: BV46321 (BV47890, BV47891)

ICP Metals - Aqueous

Lead	BRL	0.001				97.6			98.5			85 - 115	20
------	-----	-------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362977 (mg/L), QC Sample No: BV47485 (BV47875)

ICP Metals - Aqueous

Lead	BRL	0.0010	0.0011	<0.0010	NC	93.3			94.9			85 - 115	20
------	-----	--------	--------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362807 (mg/L), QC Sample No: BV47790 (BV47798, BV47799)

ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	<0.0010	NC	96.9			93.5			85 - 115	20
------	-----	--------	---------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362807A (mg/L), QC Sample No: BV47800 (BV47800, BV47801, BV47802, BV47803, BV47804, BV47805, BV47806, BV47807, BV47808, BV47809)

ICP Metals - Aqueous

Lead	BRL	0.0010				96.9			96.9			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362808 (mg/L), QC Sample No: BV47810 (BV47810, BV47811, BV47812, BV47813, BV47814, BV47815, BV47816, BV47817, BV47818, BV47819)

ICP Metals - Aqueous

Lead	BRL	0.0010	0.0019	0.0018	NC	98.1			95.4			85 - 115	20
------	-----	--------	--------	--------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362808A (mg/L), QC Sample No: BV47820 (BV47820, BV47821, BV47822, BV47823, BV47824, BV47825, BV47826, BV47827, BV47828, BV47829)

ICP Metals - Aqueous

Lead	BRL	0.0010				98.1			95.0			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Data

SDG I.D.: GBV47798

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 362809 (mg/L), QC Sample No: BV47830 (BV47830, BV47831, BV47832, BV47833, BV47834, BV47835, BV47836, BV47837, BV47838, BV47839)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0010	<0.0010	<0.0010	NC	101			99.3			85 - 115	20
Comment:													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362809A (mg/L), QC Sample No: BV47840 (BV47840, BV47841, BV47842, BV47843, BV47844, BV47845, BV47846, BV47847, BV47848, BV47849)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0010				101			94.2			85 - 115	20
Comment:													
This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362810 (mg/L), QC Sample No: BV47850 (BV47850, BV47851, BV47852, BV47853, BV47854, BV47855, BV47856, BV47857, BV47858, BV47859)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0015	0.0444	0.0448	0.90	98.3			94.0			85 - 115	20
Comment:													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362810A (mg/L), QC Sample No: BV47860 (BV47860, BV47861, BV47862, BV47863, BV47864, BV47865, BV47866, BV47867, BV47868, BV47869)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0015				98.3			99.7			85 - 115	20
Comment:													
This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362812 (mg/L), QC Sample No: BV47870 (BV47870, BV47871, BV47872, BV47873, BV47874, BV47876, BV47877, BV47878, BV47879)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0010	0.0054	0.0048	NC	108			98.6			85 - 115	20
Comment:													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362812A (mg/L), QC Sample No: BV47880 (BV47880, BV47881, BV47882, BV47883, BV47884, BV47885, BV47886, BV47887, BV47888, BV47889)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0010				108			96.8			85 - 115	20
Comment:													
This batch does not include a duplicate.													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													
QA/QC Batch 362864 (mg/L), QC Sample No: BV47892 (BV47892, BV47893, BV47894, BV47895, BV47896, BV47897, BV47898, BV47899, BV47900, BV47901)													
<u>ICP Metals - Aqueous</u>													
Lead	BRL	0.0010	0.271	0.272	0.40	97.0			93.6			85 - 115	20
Comment:													
Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.													

QA/QC Data

SDG I.D.: GBV47798

Parameter	Blk Blank	RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	--------------	----	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 362864A (mg/L), QC Sample No: BV47902 (BV47902, BV47903, BV47904, BV47905, BV47906, BV47907, BV47908, BV47909, BV47910, BV47911)

ICP Metals - Aqueous

Lead	BRL	0.0010				97.0			94.3			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362865 (mg/L), QC Sample No: BV47912 (BV47912, BV47913, BV47914, BV47915, BV47916, BV47917, BV47918, BV47919, BV47920, BV47921)

ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	<0.0010	NC	96.6			95.2			85 - 115	20
------	-----	--------	---------	---------	----	------	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 362865A (mg/L), QC Sample No: BV47922 (BV47922, BV47923, BV47924)

ICP Metals - Aqueous

Lead	BRL	0.0010				96.6			92.1			85 - 115	20
------	-----	--------	--	--	--	------	--	--	------	--	--	----------	----


Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference


 Phyllis Shiller, Laboratory Director
 November 03, 2016

Sample Criteria Exceedances Report

Criteria: None

GBV47798 - BNFCNSLT

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV47824	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0376	0.0010	0.015	0.001	mg/L
BV47824	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0376	0.0010	0.015	0.015	mg/L
BV47825	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0207	0.0010	0.015	0.001	mg/L
BV47825	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0207	0.0010	0.015	0.015	mg/L
BV47826	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0852	0.0010	0.015	0.001	mg/L
BV47826	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0852	0.0010	0.015	0.015	mg/L
BV47846	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0152	0.0010	0.015	0.001	mg/L
BV47846	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0152	0.0010	0.015	0.015	mg/L
BV47850	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0444	0.0010	0.015	0.001	mg/L
BV47850	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0444	0.0010	0.015	0.015	mg/L
BV47851	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0159	0.0010	0.015	0.001	mg/L
BV47851	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0159	0.0010	0.015	0.015	mg/L
BV47892	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.271	0.0010	0.015	0.001	mg/L
BV47892	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.271	0.0010	0.015	0.015	mg/L
BV47897	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.852	0.0010	0.015	0.001	mg/L
BV47897	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.852	0.0010	0.015	0.015	mg/L
BV47919	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0212	0.0010	0.015	0.001	mg/L
BV47919	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0212	0.0010	0.015	0.015	mg/L
BV47921	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0208	0.0010	0.015	0.001	mg/L
BV47921	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0208	0.0010	0.015	0.015	mg/L
BV47923	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0366	0.0010	0.015	0.001	mg/L
BV47923	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0366	0.0010	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



NY Temperature Narration

November 03, 2016

SDG I.D.: GBV47798

The samples in this delivery group were received at 22°C.
(Note acceptance criteria is above freezing up to 6°C)

BNF

BCSD Lead Water Sampling COC - ~~Mount Kisco Elementary School~~

John
220NIC

288	10/12	1032	10/12	2129	MKES	See the floor plan	Front Hallway WF high	47798
289	10/12		10/12	2129	MKES	See the floor plan	Front Hallway WF low	47799
290	10/12		10/12	2131	MKES	See the floor plan	Main Hallway WF high	47800
291	10/12	↓	10/12	↓	MKES	See the floor plan	Main Hallway WF low	47801
292	10/12	1033	10/12	2132	MKES	See the floor plan	Rm 130 left	47802
293	10/12		10/12	↓	MKES	See the floor plan	Rm 130 right	47803
294	10/12		10/12	2133	MKES	See the floor plan	Custodial closet #1	47804
295	10/12		10/12	↓	MKES	See the floor plan	Staff restroom	47805
296	10/12		10/12	2134	MKES	See the floor plan	Rm 129 right	47806
297	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 129 left	47807
298	10/12	1035	10/12	2135	MKES	See the floor plan	Rm 127 right	47808
299	10/12	1037	10/12		MKES	See the floor plan	Rm 127 middle	47809
300	10/12		10/12	↓	MKES	See the floor plan	Rm 127 left	47810
301	10/12		10/12	2137	MKES	See the floor plan	Rm 127 sink	47811
302	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47812
303	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47813
304	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47814
305	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47815
306	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47816
307	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47817
308	10/12		10/12		MKES	See the floor plan	Rm 127 sink	47818
309	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 127 sink	47819
310	10/12	1038	10/12	2144	MKES	See the floor plan	Rm 128 sink	47820
311	10/12		10/12		MKES	See the floor plan	Rm 128 bathroom	47821
312	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 128 patient room	47822
313	10/12	1040	10/12	2149	MKES	See the floor plan	Rm 001	47823
314	10/12	1042	10/12	2151	MKES	See the floor plan	Rm 018 sink left	47824
315	10/12		10/12		MKES	See the floor plan	Rm 018 WF left	47825
316	10/12		10/12		MKES	See the floor plan	Rm 018 sink right	47826
317	10/12		10/12	↓	MKES	See the floor plan	Rm 018 sink right	47827
318	10/12	↓	10/12	2152	MKES	See the floor plan	Sink by Rm 018	47828
319	10/12	1043	10/12	2155	MKES	See the floor plan	WF by custodial closet	47829
320	10/12	↓	10/12	2155	MKES	See the floor plan	Custodial closet	47830
321	10/12	↓	10/12	2157	MKES	See the floor plan	Rm 015	47831

Ja
Ja

10/13/16

10/13/16

10/13/16

220

BNF Consulting

Law MUMM

10/13/16 5:30

BNF

Page 2 of 4

220116

BCSD Lead Water Sampling COC - Mount Kisco Elementary School

322	10/12	1044	10/12	2159	MKES	See the floor plan	Rm 014	47832
323	10/12	1046	10/12	2200	MKES	See the floor plan	Closet/Multi-purpose room	47833
324	10/12	1047	10/12	2201	MKES	See the floor plan	Rm 011	47834
325	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 011 bathroom	47835
326	10/12	1048	10/12	2202	MKES	See the floor plan	Rm 012 sink	47836
327	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 012 WF	47837
328	10/12	↓	10/12	2202	MKES	See the floor plan	sink	47838
329	10/12	↓	10/12	2202	MKES	See the floor plan	Staff restroom	47839
330	10/12	1049	10/12	2204	MKES	See the floor plan	Rm 010 sink left	47840
331	10/12	↓	10/12	2204	MKES	See the floor plan	Rm 010 sink right	47841
332	10/12	1050	10/12	2205	MKES	See the floor plan	WF by Rm 007	47842
333	10/12	↓	10/12	2207	MKES	See the floor plan	Rm 005 sink left	47843
334	10/12	↓	10/12	2207	MKES	See the floor plan	Rm 005 sink right	47844
335	10/12	↓	10/12	2210	MKES	See the floor plan	Custodial closet	47845
336	10/12	1051	10/12	↓	MKES	See the floor plan	Custodial closet sink	47846
337	10/12	1052	10/12	2212	MKES	See the floor plan	Rm 004 sink left	47847
338	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 004 sink right	47848
339	10/12	1053	10/12	2214	MKES	See the floor plan	WF by Rm 003	47849
340	10/12	1054	10/12	2216	MKES	See the floor plan	Rm 003 sink left	47850
341	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 003 sink right	47851
342	10/12	1056	10/12	2217	MKES	See the floor plan	Rm 002	47852
343	10/12	1057	10/12	2218	MKES	See the floor plan	Rm 101	47853
344	10/12	↓	10/12	2219	MKES	See the floor plan	Rm 103	47854
345	10/12	↓	10/12	2219	MKES	See the floor plan	WF by Rm 103	47855
346	10/12	1058	10/12	2220	MKES	See the floor plan	Rm 105	47856
347	10/12	1059	10/12	2221	MKES	See the floor plan	Rm 104	47857
348	10/12	1059	10/12	2222	MKES	See the floor plan	Rm 106 sink left	47858
349	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 106 sink middle	47859
350	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 106 sink right	47860
351	10/12	1100	10/12	2224	MKES	See the floor plan	Rm 107	47861
352	10/12	1102	10/12	2226	MKES	See the floor plan	Custodial Closet	47862
353	10/12	1104	10/12	2227	MKES	See the floor plan	Rm 108 sink left	47863
354	10/12	1104	10/12	2227	MKES	See the floor plan	Rm 108 sink right	47864
355	10/12	1105	10/12	2229	MKES	See the floor plan	Rm 109	47865

tl
334
Restroom
33

47833

47842

47843

47844

47845

47846

Ja 10/12/16
Ja 10/13/16

BNF Consulting

Cam...

10/13/16 15:32

BNF

Page 3 of 4 220110

BCSD Lead Water Sampling COC - Mount Kisco Elementary School

356	10/12	1105	10/12	2230	MKES	See the floor plan	Rm 110 sink left	478600
357	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 110 sink right	478607
358	10/12	1106	10/12	2232	MKES	See the floor plan	Rm 111	478608
359	10/12	↓	10/12	2234	MKES	See the floor plan	Rm 112 sink	478609
360	10/12	↓	10/12	2234	MKES	See the floor plan	Rm 112 WF	47870
361	10/12	1108	10/12	2235	MKES	See the floor plan	WF by Rm 114	47871
362	10/12	↓	10/12	2235	MKES	See the floor plan	Rm 114	47872
363	10/12	1109	10/12	2236	MKES	See the floor plan	Sink by Rm 116	47873
364	10/12	↓	10/12	2238	MKES	See the floor plan	Rm 117	47874
365	10/12	↓	10/12	2238	MKES	See the floor plan	Rm 118	47875
366	10/12	↓	10/12	2240	MKES	See the floor plan	WF by Rm 118	47876
367	10/12	1109	10/12	2241	MKES	See the floor plan	Rm 123	47877
368	10/12	1110	10/12	2242	MKES	See the floor plan	Sink by Rm 121	47878
369	10/12	1112	10/12	2244	MKES	See the floor plan	Rm 227 sink	47879
370	10/12	↓	10/12	2244	MKES	See the floor plan	Rm 227 WF	47880
371	10/12	↓	10/12	2245	MKES	See the floor plan	Rm 228 sink	47881
372	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 228 WF	47882
373	10/12	1113	10/12	2246	MKES	See the floor plan	Rm 229 sink	47883
374	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 229 WF	47884
375	10/12	↓	10/12	2247	MKES	See the floor plan	Rm 230 sink	47885
376	10/12	↓	10/12	2247	MKES	See the floor plan	Rm 230 WF	47886
377	10/12	↓	10/12	2249	MKES	See the floor plan	Rm 231 sink	47887
378	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 231 WF	47888
379	10/12	1114	10/12	2250	MKES	See the floor plan	Staff restroom	47889
380	10/12	1115	10/12	2252	MKES	See the floor plan	Rm 232 sink left	47895 47890
381	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 232 sink middle	47891
382	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 232 sink right	47892
383	10/12	↓	10/12	2258	MKES	See the floor plan	WF high by Rm 232	47893
384	10/12	1115	10/12	↓	MKES	See the floor plan	WF low by Rm 232	47894
385	10/12	1117	10/12	2300	MKES	See the floor plan	Rm 233 sink left	47895
386	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 233 sink middle	47896
387	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 233 sink right	47897 47897
388	10/12	1118	10/12	2302	MKES	See the floor plan	Custodial closet	47898
389	10/12	1119	10/12	2304	MKES	See the floor plan	Rm 201 sink left	47899

Ja
Jr

10/12/16
10/12/11

low
20

BNF Consulting

Laura M... 10/13/16 15:32

BNF

page 4 of 4 220N/C

BCSD Lead Water Sampling COC - Mount Kisco Elementary School

390	10/12	1120	10/12	2304	MKES	See the floor plan	Rm 201 sink right	47900
391	10/12	1121	10/12	2306	MKES	See the floor plan	Rm 202 sink left	47901
392	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 202 sink right	47902
393	10/12	↓	10/12	2308	MKES	See the floor plan	Rm 203 sink left	47903
394	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 203 sink right	47904
395	10/12	1122	10/12	2310	MKES	See the floor plan	Rm 204 sink left	47905
396	10/12	↓	10/12	↓	MKES	See the floor plan	Rm 204 sink right	47906
397	10/12	↓	10/12	2311	MKES	See the floor plan	WF by Rm 205	47907
398	10/12	1123	10/12	2312	MKES	See the floor plan	Rm 207	47908
399	10/12	↓	10/12	2312	MKES	See the floor plan	Rm 209	47909
400	10/12	1124	10/12	2313	MKES	See the floor plan	Rm 208	47910
401	10/12	1125	10/12	2314	MKES	See the floor plan	Rm 210	47911
402	10/12	1126	10/12	2315	MKES	See the floor plan	Rm 212	47912
403	10/12	1127	10/12	2316	MKES	See the floor plan	WF by Exit C	47913
404	10/12	1128	10/12	2317	MKES	See the floor plan	Sink by Rm 217	47914
405	10/12	1129	10/12	↓	MKES	See the floor plan	Rm 218	47915
406	10/12	1130	10/12	↓	MKES	See the floor plan	Rm 219	47916
407	10/12	↓	10/12	2319	MKES	See the floor plan	WF by Rm 219	47917
408	10/12	1131	10/12	2320	MKES	See the floor plan	Sink by Rm 217	47918
409	10/12	1132	10/12	2322	MKES	See the floor plan	Exterior by Rm 016	47919
410	10/12	1134	10/12	2324	MKES	See the floor plan	Exterior by Rm 003	47920
411	10/12	1136	10/12	2326	MKES	See the floor plan	Exterior by Rm 008	47921
334A	10/12	1050	↓	2207	↓	↓	Rm 005 Sink Rylor	47922
336A	10/12	1051	↓	2216	↓	↓	Custodial closet sub	Rylor
357A	10/12	1105	↓	2235	↓	↓	WF by Rm 109	47924
								47923

10/13/16
10/12/11

BNF Consulting

10/13/16 15:32