



BEDFORD CENTRAL SCHOOL DISTRICT  
FOX LANE CAMPUS  
P.O. BOX 180  
MOUNT KISCO, NY 10549

## LEAD WATER TESTING

For

West Patent Elementary School  
80 West Patent Road  
Bedford Hills NY 10507

Date of Assessment: October 14, 2016

Date of Report: November 4, 2016

Completed By: Justin Joe, PhD, CSP  
Industrial Hygienist / Building Inspector  
BNF Consulting, Inc.  
152 Route 202, #404  
Lincolndale, NY 10540  
[bnfjustin@gmail.com](mailto:bnfjustin@gmail.com)

## EXECUTIVE SUMMARY

On October 14, 2016, lead water testing was completed for West Patent Elementary School, one of the Bedford Central School District (BCSD) schools, located at 80 West Patent Road, Bedford Hills, NY 10507. Primarily assisting in the completion of this study were Mr. Gregory Sullivan, Interim Assistant Superintendent; Mr. Shawn Pitulle, Interim Director of Buildings and Grounds; and the maintenance staff in WPES.

The purpose of this survey is to comply to 10 NYCRR SUBPART 67-4: Lead Testing in School Drinking Water. This subpart requires all school districts and boards of cooperative education services, including those already classified as a public water system under 10 NYCRR Subpart 5-1, to test portable water for lead contamination and to develop and implement a lead remediation plan when applicable. Action Level used in the Subpart means 15 micrograms per liter ( $\mu\text{g/L}$ ) or parts per billion (ppb). Exceedance of the action level requires a response to implement a lead remediation plan.

First-draw water samples were collected from all available water outlets including faucets, sinks and water fountains in and around the building. These areas included classrooms, restrooms, hallways, the kitchen, custodial closets, the boiler room and the exterior. The sampled water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before the sample collection according to the guideline from the Subpart. The first-draw samples were collected from a cold water outlet before any water was used. The samples were sent to Phoenix Environmental Laboratories, Inc., which is approved to perform lead analyses by the Department's Environmental Laboratory Approval Program (ELAP#: 11715).

Lab results indicate that:

- 46 out of 126 water outlets were above the action level.
- 9 water fountains were above the action level.
- 3 kitchen sinks were above the action level.
- The following water outlets are listed as being above the action level:
  1. Team 2 sink (Left) (See the floor plan, sample no. 232)
  2. Team 2 sink (Right) (See the floor plan, sample no. 233 )
  3. Galloway's Rm sink (Left) (See the floor plan, sample no. 249)
  4. Galloway's Rm water fountain (Left) (See the floor plan, sample no. 250)
  5. Galloway's Rm sink (Right) (See the floor plan, sample no. 251)
  6. Moreno's Rm sink (Left) (See the floor plan, sample no. 252)
  7. Moreno's Rm water fountain (Left) (See the floor plan, sample no. 253)
  8. Moreno's Rm sink (Right) (See the floor plan, sample no. 254)
  9. Moreno's Rm water fountain (Right) (See the floor plan, sample no. 255)
  10. Kurlanzik's Rm water fountain (Left) (See the floor plan, sample no. 261)
  11. Kurlanzik's Rm sink (Right) (See the floor plan, sample no. 262)
  12. Wanderlingh's Rm sink (See the floor plan, sample no. 264)
  13. Neglia's Rm sink (See the floor plan, sample no. 266)
  14. Leap 3 sink (See the floor plan, sample no. 268)
  15. Leap 3 water fountain (See the floor plan, sample no. 269)
  16. Leap 2 water fountain (See the floor plan, sample no. 271)
  17. Exterior faucet gym wing (See the floor plan, sample no. 274)
  18. Exterior faucet 3-5 wing (See the floor plan, sample no. 275)
  19. Exterior faucet gym wing (See the floor plan, sample no. 276)

20. Exterior faucet 3-5 wing (See the floor plan, sample no. 277)
21. Exterior faucet 3-5 wing (See the floor plan, sample no. 278)
22. Exterior faucet 3-5 wing (See the floor plan, sample no. 279)
23. Exterior faucet K-2 wing (See the floor plan, sample no. 280)
24. Exterior faucet K-2 wing (See the floor plan, sample no. 281)
25. Exterior faucet K-2 wing (See the floor plan, sample no. 282)
26. Exterior faucet K-2 wing (See the floor plan, sample no. 283)
27. Exterior faucet court yard (See the floor plan, sample no. 286)
28. Exterior faucet by fence (See the floor plan, sample no. 287)
29. Storage sink (See the floor plan, sample no. 168)
30. Woman's bathroom sink (See the floor plan, sample no. 183)
31. Band room sink (See the floor plan, sample no. 185)
32. Kitchen hand wash sink (See the floor plan, sample no. 190)
33. Kitchen triple sink (Left) (See the floor plan, sample no. 191)
34. Kitchen vegetable sink (See the floor plan, sample no. 193)
35. Kitchen bathroom sink (See the floor plan, sample no. 194)
36. Custodial sink (See the floor plan, sample no. 195)
37. Cafeteria custodial sink (See the floor plan, sample no. 197)
38. Kindergarten white top sink (Left) (See the floor plan, sample no. 211)
39. Kindergarten white top water fountain (Left) (See the floor plan, sample no. 212)
40. Kindergarten white top sink (Right) (See the floor plan, sample no. 213)
41. Kindergarten white top water fountain (Right) (See the floor plan, sample no. 214)
42. Leap 1 sink (See the floor plan, sample no. 215)
43. Leap 1 water fountain (See the floor plan, sample no. 216)
44. OTPT sink (See the floor plan, sample no. 217)
45. Wagner's room sink (Left) (See the floor plan, sample no. 224)
46. Wagner's room sink (Right) (See the floor plan, sample no. 226)

## RECOMMENDATIONS

The following is a recommendation from this survey.

- 2016-10-01 Install carbon filters to reduce the lead content from the water outlet fixtures tested above the action level, or the allowable limits.
- 2016-10-02 Check for plumbing work. If copper pipes are joined with lead solder that has been installed, notify a qualified plumber to replace the lead solder with lead-free solder. Lead solder looks dull gray and when scratched with a key, looks shiny.
- 2016-10-03 Check type of piping used to connect to water main. Determine whether or not the service line that connects the building to the water line is made of lead.

## CONCLUSION

This survey revealed that most of the lead testing from water source fixtures indicated low or non-detectable exposures. However, 46 out of 126 samples were above the Action Level, 15 micrograms per liter ( $\mu\text{g/L}$ ) or parts per billion (ppb), listed in the report. 9 water fountains were above the action level. 3 kitchen sinks were above the action level.

The recommendations in this report are intended to achieve the goal of a safer and more healthful environment. If the recommendations are completed, future health issues should be prevented.

If there are any questions regarding the contents of this report or further assistance is needed for recommendation completion, please feel free to contact Dr. Justin Joe, who can be reached via the following:

Justin H. Joe, PhD, CSP  
BNF Consulting, Inc.  
152 Route 202, #404  
Lincolndale, NY 10540  
[bnfjustin@gmail.com](mailto:bnfjustin@gmail.com)

A closing Thank You is extended to all who assisted or participated in completion of this Survey.

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any representation contained herein. This information should not be construed as business, risk management, or legal advice or legal opinion.

APPENDIX A

LEAD WATER TESTING LAB RESULTS



Friday, November 04, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: WEST PATENT ELEMENTARY SCHOOL  
Sample ID#s: BV52935 - BV52992

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        6:44  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52935

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 231 PROVOST'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0069	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:48  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52936

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 232 TEAM TWO SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0423	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date

10/14/16  
 10/14/16

Time

6:48  
 17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52937

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 233 TEAM TWO SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0234	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            6:48  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52938

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 234 TEAM TWO GIRLS BATHROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            6:50  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52939

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 235 LIBRARY

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0077	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:52  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52940

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 236 UPPER CLASS CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 10/14/16                      6:54  
 10/14/16                      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52941

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 237 UPPER CLASS STAFF BATHROOM SINK 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            6:54  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52942

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 238 UPPER CLASS STAFF BATHROOM SINK 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52943

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 239 GIRL`S BATHROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0054	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52944

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 240 GIRL`S BATHROOM SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52945

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 241 GIRL`S BATHROOM SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        6:57  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52946

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 242 GIRL`S BATHROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            6:58  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52947

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 243 VENDITTO`S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0096	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:58  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52948

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 244 VENDITTO`S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0096	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:00  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52949

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 245 MULLER'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0107	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52950

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 246 MULLER'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0028	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52951

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 247 MULLER'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0120	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52952

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 248 MULLER'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0066	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52953

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 249 GALLOWAY'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0410	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52954

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 250 GALLOWAY'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0201	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52955

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 251 GALLOWAY'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0219	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date

10/14/16  
 10/14/16

Time

7:04  
 17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52956

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 252 MORENO'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0353	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52957

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 253 MORENO'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0483	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52958

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 254 MORENO`S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0190	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52959

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 255 MORENO'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0445	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:05  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52960

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 256 BOYS BATHROOM RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:05  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52961

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 257 BOYS BATHROOM MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:05  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52962

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 258 BOYS BATHROOM MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:05  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52963

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 259 BOYS BATHROOM LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0031	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52964

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 260 KURLANZIK'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0134	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52965

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 261 KURLANZIK`S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0225	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/bf	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52966

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 262 KURLANZIK`S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0227	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:07  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52967

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 263 KURLANZIK'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0121	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:08  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52968

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 264 WANDERLINGH'S ROOM SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0677	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:08  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52969

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 265 WANDERLINGH'S ROOM WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0110	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52970

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 266 NEGLIA`S ROOM SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0159	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52971

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 267 NEGLIA`S ROOM WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0094	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52972

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 268 LEAP 3 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0418	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52973

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 269 LEAP 3 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.523	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:22  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52974

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 270 LEAP 2 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0059	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:22  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52975

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 271 LEAP 2 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0481	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
<b>*** Lead exceeds Action Level of 0.015 ***</b>										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:25  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52976

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 272 CONNLEY'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0058	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:25  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52977

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 273 CONNLEY'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0080	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        5:09  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52978

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 274 EXTERIOR FAUCET GYM WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.232	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:10  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52979

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 275 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0182	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:11  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52980

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 276 EXTERIOR FAUCET GYM WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0910	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:13  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52981

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 277 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0315	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:14  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52982

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 278 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0947	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:15  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52983

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 279 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0193	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:17  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52984

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 280 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0436	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:19  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52985

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 281 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.424	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:20  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52986

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 282 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.33	0.010	10	mg/L	0.015			11/01/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:22  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52987

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 283 EXTERIOR FAUCET W-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0252	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        5:24  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52988

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 284 EXTERIOR FAUCET BY CAFETERIA

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0101	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        5:25  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52989

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 285 EXTERIOR FAUCET FRONT A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0061	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:26  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52990

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 286 EXTERIOR FAUCET COURT YARD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0293	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:27  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52991

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 287 EXTERIOR FAUCET BY FENCE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0569	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:28  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52992

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 285A EXTERIOR FAUCET FRONT B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0112	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 04, 2016

## QA/QC Data

SDG I.D.: GBV52935

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 363648A (mg/L), QC Sample No: BV52926 (BV52935)

### ICP Metals - Aqueous

Lead	BRL	0.0010				96.5			101			85 - 115	20
------	-----	--------	--	--	--	------	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363649 (mg/L), QC Sample No: BV52936 (BV52936, BV52937, BV52938, BV52939, BV52940, BV52941, BV52942, BV52943, BV52944, BV52945)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0423	0.0434	2.60	105			101			85 - 115	20
------	-----	--------	--------	--------	------	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363649A (mg/L), QC Sample No: BV52946 (BV52946, BV52947, BV52948, BV52949, BV52950, BV52951, BV52952, BV52953, BV52954, BV52955)

### ICP Metals - Aqueous

Lead	BRL	0.0010				105			102			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363661 (mg/L), QC Sample No: BV52956 (BV52956, BV52957, BV52958, BV52959, BV52960, BV52961, BV52962, BV52963, BV52964, BV52965)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0353	0.0347	1.70	104			98.3			85 - 115	20
------	-----	--------	--------	--------	------	-----	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363661A (mg/L), QC Sample No: BV52966 (BV52966, BV52967, BV52968, BV52969, BV52970, BV52971, BV52972, BV52973, BV52974, BV52975)

### ICP Metals - Aqueous

Lead	BRL	0.0010				104			102			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363662 (mg/L), QC Sample No: BV52976 (BV52976, BV52977, BV52978, BV52979, BV52980, BV52981, BV52982, BV52983, BV52984, BV52985)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0058	0.0065	11.4	88.2			101			85 - 115	20
------	-----	--------	--------	--------	------	------	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

## QA/QC Data

SDG I.D.: GBV52935

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 363662A (mg/L), QC Sample No: BV52986 (BV52986, BV52987, BV52988, BV52989, BV52990, BV52991, BV52992)													
<b>ICP Metals - Aqueous</b>													
Lead		BRL	0.0010			88.2			107			85 - 115	20


Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 November 04, 2016

# Sample Criteria Exceedances Report

Criteria: None

## GBV52935 - BNFCNSLT

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV52936	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0423	0.0010	0.015	0.001	mg/L
BV52936	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0423	0.0010	0.015	0.015	mg/L
BV52937	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0234	0.0010	0.015	0.001	mg/L
BV52937	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0234	0.0010	0.015	0.015	mg/L
BV52953	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0410	0.0010	0.015	0.001	mg/L
BV52953	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0410	0.0010	0.015	0.015	mg/L
BV52954	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0201	0.0010	0.015	0.001	mg/L
BV52954	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0201	0.0010	0.015	0.015	mg/L
BV52955	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0219	0.0010	0.015	0.001	mg/L
BV52955	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0219	0.0010	0.015	0.015	mg/L
BV52956	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0353	0.0010	0.015	0.001	mg/L
BV52956	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0353	0.0010	0.015	0.015	mg/L
BV52957	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0483	0.0010	0.015	0.001	mg/L
BV52957	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0483	0.0010	0.015	0.015	mg/L
BV52958	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0190	0.0010	0.015	0.001	mg/L
BV52958	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0190	0.0010	0.015	0.015	mg/L
BV52959	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0445	0.0010	0.015	0.001	mg/L
BV52959	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0445	0.0010	0.015	0.015	mg/L
BV52965	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0225	0.0010	0.015	0.001	mg/L
BV52965	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0225	0.0010	0.015	0.015	mg/L
BV52966	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0227	0.0010	0.015	0.001	mg/L
BV52966	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0227	0.0010	0.015	0.015	mg/L
BV52968	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0677	0.0010	0.015	0.001	mg/L
BV52968	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0677	0.0010	0.015	0.015	mg/L
BV52970	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0159	0.0010	0.015	0.001	mg/L
BV52970	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0159	0.0010	0.015	0.015	mg/L
BV52972	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0418	0.0010	0.015	0.001	mg/L
BV52972	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0418	0.0010	0.015	0.015	mg/L
BV52973	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.523	0.0010	0.015	0.001	mg/L
BV52973	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.523	0.0010	0.015	0.015	mg/L

**Sample Criteria Exceedances Report**

Criteria: None

**GBV52935 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV52975	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0481	0.0010	0.015	0.001	mg/L
BV52975	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0481	0.0010	0.015	0.015	mg/L
BV52978	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.232	0.0010	0.015	0.001	mg/L
BV52978	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.232	0.0010	0.015	0.015	mg/L
BV52979	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0182	0.0010	0.015	0.001	mg/L
BV52979	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0182	0.0010	0.015	0.015	mg/L
BV52980	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0910	0.0010	0.015	0.001	mg/L
BV52980	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0910	0.0010	0.015	0.015	mg/L
BV52981	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0315	0.0010	0.015	0.001	mg/L
BV52981	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0315	0.0010	0.015	0.015	mg/L
BV52982	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0947	0.0010	0.015	0.001	mg/L
BV52982	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0947	0.0010	0.015	0.015	mg/L
BV52983	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0193	0.0010	0.015	0.001	mg/L
BV52983	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0193	0.0010	0.015	0.015	mg/L
BV52984	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0436	0.0010	0.015	0.001	mg/L
BV52984	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0436	0.0010	0.015	0.015	mg/L
BV52985	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.424	0.0010	0.015	0.001	mg/L
BV52985	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.424	0.0010	0.015	0.015	mg/L
BV52986	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	3.33	0.010	0.015	0.001	mg/L
BV52986	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	3.33	0.010	0.015	0.015	mg/L
BV52987	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0252	0.0010	0.015	0.001	mg/L
BV52987	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0252	0.0010	0.015	0.015	mg/L
BV52990	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0293	0.0010	0.015	0.001	mg/L
BV52990	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0293	0.0010	0.015	0.015	mg/L
BV52991	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0569	0.0010	0.015	0.001	mg/L
BV52991	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0569	0.0010	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

November 04, 2016

SDG I.D.: GBV52935

---

The samples in this delivery group were received at 22°C.  
(Note acceptance criteria is above freezing up to 6°C)

BNF

Page 3 of 4  
220116

BCSD Lead Water Sampling COC - West Patent Elementary School

231	10/13	1949	10/14	0644	WPES	See the floor plan	Provost's Room WF right	52935
232	10/13	1950	10/14	0648	WPES	See the floor plan	Team Two sink left	52936
233	10/13	↓	10/14	0648	WPES	See the floor plan	Team Two sink right	52937
234	10/13	1951	10/14	0648	WPES	See the floor plan	Team Two girl's bathroom	52938
235	10/13	1952	10/14	0650	WPES	See the floor plan	Library	52939
236	10/13	↓	10/14	0652	WPES	See the floor plan	Upper class custodial closet	52940
237	10/13	1953	10/14	0654	WPES	See the floor plan	Upper grade staff bathroom sink 1	52941
238	10/13	↓	10/14	↓	WPES	See the floor plan	Upper grade staff bathroom sink 2	52942
239	10/13	1954	10/14	0657	WPES	See the floor plan	Girl's bathroom sink left	52943
240	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink middle	52944
241	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink middle	52945
242	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink right	52946
243	10/13	1955	10/14	0658	WPES	See the floor plan	Venditto's room sink left	52947
244	10/13	↓	10/14	↓	WPES	See the floor plan	Venditto's room sink right	52948
245	10/13	1956	10/14	0700	WPES	See the floor plan	Muller's room sink left	52949
246	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room WF left	52950
247	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room sink right	52951
248	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room WF right	52952
249	10/13	1958	10/14	0702	WPES	See the floor plan	Galloway's Room sink left	52953
250	10/13	↓	10/14	↓	WPES	See the floor plan	Galloway's Room sink right	52954
251	10/13	↓	10/14	↓	WPES	See the floor plan	Galloway's Room WF right	52955
252	10/13	↓	10/14	0704	WPES	See the floor plan	Morenos's Room sink left	52956
253	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room WF left	52957
254	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room sink right	52958
255	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room WF right	52959
256	10/13	1959	10/14	0705	WPES	See the floor plan	Boy's bathroom right	52960
257	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom middle	52961
258	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom middle	52962
259	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom left	52963
260	10/13	2000	10/14	0707	WPES	See the floor plan	Kurlanzik's Room sink left	52964
261	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room WF left	52965
262	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room sink right	52966
263	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room WF right	52967
264	10/13	2001	10/14	0708	WPES	See the floor plan	Wanderlingh's Room sink	52968

Joe O

10/14/16 115

BNF Consulting

Joe O 10/14/16 300

10-14-16

300 BNF

10/14/16 17:02

BNF

page 4 of 4  
220116

BCSD Lead Water Sampling COC - West Patent Elementary School

No.	Dispatched	Drawn	Date	Location	Notes	Location
265	10/13	↓	10/14	0708	WPES	See the floor plan Wanderlingh's Room WF
266	10/13	2002	10/14	0718	WPES	See the floor plan Neglias' Room sink
267	10/13	↓	10/14	0718	WPES	See the floor plan Neglias' Room WF
268	10/13	2003	10/14	0718	WPES	See the floor plan Leap 3 sink
269	10/13	↓	10/14	0718	WPES	See the floor plan Leap 3 WF
270	10/13	2004	10/14	0722	WPES	See the floor plan Leap 2 sink
271	10/13	↓	10/14	0722	WPES	See the floor plan Leap 2 WF
272	10/13	2004	10/14	0725	WPES	See the floor plan Connley's Rom sink left
273	10/13	↓	10/14	0725	WPES	See the floor plan Connley's Rom sink right
274	10/13	2006	10/14	0509	WPES	See the floor plan Exterior faucet Gym Wing
275	10/13	2009	10/14	0510	WPES	See the floor plan Exterior faucet 3-5 wing
276	10/13	2012	10/14	0511	WPES	See the floor plan Exterior faucet 3-5 wing Gym wing
277	10/13	2015	10/14	0513	WPES	See the floor plan Exterior faucet 3-5 wing
278	10/13	2018	10/14	0514	WPES	See the floor plan Exterior faucet 3-5 wing
279	10/13	2021	10/14	0515	WPES	See the floor plan Exterior faucet 3-5 wing
280	10/13	2024	10/14	0517	WPES	See the floor plan Exterior faucet K-2 wing
281	10/13	2027	10/14	0519	WPES	See the floor plan Exterior faucet K-2 wing
282	10/13	2030	10/14	0520	WPES	See the floor plan Exterior faucet K-2 wing
283	10/13	2033	10/14	0522	WPES	See the floor plan Exterior faucet W-2 wing
284	10/13	2036	10/14	0524	WPES	See the floor plan Exterior faucet by cafeteria
285	10/13	2039	10/14	0525	WPES	See the floor plan Exterior faucet Front A
286	10/13	2010	10/14	0526	WPES	See the floor plan Exterior faucet Court yard
287	10/13	2042	10/14	0527	WPES	See the floor plan Exterior faucet by fence
285A	10/13	2045	10/14	0528	↓	↓ Exterior faucet Front B

52969  
52970  
52971  
52972  
52973  
52974  
52975  
52976  
52977  
52978  
52979  
52980  
52981  
52982  
52983  
52984  
52985  
52986  
52987  
52988  
52989  
52990  
52991  
52992

John QD  
John QD  
Bul

10/14/16 115  
10/14/16 300  
10/14/16

BNF Consulting

10/14/16 17:02



Friday, November 04, 2016

Attn: Justin Joe  
BNF Consulting  
152 Route 202 #404  
Lincolndale, NY 10540-0404

Project ID: WEST PATENT ELEMENTARY SCHOOL  
Sample ID#s: BV52935 - BV52992

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:44  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52935

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 231 PROVOST'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0069	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:48  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52936

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 232 TEAM TWO SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0423	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date

10/14/16  
 10/14/16

Time

6:48  
 17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52937

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 233 TEAM TWO SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0234	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:48  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52938

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 234 TEAM TWO GIRLS BATHROOM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:50  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52939

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 235 LIBRARY

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0077	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:52  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52940

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 236 UPPER CLASS CUSTODIAL CLOSET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        6:54  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52941

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 237 UPPER CLASS STAFF BATHROOM SINK 1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            6:54  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52942

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 238 UPPER CLASS STAFF BATHROOM SINK 2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52943

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 239 GIRL`S BATHROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0054	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52944

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 240 GIRL`S BATHROOM SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52945

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 241 GIRL`S BATHROOM SINK MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0027	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:57  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52946

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 242 GIRL`S BATHROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0024	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:58  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52947

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 243 VENDITTO'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0096	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      6:58  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52948

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 244 VENDITTO`S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0096	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52949

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 245 MULLER'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0107	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52950

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 246 MULLER'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0028	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52951

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 247 MULLER'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0120	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:00  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52952

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 248 MULLER'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0066	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52953

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 249 GALLOWAY'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0410	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52954

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 250 GALLOWAY'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0201	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:02  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52955

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 251 GALLOWAY'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0219	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	VM/CB/R	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52956

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 252 MORENO'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0353	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52957

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 253 MORENO'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0483	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52958

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 254 MORENO`S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0190	0.0010	1	mg/L	0.015			11/03/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:04  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52959

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 255 MORENO'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0445	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 10/14/16                      7:05  
 10/14/16                      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52960

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 256 BOYS BATHROOM RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0029	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:05  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52961

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 257 BOYS BATHROOM MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:05  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52962

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 258 BOYS BATHROOM MIDDLE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            7:05  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52963

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 259 BOYS BATHROOM LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0031	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52964

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 260 KURLANZIK'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0134	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	3/CB/RVME200.5/E200.7	

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52965

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 261 KURLANZIK'S ROOM WF LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0225	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/bf	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52966

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 262 KURLANZIK'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0227	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:07  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52967

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 263 KURLANZIK'S ROOM WF RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0121	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:08  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52968

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 264 WANDERLINGH'S ROOM SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0677	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:08  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52969

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 265 WANDERLINGH'S ROOM WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0110	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52970

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 266 NEGLIA`S ROOM SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0159	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:18  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52971

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 267 NEGLIA`S ROOM WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0094	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52972

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 268 LEAP 3 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0418	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
<b>*** Lead exceeds Action Level of 0.015 ***</b>										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:18  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52973

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 269 LEAP 3 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.523	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:22  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52974

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 270 LEAP 2 SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0059	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      7:22  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52975

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 271 LEAP 2 WF

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0481	0.0010	1	mg/L	0.015			11/03/16	TH	E200.5
<b>*** Lead exceeds Action Level of 0.015 ***</b>										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:25  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52976

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 272 CONNLEY'S ROOM SINK LEFT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0058	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        7:25  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52977

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 273 CONNLEY'S ROOM SINK RIGHT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0080	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            5:09  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52978

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 274 EXTERIOR FAUCET GYM WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.232	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date

10/14/16  
 10/14/16

Time

5:10  
 17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52979

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 275 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0182	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:11  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52980

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 276 EXTERIOR FAUCET GYM WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0910	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:13  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52981

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 277 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0315	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:14  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52982

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 278 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0947	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 10/14/16                      5:15  
 10/14/16                      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52983

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 279 EXTERIOR FAUCET 3-5 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0193	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:17  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52984

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 280 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0436	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:19  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52985

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 281 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.424	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:20  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52986

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 282 EXTERIOR FAUCET K-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.33	0.010	10	mg/L	0.015			11/01/16	LK	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:22  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52987

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 283 EXTERIOR FAUCET W-2 WING

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0252	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16        5:24  
 10/14/16        17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52988

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 284 EXTERIOR FAUCET BY CAFETERIA

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0101	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:25  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52989

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 285 EXTERIOR FAUCET FRONT A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0061	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:26  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52990

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 286 EXTERIOR FAUCET COURT YARD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0293	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date      Time  
 10/14/16      5:27  
 10/14/16      17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52991

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 287 EXTERIOR FAUCET BY FENCE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0569	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 November 04, 2016

FOR: Attn: Justin Joe  
 BNF Consulting  
 152 Route 202 #404  
 Lincolndale, NY 10540-0404

Sample Information

Matrix: DRINKING WATER  
 Location Code: BNFCNSLT  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: B  
 Analyzed by: see "By" below

Date            Time  
 10/14/16            5:28  
 10/14/16            17:02

Laboratory Data

SDG ID: GBV52935  
 Phoenix ID: BV52992

Project ID: WEST PATENT ELEMENTARY SCHOOL  
 Client ID: 285A EXTERIOR FAUCET FRONT B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0112	0.0010	1	mg/L	0.015			10/29/16	TH	E200.5
Total Metal Digestion	Completed							10/20/16	G/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**November 04, 2016**

**Reviewed and Released by: Bobbi Aloisa, Vice President**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

November 04, 2016

## QA/QC Data

SDG I.D.: GBV52935

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 363648A (mg/L), QC Sample No: BV52926 (BV52935)

### ICP Metals - Aqueous

Lead	BRL	0.0010				96.5			101			85 - 115	20
------	-----	--------	--	--	--	------	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363649 (mg/L), QC Sample No: BV52936 (BV52936, BV52937, BV52938, BV52939, BV52940, BV52941, BV52942, BV52943, BV52944, BV52945)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0423	0.0434	2.60	105			101			85 - 115	20
------	-----	--------	--------	--------	------	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363649A (mg/L), QC Sample No: BV52946 (BV52946, BV52947, BV52948, BV52949, BV52950, BV52951, BV52952, BV52953, BV52954, BV52955)

### ICP Metals - Aqueous

Lead	BRL	0.0010				105			102			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363661 (mg/L), QC Sample No: BV52956 (BV52956, BV52957, BV52958, BV52959, BV52960, BV52961, BV52962, BV52963, BV52964, BV52965)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0353	0.0347	1.70	104			98.3			85 - 115	20
------	-----	--------	--------	--------	------	-----	--	--	------	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363661A (mg/L), QC Sample No: BV52966 (BV52966, BV52967, BV52968, BV52969, BV52970, BV52971, BV52972, BV52973, BV52974, BV52975)

### ICP Metals - Aqueous

Lead	BRL	0.0010				104			102			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 363662 (mg/L), QC Sample No: BV52976 (BV52976, BV52977, BV52978, BV52979, BV52980, BV52981, BV52982, BV52983, BV52984, BV52985)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0058	0.0065	11.4	88.2			101			85 - 115	20
------	-----	--------	--------	--------	------	------	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Data

SDG I.D.: GBV52935

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 363662A (mg/L), QC Sample No: BV52986 (BV52986, BV52987, BV52988, BV52989, BV52990, BV52991, BV52992)

ICP Metals - Aqueous

Lead                                      BRL    0.0010                                      88.2                                      107                                      85 - 115    20

Comment:


This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

---

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
Phyllis Shiller, Laboratory Director  
November 04, 2016

**Sample Criteria Exceedances Report**

Criteria: None

**GBV52935 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV52936	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0423	0.0010	0.015	0.001	mg/L
BV52936	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0423	0.0010	0.015	0.015	mg/L
BV52937	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0234	0.0010	0.015	0.001	mg/L
BV52937	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0234	0.0010	0.015	0.015	mg/L
BV52953	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0410	0.0010	0.015	0.001	mg/L
BV52953	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0410	0.0010	0.015	0.015	mg/L
BV52954	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0201	0.0010	0.015	0.001	mg/L
BV52954	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0201	0.0010	0.015	0.015	mg/L
BV52955	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0219	0.0010	0.015	0.001	mg/L
BV52955	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0219	0.0010	0.015	0.015	mg/L
BV52956	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0353	0.0010	0.015	0.001	mg/L
BV52956	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0353	0.0010	0.015	0.015	mg/L
BV52957	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0483	0.0010	0.015	0.001	mg/L
BV52957	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0483	0.0010	0.015	0.015	mg/L
BV52958	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0190	0.0010	0.015	0.001	mg/L
BV52958	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0190	0.0010	0.015	0.015	mg/L
BV52959	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0445	0.0010	0.015	0.001	mg/L
BV52959	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0445	0.0010	0.015	0.015	mg/L
BV52965	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0225	0.0010	0.015	0.001	mg/L
BV52965	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0225	0.0010	0.015	0.015	mg/L
BV52966	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0227	0.0010	0.015	0.001	mg/L
BV52966	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0227	0.0010	0.015	0.015	mg/L
BV52968	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0677	0.0010	0.015	0.001	mg/L
BV52968	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0677	0.0010	0.015	0.015	mg/L
BV52970	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0159	0.0010	0.015	0.001	mg/L
BV52970	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0159	0.0010	0.015	0.015	mg/L
BV52972	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0418	0.0010	0.015	0.001	mg/L
BV52972	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0418	0.0010	0.015	0.015	mg/L
BV52973	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.523	0.0010	0.015	0.001	mg/L
BV52973	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.523	0.0010	0.015	0.015	mg/L

**Sample Criteria Exceedances Report**

Criteria: None

**GBV52935 - BNFCNSLT**

State: NY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
BV52975	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0481	0.0010	0.015	0.001	mg/L
BV52975	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0481	0.0010	0.015	0.015	mg/L
BV52978	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.232	0.0010	0.015	0.001	mg/L
BV52978	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.232	0.0010	0.015	0.015	mg/L
BV52979	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0182	0.0010	0.015	0.001	mg/L
BV52979	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0182	0.0010	0.015	0.015	mg/L
BV52980	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0910	0.0010	0.015	0.001	mg/L
BV52980	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0910	0.0010	0.015	0.015	mg/L
BV52981	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0315	0.0010	0.015	0.001	mg/L
BV52981	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0315	0.0010	0.015	0.015	mg/L
BV52982	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0947	0.0010	0.015	0.001	mg/L
BV52982	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0947	0.0010	0.015	0.015	mg/L
BV52983	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0193	0.0010	0.015	0.001	mg/L
BV52983	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0193	0.0010	0.015	0.015	mg/L
BV52984	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0436	0.0010	0.015	0.001	mg/L
BV52984	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0436	0.0010	0.015	0.015	mg/L
BV52985	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.424	0.0010	0.015	0.001	mg/L
BV52985	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.424	0.0010	0.015	0.015	mg/L
BV52986	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	3.33	0.010	0.015	0.001	mg/L
BV52986	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	3.33	0.010	0.015	0.015	mg/L
BV52987	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0252	0.0010	0.015	0.001	mg/L
BV52987	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0252	0.0010	0.015	0.015	mg/L
BV52990	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0293	0.0010	0.015	0.001	mg/L
BV52990	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0293	0.0010	0.015	0.015	mg/L
BV52991	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	0.0569	0.0010	0.015	0.001	mg/L
BV52991	PB-DWICP	Lead	NY / NY Residential DW / Lead & Copper Als	0.0569	0.0010	0.015	0.015	mg/L

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

November 04, 2016

SDG I.D.: GBV52935

---

The samples in this delivery group were received at 22°C.  
(Note acceptance criteria is above freezing up to 6°C)

BNF

Page 3 of 4  
220116

BCSD Lead Water Sampling COC - West Patent Elementary School

231	10/13	1949	10/14	0644	WPES	See the floor plan	Provost's Room WF right	52935
232	10/13	1950	10/14	0648	WPES	See the floor plan	Team Two sink left	52936
233	10/13	↓	10/14	0648	WPES	See the floor plan	Team Two sink right	52937
234	10/13	1951	10/14	0648	WPES	See the floor plan	Team Two girl's bathroom	52938
235	10/13	1952	10/14	0650	WPES	See the floor plan	Library	52939
236	10/13	↓	10/14	0652	WPES	See the floor plan	Upper class custodial closet	52940
237	10/13	1953	10/14	0654	WPES	See the floor plan	Upper grade staff bathroom sink 1	52941
238	10/13	↓	10/14	↓	WPES	See the floor plan	Upper grade staff bathroom sink 2	52942
239	10/13	1954	10/14	0657	WPES	See the floor plan	Girl's bathroom sink left	52943
240	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink middle	52944
241	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink middle	52945
242	10/13	↓	10/14	↓	WPES	See the floor plan	Girl's bathroom sink right	52946
243	10/13	1955	10/14	0658	WPES	See the floor plan	Venditto's room sink left	52947
244	10/13	↓	10/14	↓	WPES	See the floor plan	Venditto's room sink right	52948
245	10/13	1956	10/14	0700	WPES	See the floor plan	Muller's room sink left	52949
246	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room WF left	52950
247	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room sink right	52951
248	10/13	↓	10/14	↓	WPES	See the floor plan	Muller's room WF right	52952
249	10/13	1958	10/14	0702	WPES	See the floor plan	Galloway's Room sink left	52953
250	10/13	↓	10/14	↓	WPES	See the floor plan	Galloway's Room sink right	52954
251	10/13	↓	10/14	↓	WPES	See the floor plan	Galloway's Room WF right	52955
252	10/13	↓	10/14	0704	WPES	See the floor plan	Morenos's Room sink left	52956
253	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room WF left	52957
254	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room sink right	52958
255	10/13	↓	10/14	↓	WPES	See the floor plan	Morenos's Room WF right	52959
256	10/13	1959	10/14	0705	WPES	See the floor plan	Boy's bathroom right	52960
257	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom middle	52961
258	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom middle	52962
259	10/13	↓	10/14	↓	WPES	See the floor plan	Boy's bathroom left	52963
260	10/13	2000	10/14	0707	WPES	See the floor plan	Kurlanzik's Room sink left	52964
261	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room WF left	52965
262	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room sink right	52966
263	10/13	↓	10/14	↓	WPES	See the floor plan	Kurlanzik's Room WF right	52967
264	10/13	2001	10/14	0708	WPES	See the floor plan	Wanderlingh's Room sink	52968

Joe O

10/14/16 115

BNF Consulting

Joe O 10/14/16  
10-14-16

300 BNF

10/14/16 115

10/14/16 115



BNF

page 4 of 4  
220116

BCSD Lead Water Sampling COC - West Patent Elementary School

No.	Dispatched	Drawn	Date	ID	Location	Notes	Location
265	10/13	↓	10/14	0708	WPES	See the floor plan	Wanderling's Room WF
266	10/13	2002	10/14	0718	WPES	See the floor plan	Neglias' Room sink
267	10/13	↓	10/14	0718	WPES	See the floor plan	Neglias' Room WF
268	10/13	2003	10/14	0718	WPES	See the floor plan	Leap 3 sink
269	10/13	↓	10/14	0718	WPES	See the floor plan	Leap 3 WF
270	10/13	2004	10/14	0722	WPES	See the floor plan	Leap 2 sink
271	10/13	↓	10/14	0722	WPES	See the floor plan	Leap 2 WF
272	10/13	2004	10/14	0725	WPES	See the floor plan	Connley's Rom sink left
273	10/13	↓	10/14	0725	WPES	See the floor plan	Connley's Rom sink right
274	10/13	2006	10/14	0509	WPES	See the floor plan	Exterior faucet Gym Wing
275	10/13	2009	10/14	0510	WPES	See the floor plan	Exterior faucet 3-5 wing
276	10/13	2012	10/14	0511	WPES	See the floor plan	Exterior faucet 3-5 Wing Gym wing
277	10/13	2015	10/14	0513	WPES	See the floor plan	Exterior faucet 3-5 wing
278	10/13	2018	10/14	0514	WPES	See the floor plan	Exterior faucet 3-5 Wing
279	10/13	2021	10/14	0515	WPES	See the floor plan	Exterior faucet 3-5 wing
280	10/13	2024	10/14	0517	WPES	See the floor plan	Exterior faucet K-2 wing
281	10/13	2027	10/14	0519	WPES	See the floor plan	Exterior faucet K-2 Wing
282	10/13	2030	10/14	0520	WPES	See the floor plan	Exterior faucet K-2 Wing
283	10/13	2033	10/14	0522	WPES	See the floor plan	Exterior faucet W-2 wing
284	10/13	2036	10/14	0524	WPES	See the floor plan	Exterior faucet by cafeteria
285	10/13	2039	10/14	0525	WPES	See the floor plan	Exterior faucet Front A
286	10/13	2010	10/14	0526	WPES	See the floor plan	Exterior faucet Court yard
287	10/13	2042	10/14	0527	WPES	See the floor plan	Exterior faucet by fence
285A	10/13	2045	10/14	0528	↓	↓	Exterior faucet Front B

52969  
52970  
52971  
52972  
52973  
52974  
52975  
52976  
52977  
52978  
52979  
52980  
52981  
52982  
52983  
52984  
52985  
52986  
52987  
52988  
52989  
52990  
52991  
52992

John QD 10/14/16 115  
John QD 10/14/16 300  
BNF Consulting  
10/14/16  
10/14/16 17:02