



February 4, 2020

Zach Nannestad
Douglas County School District
620 Wilcox Street
Castle Rock, CO 80104

**Re: Stone Canyon – Building 108
12163 South Perry Park Road in Larkspur, CO 80118
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Stone Canyon with its radon survey. At your request, QUEST conducted radon testing at the Stone Canyon – Building 108, located at 12163 South Perry Park Road in Larkspur, Colorado.

Nine (9) Air Chek radon test kits were placed on January 28, 2020 and were retrieved on January 30, 2020. The attached laboratory report identifies that radon concentrations in all locations were within (below) the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager/Industrial Hygienist

Attachment: Laboratory Report

January 31, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
STONE CANYON BLDG 108

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9291978	BUNK 1	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.6 ± 0.3	2020-01-31
9291979	BUNK 1	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.3 ± 0.3	2020-01-31
9291980	BUNK 1	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	< 0.3	2020-01-31
9291981	BUNK 2	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.7 ± 0.3	2020-01-31
9291983	BUNK 3	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.8 ± 0.3	2020-01-31
9291984	BUNK 4	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.5 ± 0.3	2020-01-31
9291985	BUNK 5	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.8 ± 0.3	2020-01-31
9291986	BUNK 6	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.7 ± 0.3	2020-01-31
9291982	GROUP AREA	2020-01-28 @ 11:00 am	2020-01-30 @ 11:00 am	3.7 ± 0.3	2020-01-31

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498