



February 4, 2020

Zach Nannestad  
Douglas County School District  
620 Wilcox Street  
Castle Rock, CO 80104

**Re: Stone Canyon – Building 100  
12163 South Perry Park Road in Larkspur, CO 80118  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Stone Canyon with its radon survey. At your request, QUEST conducted radon testing at the Stone Canyon – Building 100, located at 12163 South Perry Park Road in Larkspur, Colorado.

Thirteen (13) Air Chek radon test kits were placed on January 28, 2020 and were retrieved on January 30, 2020. The attached laboratory report identifies that radon concentrations in all locations were within (below) the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
President/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal  
Project Manager/Industrial Hygienist

Attachment: Laboratory Report

Radon test result report for:**STONE CANYON BLDG 100**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9291966	CLASSROOM 1- MT. DECEPTION	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.1 ± 0.3	2020-01-31
9291967	CLASSROOM 2- TURTLE MT.	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.3 ± 0.3	2020-01-31
9291968	CLASSROOM 3- DAKAN MT.	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.4 ± 0.3	2020-01-31
9291970	CLASSROOM 4- THUNDER BUTTE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.6 ± 0.3	2020-01-31
9291969	CLASSROOM 4- THUNDER BUTTE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.6 ± 0.3	2020-01-31
9291971	CLASSROOM 5- TURKEY ROCK	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.3 ± 0.3	2020-01-31
9291972	CLASSROOM 6- MT. HERMON	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.0 ± 0.3	2020-01-31
9291973	DINING HALL	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.9 ± 0.3	2020-01-31
9291962	DIRECTOR'S OFFICE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	2.1 ± 0.3	2020-01-31
9291961	MAIN OFFICE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.1 ± 0.3	2020-01-31
9291963	PROGRAMMING OFFICE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.1 ± 0.3	2020-01-31
9291964	SITE MANAGER OFFICE	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.4 ± 0.3	2020-01-31
9291965	SITUATION ROOM	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	1.4 ± 0.3	2020-01-31