



February 4, 2020

Zach Nannestad  
Douglas County School District  
620 Wilcox Street  
Castle Rock, CO 80104

**Re: Stone Canyon – Building 106  
12163 South Perry Park Road in Larkspur, CO 80118  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Stone Canyon with its radon survey. At your request, QUEST conducted radon testing at the Stone Canyon – Building 106, located at 12163 South Perry Park Road in Larkspur, Colorado.

Four (4) Air Chek radon test kits were placed on January 28, 2020 and were retrieved on January 30, 2020. The attached laboratory report identifies that radon concentrations in all locations were within (below) the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
President/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal  
Project Manager/Industrial Hygienist

Attachment: Laboratory Report

---

January 31, 2020

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**STONE CANYON BLDG 106**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9291976	BUNK 1	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	3.9 ± 0.3	2020-01-31
9291975	BUNK 2	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	3.7 ± 0.3	2020-01-31
9291974	BUNK 3	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	3.6 ± 0.3	2020-01-31
9291977	COMMON AREA	2020-01-28 @ 10:00 am	2020-01-30 @ 11:00 am	3.9 ± 0.3	2020-01-31

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498