



February 17, 2020

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Douglas County School District Building B
2808 U.S. Highway 85 in Castle Rock, CO 80109
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Douglas County School District Building B, located at 2808 U.S. Highway 85 in Castle Rock, Colorado.

Twenty-two (22) AirChek radon test kits were placed on February 11, 2020 and were retrieved on February 13, 2020. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:**2808 HWY 85****B**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9292085	BREAK/CONFERENCE ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.3 ± 0.3	2020-02-14
9292086	BREAK/CONFERENCE ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	< 0.3	2020-02-14
9292084	BREAK/CONFERENCE ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.2 ± 0.3	2020-02-14
9292080	CONFERENCE ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.2 ± 0.3	2020-02-14
9292088	CONSTRUCT. OWNER'S REP - NV5	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.3 ± 0.3	2020-02-14
9292082	COPY ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.8 ± 0.3	2020-02-14
9292089	DIR. OF CONSTRUCT. - L. RAJASEKAR	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.7 ± 0.3	2020-02-14
9292079	FACILITIES - W. BLAZEK	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.6 ± 0.3	2020-02-14
9292090	MECH. FOREMAN - J. PIHL	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.8 ± 0.3	2020-02-14
9292092	PARTS - DESK	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	< 0.3	2020-02-14
9292078	PROJECT ACCOUNT. - K. KALCEVIK	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.0 ± 0.3	2020-02-14
9292081	PROJECT MGR. - E. MCCAIN	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.9 ± 0.3	2020-02-14
9292083	PROJECT MGR. - M. SCHUURMAN	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.1 ± 0.3	2020-02-14
9292093	SHOP	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.6 ± 0.3	2020-02-14
9292098	SHOP	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.1 ± 0.3	2020-02-14
9292094	SHOP	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	< 0.3	2020-02-14
9292099	SHOP	2020-02-11 @ 11:00 am	2020-02-13 @ 12:00 pm	0.5 ± 0.3	2020-02-14
9292097	SHOP - BAY I	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	< 0.3	2020-02-14
9292095	SHOP - BAY M	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.6 ± 0.3	2020-02-14
9292096	SHOP - BAY M	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.6 ± 0.3	2020-02-14
9292091	SHOP - LUNCH ROOM	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	0.7 ± 0.3	2020-02-14
9292087	VACANT OFFICE	2020-02-11 @ 11:00 am	2020-02-13 @ 11:00 am	1.0 ± 0.3	2020-02-14