



February 17, 2020

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Douglas County School District Building E
2812 U.S. Highway 85 in Castle Rock, CO 80109
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Douglas County School District Building E, located at 2812 U.S. Highway 85 in Castle Rock, Colorado.

Forty-two (42) AirChek radon test kits were placed on February 11, 2020 and forty-one (41) test kits were retrieved on February 13, 2020. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:**2812 HWY 85****E**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9384931	101 - RECEPTION	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.0 ± 0.3	2020-02-14
9384939	102	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	0.9 ± 0.3	2020-02-14
9384938	103	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.1 ± 0.3	2020-02-14
9384940	104 - CONFERENCE	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.1 ± 0.3	2020-02-14
9384937	105	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	0.9 ± 0.3	2020-02-14
9384936	106	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.2 ± 0.3	2020-02-14
9384935	106	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.4 ± 0.3	2020-02-14
9384934	108/107	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.6 ± 0.3	2020-02-14
9384933	109	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.6 ± 0.3	2020-02-14
9384943	110	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.9 ± 0.3	2020-02-14
9384932	110	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.3 ± 0.3	2020-02-14
9384930	112	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.1 ± 0.3	2020-02-14
9384929	113	2020-02-11 @ 12:00 pm	2020-02-13 @ 1:00 pm	1.1 ± 0.3	2020-02-14
9384928	114	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384927	115	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384926	116	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	< 0.3	2020-02-14
9384924	116	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9384925	116	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384923	117	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384922	118	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.0 ± 0.3	2020-02-14
9384921	119	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.1 ± 0.3	2020-02-14
9384920	120/121	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384918	123	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.9 ± 0.3	2020-02-14
9384919	125	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.6 ± 0.3	2020-02-14
9384909	131/132	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.9 ± 0.3	2020-02-14
9384910	133	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.1 ± 0.3	2020-02-14
9384944	155 - EMERGENCY OP. CENTER	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	2.4 ± 0.3	2020-02-14
9384942	155 - OFFICE	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.5 ± 0.3	2020-02-14
9384949	157 - DISPATCH	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	2.5 ± 0.3	2020-02-14
9384946	160	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	2.8 ± 0.3	2020-02-14
9384947	160	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	< 0.3	2020-02-14
9384945	160	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	2.9 ± 0.3	2020-02-14
9384948	162	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	1.3 ± 0.3	2020-02-14
9384917	COPY AREA	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9384941	SECURITY AREA - VACANT OFFICE	2020-02-11 @ 1:00 pm	2020-02-13 @ 1:00 pm	2.5 ± 0.3	2020-02-14
9384916	SMOOTHIE ROOM - DESK	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.9 ± 0.3	2020-02-14
9384915	SMOOTHIE ROOM - DESK	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.0 ± 0.3	2020-02-14

February 15, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

2812 HWY 85

E

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9384911	WAREHOUSE - BREAK AREA	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9384913	WAREHOUSE - ROW 11	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.8 ± 0.3	2020-02-14
9384912	WAREHOUSE - ROW 14	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.0 ± 0.3	2020-02-14
9384914	WAREHOUSE - ROW 6	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.9 ± 0.3	2020-02-14

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498