



February 17, 2020

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Douglas County School District Building C
2810 U.S. Highway 85 in Castle Rock, CO 80109
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Douglas County School District Building C, located at 2810 U.S. Highway 85 in Castle Rock, Colorado.

Nine (9) AirChek radon test kits were placed on February 11, 2020 and were retrieved on February 13, 2020. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

February 15, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

2810 HWY 85

C

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9384905	BREAK ROOM	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9384906	BREAK ROOM	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	< 0.3	2020-02-14
9384904	BREAK ROOM	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9384902	COMPUTER ROOM	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.3 ± 0.3	2020-02-14
9292100	CONTROLS DEPT. OFFICE	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	< 0.3	2020-02-14
9384903	OPEN AREA	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	0.9 ± 0.3	2020-02-14
9384908	OPEN AREA - NORTH	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.2 ± 0.3	2020-02-14
9384907	PARTS ROOM	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.1 ± 0.3	2020-02-14
9384901	SOUND OFFICE	2020-02-11 @ 12:00 pm	2020-02-13 @ 12:00 pm	1.1 ± 0.3	2020-02-14

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498