



May 22, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Wildcat Mountain Elementary School
6585 Lionshead Parkway, Littleton, CO 80130
Radon Sampling Assessment – Follow-Up**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted follow-up radon testing at Wildcat Mountain Elementary School, located at 6585 Lionshead Parkway in Littleton, Colorado.

Fourty-seven (47) AirChek radon test kits were placed on May 15, 2024, and were retrieved on May 17, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Handwritten signature of Robert A. Woellner in black ink.

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Handwritten signature of Jake Gamble in black ink.

Jake Gamble
Industrial Hygienist

Handwritten signature of Larry Head in black ink.

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
WILDCAT MOUNTAIN ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536008	102	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.9	2024-05-20
11536015	103	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.4	2024-05-20
11536007	107	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.3	2024-05-20
11536016	126	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.8	2024-05-20
11536018	128	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536027	137	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536028	140	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.1	2024-05-20
11536012	144	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536014	146	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536039	153/155	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536004	165	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.7	2024-05-20
11536006	167	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536002	170	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.0	2024-05-20
11536040	177	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.1	2024-05-20
11536041	178	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.1	2024-05-20
11536042	179	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	4.0	2024-05-20
11536043	180	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.8	2024-05-20
11536044	181	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.2	2024-05-20
11536046	181 (B)	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	< 0.3	2024-05-20
11536045	181 (D)	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.2	2024-05-20
11536047	182	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	3.8	2024-05-20
11536031	277	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.7	2024-05-20
11536032	278	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536033	279	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.3	2024-05-20
11536034	279 (D)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.4	2024-05-20
11536035	280	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.8	2024-05-20
11536036	281	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536037	282	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.1	2024-05-20
11536019	377	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.4	2024-05-20
11536020	378	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536021	379	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536023	379 (B)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	< 0.3	2024-05-20
11536022	379 (D)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.2	2024-05-20
11536024	380	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.8	2024-05-20
11536025	381	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.9	2024-05-20
11536026	382	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.8	2024-05-20
11536017	CAFETERIA	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.1	2024-05-20

May 20, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
WILDCAT MOUNTAIN ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536029	COPY ROOM (140)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536009	GYM NORTH	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.9	2024-05-20
11536010	GYM SOUTH	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.9	2024-05-20
11536011	GYM SOUTH (D)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.9	2024-05-20
11536003	MAIL ROOM	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20
11536001	MAIN OFFICE	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.8	2024-05-20
11536005	MEDIA OFFICE	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	2.2	2024-05-20
11536013	MEDIA OFFICE 2	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.5	2024-05-20
11536038	STUDY ROOM NEXT TO 144	2024-05-15 @ 9:00 am	2024-05-17 @ 9:00 am	1.4	2024-05-20
11536030	TELEPHONE ROOM (140)	2024-05-15 @ 8:00 am	2024-05-17 @ 9:00 am	1.6	2024-05-20

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498