



May 7, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Buffalo Ridge Elementary School
7075 Shoreham Drive, Castle Pines, CO 80108
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Buffalo Ridge Elementary School, located at 7075 Shoreham Drive, in Castle Pines, Colorado.

Sixty (60) AirChek radon test kits were placed on April 30, 2024, and were retrieved on May 2, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
BUFFALO RIDGE ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528814	101	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528815	102	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.8	2024-05-03
11528816	103	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.9	2024-05-03
11528818	104	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528819	105	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528820	106	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528822	106 (B)	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528821	106 (D)	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528817	107	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528831	201	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528832	202	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528833	202 (D)	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528834	203	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528837	204	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528838	205	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528839	206	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528835	207	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.9	2024-05-03
11528842	301	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.5	2024-05-03
11528844	301 (B)	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528843	301 (D)	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528845	302	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528846	303	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528848	304	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528849	305	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528850	306	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528847	307	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528857	403 PLC	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.6	2024-05-03
11528851	404	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	1.4	2024-05-03
11528852	405	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.9	2024-05-03
11528855	407 GYM NORTH	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528856	407 GYM SOUTH	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528853	407 OFFICE	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.8	2024-05-03
11528854	407 OFFICE (D)	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.9	2024-05-03
11528809	501A	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	1.2	2024-05-03
11528810	501B	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528811	501B (D)	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528813	502	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03

Radon test result report for:
BUFFALO RIDGE ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528812	503	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528824	503	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528823	504	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.5	2024-05-03
11528827	505	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528825	506	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.5	2024-05-03
11528826	508	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.5	2024-05-03
11528828	509	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528829	509 PHONE ROOM	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528830	510	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528836	511	2024-04-30 @ 9:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528840	512	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.5	2024-05-03
11528841	513	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528806	514A	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03
11528805	514B	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	1.8	2024-05-03
11528804	514C	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	< 0.3	2024-05-03
11528803	514D	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	1.1	2024-05-03
11528802	514E	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528858	CAFETERIA EAST	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	0.6	2024-05-03
11528860	CAFETERIA OFFICE	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528859	CAFETERIA WEST	2024-04-30 @ 9:00 am	2024-05-02 @ 10:00 am	< 0.3	2024-05-03
11528808	LIBRARY - BLUE WALL	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.6	2024-05-03
11528807	LIBRARY - GREEN WALL	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.5	2024-05-03
11528801	MAIN OFFICE	2024-04-30 @ 8:00 am	2024-05-02 @ 9:00 am	0.7	2024-05-03