



May 10, 2022

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Bridge East
11722 N. Dransfeldt Road in Parker, Colorado
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Bridge East located at 11722 N. Dransfeldt Road in Parker, Colorado.

Five (5) AirChek radon test kits were placed in the main building, and four (4) AirChek radon test kits were placed in the mobile classroom on May 2, 2022. All nine (9) AirChek radon test kits were retrieved on May 4, 2022. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

May 5, 2022

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
BRIDGE EAST
MAIN BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9643500	EAST OFFICE	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	0.9	2022-05-05
9643499	ENTRY/RECEPTION	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668704	NORTH ROOM	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9643493	SOUTH ROOM	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	1.3	2022-05-05
9643496	WEST OFFICE	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	0.8	2022-05-05

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

May 5, 2022

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**BRIDGE EAST
MOBILE CLASSROOM**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9668702	BREAK ROOM	2022-05-02 @ 9:00 am	2022-05-04 @ 9:00 am	< 0.3	2022-05-05
9668703	BREAK ROOM OFFICE	2022-05-02 @ 9:00 am	2022-05-04 @ 9:00 am	< 0.3	2022-05-05
9643491	CLASS ROOM	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	< 0.3	2022-05-05
9668701	CLASS ROOM (DUPLICATE)	2022-05-02 @ 9:00 am	2022-05-04 @ 10:00 am	< 0.3	2022-05-05

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498