



May 10, 2022

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: DCSD Cherokee Trail Elementary School  
17302 Clarke Farms Drive in Parker, Colorado  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Cherokee Trail Elementary School, located at 17302 Clarke Farms Drive in Parker, Colorado.

Fifty-five (55) AirChek radon test kits were placed on May 2, 2022, and they were retrieved on May 4, 2022. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
Senior Scientist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal  
Project Manager

Attachment: Laboratory Report

Radon test result report for:

**CHEROKEE TRAIL ELEMENTARY SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9668724	110	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.8	2022-05-05
9668719	113	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.3	2022-05-05
9668718	115	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9668717	120	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9668712	127	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.3	2022-05-05
9668713	127	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9643498	141	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.8	2022-05-05
9643494	143	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.6	2022-05-05
9643497	144	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668744	145	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668743	146	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.7	2022-05-05
9668738	152	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.5	2022-05-05
9668739	153	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.7	2022-05-05
9668741	153 (BLANK)	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	< 0.3	2022-05-05
9668740	153 (DUPLICATE)	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.3	2022-05-05
9668745	154	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668746	155	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668742	156	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668737	158	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.3	2022-05-05
9668725	158	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9668736	159	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668735	160	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.3	2022-05-05
9668732	161	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.5	2022-05-05
9668731	162	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.8	2022-05-05
9668729	163	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.5	2022-05-05
9668730	163 (DUPLICATE)	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.5	2022-05-05
9668728	164	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.5	2022-05-05
9668727	165	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668726	166	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668734	169	2022-05-02 @ 10:00 am	2022-05-04 @ 11:00 am	1.4	2022-05-05
9668733	170	2022-05-02 @ 10:00 am	2022-05-04 @ 11:00 am	1.1	2022-05-05
9668709	185	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.0	2022-05-05
9668710	185 (DUPLICATE)	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	0.9	2022-05-05
9668706	186	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668707	187	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9668708	188	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668711	190	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05

Radon test result report for:

**CHEROKEE TRAIL ELEMENTARY SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9668755	222	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.1	2022-05-05
9668754	223	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	0.9	2022-05-05
9668753	224	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.0	2022-05-05
9668749	225	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	0.9	2022-05-05
9668750	225 (DUPLICATE)	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	0.8	2022-05-05
9668748	226	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	0.9	2022-05-05
9668747	227	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.5	2022-05-05
9668751	229	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	0.9	2022-05-05
9668752	230	2022-05-02 @ 11:00 am	2022-05-04 @ 11:00 am	1.0	2022-05-05
9668715	CAFETERIA	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668716	CAFETERIA	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.0	2022-05-05
9668705	COPY ROOM	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.5	2022-05-05
9668714	GYM OFFICE	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.2	2022-05-05
9668720	LIBRARY	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.1	2022-05-05
9668721	LIBRARY OFFICE	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.3	2022-05-05
9668723	LIBRARY OFFICE (BLANK)	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	< 0.3	2022-05-05
9668722	LIBRARY OFFICE (DUPLICATE)	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.3	2022-05-05
9643495	MAIN OFFICE	2022-05-02 @ 10:00 am	2022-05-04 @ 10:00 am	1.9	2022-05-05