



February 10, 2020

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

Re: Cantril Building
312 Cantril Street in Castle Rock, CO 80104
Radon Sampling Assessment

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools and buildings. At your request, QUEST conducted radon testing at the Cantril Building, located at 312 Cantril Street in Castle Rock, Colorado.

Nineteen (19) AirChek radon test kits were placed on February 4, 2020 and were retrieved on February 6, 2020. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:
CANTRIL BUILDING

| Kit # | Room Id | Started | Ended | pCi/L | Analyzed |
|---------|------------------------|-----------------------|-----------------------|-----------|------------|
| 9291756 | 100 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 2.7 ± 0.3 | 2020-02-07 |
| 9291754 | 101 - EAST | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 3.3 ± 0.3 | 2020-02-07 |
| 9291755 | 101 - WEST | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 3.0 ± 0.3 | 2020-02-07 |
| 9291757 | 102 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 1.7 ± 0.3 | 2020-02-07 |
| 9291762 | 103 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | < 0.3 | 2020-02-07 |
| 9291760 | 103 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 2.6 ± 0.3 | 2020-02-07 |
| 9291761 | 103 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 1.8 ± 0.3 | 2020-02-07 |
| 9291759 | 104 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 1.8 ± 0.3 | 2020-02-07 |
| 9291744 | 110 - PRESCHOOL SOUTH | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 3.7 ± 0.3 | 2020-02-07 |
| 9291745 | 113 - PRESCHOOL NORTH | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 3.2 ± 0.3 | 2020-02-07 |
| 9291747 | 115 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 1.0 ± 0.3 | 2020-02-07 |
| 9291748 | 115 - SOUTHEAST OFFICE | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 1.0 ± 0.3 | 2020-02-07 |
| 9291749 | 115 - SOUTHWEST OFFICE | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 1.3 ± 0.3 | 2020-02-07 |
| 9291750 | 115 - WEST OFFICE | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 1.1 ± 0.3 | 2020-02-07 |
| 9291751 | ANNEX - BASEMENT NORTH | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 3.3 ± 0.3 | 2020-02-07 |
| 9291753 | ANNEX - BASEMENT SOUTH | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 3.6 ± 0.3 | 2020-02-07 |
| 9291752 | ANNEX - BASEMENT SOUTH | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 3.7 ± 0.3 | 2020-02-07 |
| 9291758 | OPEN AREA BY 102 | 2020-02-04 @ 10:00 am | 2020-02-06 @ 11:00 am | 2.2 ± 0.3 | 2020-02-07 |
| 9291746 | STAGE | 2020-02-04 @ 10:00 am | 2020-02-06 @ 10:00 am | 2.9 ± 0.3 | 2020-02-07 |