



May 7, 2024

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: Daniel C. Oakes High School  
961 South Plum Creek Boulevard, Castle Rock, CO 80104  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Daniel C. Oakes High School, located at 961 South Plum Creek Boulevard in Castle Rock, Colorado.

Thirty-one (31) AirChek radon test kits were placed on May 1, 2024, and were retrieved on May 3, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
Founder/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble  
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head  
CEO

Attachment: Laboratory Report

Radon test result report for:  
**D.C. OAKES HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528994	AUDITORIUM AREA	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06
11528979	CONFERENCE ROOM	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.7	2024-05-06
11528992	COPY ROOM	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06
11528982	COPY/LOUNGE ROOM	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.4	2024-05-06
11528988	COUNSELING ROOM	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	2.2	2024-05-06
11528977	ITS ROOM	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.4	2024-05-06
11528990	MEETING ROOM	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.8	2024-05-06
11529005	MEZZANINE	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06
11528968	MRS. SCHMIDT ROOM	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.4	2024-05-06
11528989	OFFICE - AMIDON	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.1	2024-05-06
11528980	OFFICE MAIN	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06
11528991	OFFICE NEXT TO MEETING ROOM	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	2.2	2024-05-06
11528981	OFFICE WEST	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	2.1	2024-05-06
11529006	ROOM 1	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	0.8	2024-05-06
11528986	ROOM 10	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.8	2024-05-06
11528987	ROOM 10 (D)	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.8	2024-05-06
11528985	ROOM 11	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.1	2024-05-06
11528984	ROOM 12	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06
11528983	ROOM 13	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.7	2024-05-06
11529004	ROOM 2	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.1	2024-05-06
11529003	ROOM 3	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.4	2024-05-06
11529001	ROOM 4	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.1	2024-05-06
11529000	ROOM 5	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.3	2024-05-06
11528996	ROOM 6	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	2.1	2024-05-06
11528995	ROOM 7	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.3	2024-05-06
11528993	ROOM 8	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	2.0	2024-05-06
11528978	STAFF LOUNGE	2024-05-01 @ 9:00 am	2024-05-03 @ 10:00 am	1.7	2024-05-06
11528997	STUDENT STORE	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.3	2024-05-06
11528999	STUDENT STORE (B)	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	< 0.3	2024-05-06
11528998	STUDENT STORE (D)	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	0.9	2024-05-06
11529002	STUDY ROOM IN ROOM 4	2024-05-01 @ 10:00 am	2024-05-03 @ 10:00 am	1.2	2024-05-06