



May 7, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Clear Sky Elementary School
1470 Clear Sky Way, Castle Rock, CO 80109
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Clear Sky Elementary School, located at 1470 Clear Sky Way in Castle Rock, Colorado.

Fifty-two (52) AirChek radon test kits were placed on May 1, 2024, and were retrieved on May 3, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink that reads "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink that reads "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink that reads "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:

CLEAR SKY ELEMENTARY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529054	A101A	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529055	A101B	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529056	A101F	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529057	A101G	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529059	A102	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529068	A103A	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529071	A104A	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529072	A106	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529073	A106 KILN ROOM	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529075	A106 KILN ROOM (B)	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529074	A106 KILN ROOM (D)	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	1.0	2024-05-06
11529060	A110	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.5	2024-05-06
11529061	A111	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.5	2024-05-06
11529065	A111 OFFICE	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529062	A112	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529063	A112 (D)	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.7	2024-05-06
11529064	A113	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529105	B101	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	0.5	2024-05-06
11529104	B102	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	0.6	2024-05-06
11529078	B104A	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529103	B105	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	0.7	2024-05-06
11529102	B106	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529101	B107	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529100	B108	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529093	B109	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529094	B110	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529099	B111	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529095	B112	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529096	B112 OFFICE	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529098	B112 OFFICE (B)	2024-05-01 @ 12:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529097	B112 OFFICE (D)	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529080	B121	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529081	B122	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529082	B123	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529079	B124	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529083	B125	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529084	B126	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06

Radon test result report for:**CLEAR SKY ELEMENTARY**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529085	B127	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529086	B127 (D)	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529087	B128	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529088	B129	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529092	B130	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529089	B131	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529090	B131 OFFICE	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529091	B131 STUDY ROOM	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529069	CAFETERIA NORTH	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529070	CAFETERIA SOUTH	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529066	GYM EAST	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.6	2024-05-06
11529067	GYM WEST	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529076	LIBRARY NORTH	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529077	LIBRARY SOUTH	2024-05-01 @ 12:00 pm	2024-05-03 @ 12:00 pm	< 0.3	2024-05-06
11529053	MAIN OFFICE	2024-05-01 @ 11:00 am	2024-05-03 @ 12:00 pm	0.6	2024-05-06