



May 7, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Early Childhood Center South Building
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Early Childhood Center (ECC) South Building.

Twenty-six (26) AirChek radon test kits were placed on May 1, 2024, and twenty-five (25) were retrieved on May 3, 2024. One (1) AirChek radon kit was missing from Room A126 at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:**DCSD - EARLY CHILDHOOD SOUTH**

| Kit # | Room Id | Started | Ended | pCi/L | Analyzed |
|----------|-----------------|----------------------|----------------------|-------|------------|
| 11529115 | A102 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |
| 11529116 | A103 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 1.0 | 2024-05-06 |
| 11529117 | A103 (D) | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.7 | 2024-05-06 |
| 11529118 | A104 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |
| 11529119 | A105 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.9 | 2024-05-06 |
| 11529127 | A111 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.9 | 2024-05-06 |
| 11529133 | A115 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.9 | 2024-05-06 |
| 11529132 | A116 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.9 | 2024-05-06 |
| 11529131 | A117 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |
| 11529128 | A118 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.6 | 2024-05-06 |
| 11529130 | A118 (B) | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.7 | 2024-05-06 |
| 11529129 | A118 (D) | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |
| 11529126 | A119 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.6 | 2024-05-06 |
| 11529122 | A120 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.6 | 2024-05-06 |
| 11529123 | A123 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.7 | 2024-05-06 |
| 11529124 | A124 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.8 | 2024-05-06 |
| 11529125 | A125 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.8 | 2024-05-06 |
| 11529109 | A129 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.8 | 2024-05-06 |
| 11529111 | B101 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.8 | 2024-05-06 |
| 11529112 | B102 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.5 | 2024-05-06 |
| 11529114 | B105 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.6 | 2024-05-06 |
| 11529113 | B108 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.7 | 2024-05-06 |
| 11529110 | B112 | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |
| 11529121 | BREAK ROOM | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | 0.8 | 2024-05-06 |
| 11529107 | MAIN LOBBY AREA | 2024-05-01 @ 1:00 pm | 2024-05-03 @ 1:00 pm | < 0.3 | 2024-05-06 |