



May 17, 2022

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD; Eagle Ridge Elementary School
7716 Timberline Rd., Lone Tree, CO 80124
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Eagle Ridge Elementary School, located at 7716 Timberline Road in Lone Tree, Colorado.

Fifty-seven (57) AirChek radon test kits were placed on May 9, 2022, and they were retrieved on May 11, 2022. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:
EAGLE RIDGE ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11196817	109	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.6	2022-05-13
11196832	113	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.8	2022-05-13
11196835	121	2022-05-09 @ 12:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11189296	141	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189295	142	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189294	143	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189293	144	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189299	145	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189300	146	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.6	2022-05-13
11196801	146 (DUPLICATE)	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196802	152	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189298	153	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11189297	156	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196809	158	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.5	2022-05-13
11196811	158 (BLANK)	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196810	158 (DUPLICATE)	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196812	159	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196813	160	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196807	161	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196808	162	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196803	163	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196804	164	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196805	165	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196815	167	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196816	168	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196814	170	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196806	171	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196818	181	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.9	2022-05-13
11196839	185	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196841	185 (BLANK)	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196840	185 (DUPLICATE)	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196836	186	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196837	187	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196838	188	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196842	190	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196843	191	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196824	222	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13

Radon test result report for:
EAGLE RIDGE ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11196825	223	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.7	2022-05-13
11196826	224	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196822	225	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.6	2022-05-13
11196823	226	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196819	227	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196820	229	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196821	229 (DUPLICATE)	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.7	2022-05-13
11196827	230	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.6	2022-05-13
11196833	ART 115	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196848	CAFETERIA	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	0.6	2022-05-13
11196847	CAFETERIA	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196845	GYM	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	0.5	2022-05-13
11196844	GYM	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196846	GYM (INSIDE 134)	2022-05-09 @ 1:00 pm	2022-05-11 @ 1:00 pm	< 0.3	2022-05-13
11196829	MEDIA CENTER	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196828	MEDIA CENTER	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.5	2022-05-13
11196830	MEDIA CENTER 111	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13
11196831	MEDIA CENTER 111 (D)	2022-05-09 @ 12:00 pm	2022-05-11 @ 12:00 pm	0.6	2022-05-13
11196834	MUSIC 120	2022-05-09 @ 12:00 pm	2022-05-11 @ 1:00 pm	0.6	2022-05-13
11189292	OFFICE RECEPTION	2022-05-09 @ 11:00 am	2022-05-11 @ 12:00 pm	< 0.3	2022-05-13