



October 8, 2019

Zach Nannestad  
Douglas County School District  
620 Wilcox Street  
Castle Rock, CO 80104

**Re: Meadow View Elementary School at 3565 Celestial Avenue in Castle Rock, CO  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Meadow View Elementary School with its radon survey. At your request, QUEST conducted radon testing at the Meadow View Elementary School, located at 3565 Celestial Avenue in Castle Rock, Colorado.

Thirty-one (31) Air Chek radon test kits were placed on October 1, 2019 and were retrieved on October 3, 2019. The attached laboratory report identifies that radon concentrations in all locations were within (below) the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
President/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal  
Project Manager/Industrial Hygienist

Attachment: Laboratory Report

Radon test result report for:  
**MEADOW VIEW ES**  
**3565 CELESTIAL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9292402	100	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292401	101	2019-10-01 @ 10:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292403	102	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292404	103	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	0.6 ± 0.3	2019-10-04
9292405	104	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292406	106	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292407	108	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292408	109	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292412	110	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292413	110B	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	0.5 ± 0.3	2019-10-04
9292410	111	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292409	111	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292414	112	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292411	113	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292416	114	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	0.6 ± 0.3	2019-10-04
9292415	115	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292417	116	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292420	117	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292418	117	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292419	117	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292421	118	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292422	119	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292423	121	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292425	133	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292424	133	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292426	133A	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292427	CAFETERIA	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	0.6 ± 0.3	2019-10-04
9292428	CAFETERIA	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	0.6 ± 0.3	2019-10-04
9292430	H100B	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292429	H100B	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04
9292431	H100F	2019-10-01 @ 11:00 am	2019-10-03 @ 12:00 pm	< 0.3	2019-10-04