



May 22, 2024

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: Legend High School  
22219 Hilltop Road, Parker, CO 80138  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Legend High School, located at 22219 Hilltop Road in Parker, Colorado.

Seventy-five (75) AirChek radon test kits were placed on May 15, 2024, and seventy-four (74) were retrieved on May 17, 2024. One (1) AirChek radon kit was missing from Auditorium East at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
Founder/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble  
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head  
CEO

Attachment: Laboratory Report

Radon test result report for:  
**LEGEND HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536270	205	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536255	A200	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536258	A201	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536256	A201A	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536257	A201A (D)	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536259	A201B	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536261	A201C	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536260	A201D	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536262	A201E	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536263	A202	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536264	A203	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536267	A207	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536269	A207 (B)	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536268	A207 (D)	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536272	AUDITORIUM W	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536250	AUX GYM N	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536251	AUX GYM S	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536242	B101	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536238	B102	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536239	B103	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536240	B104	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536241	B105 OFFICE	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536243	B105 OFFICE	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536274	BUILDING ENGINEER OFFICE	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536247	CAFETERIA N	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536244	CAFETERIA S	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536246	CAFETERIA S (B)	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536245	CAFETERIA S (D)	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536273	CONTROL ROOM	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536202	CUSTODIAL OFFICE	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536225	D100	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536226	D101	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536227	D102	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536228	D103	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536229	D104	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536230	D105	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536231	D106	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20

Radon test result report for:  
**LEGEND HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536232	D107	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536233	D108	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536234	D108 (D)	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536235	D109	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536236	D110	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536237	D111	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536220	D112	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536221	D113	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536223	D113 (B)	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536222	D113 (D)	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536224	D113 FLEX ROOM	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536205	F100	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536206	F101	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536207	F101 OFFICE	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	0.5	2024-05-20
11536208	F102	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536209	F103	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536210	F104	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536211	F104 (D)	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536213	F105	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536214	F106	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536215	F107	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536216	F108	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536217	F109	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536218	F110	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536219	F111	2024-05-15 @ 1:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536212	F112	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536203	F113	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536204	F113 OFFICE	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	< 0.3	2024-05-20
11536201	KITCHEN OFFICE	2024-05-15 @ 12:00 pm	2024-05-17 @ 1:00 pm	0.6	2024-05-20
11536248	MAIN GYM N	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536249	MAIN GYM S	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536271	THEATER SHOP	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536254	TRAINING ROOM	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536252	WEIGHT ROOM	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536253	WEIGHT ROOM OFFICE	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536265	WRESTLING	2024-05-15 @ 1:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20
11536266	WRESTLING OFFICE	2024-05-15 @ 2:00 pm	2024-05-17 @ 2:00 pm	< 0.3	2024-05-20