



July 6, 2022

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: DCSD; Mountain Vista High School  
10585 Mountain Vista Ridge, Highlands Ranch, CO 80126  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Mountain Vista High School, located at 10585 Mountain Vista Ridge, in Highlands Ranch, Colorado.

Two hundred two (202) AirChek radon test kits were placed on June 28, 2022 and they were retrieved on June 30, 2022. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
Senior Scientist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal  
Project Manager

Attachment: Laboratory Report

Radon test result report for:  
**MOUNTAIN VISTA HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11222165	ATHLETIC CAGES	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11221965	AUD	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221967	AUD	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221966	AUD (DUPLICATE)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11222192	BOOKKEEPING	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11221903	BREAK ROOM	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11222156	CAFETERIA	2022-06-28 @ 11:00 am	2022-06-30 @ 1:00 pm	0.9	2022-07-01
11222155	CAFETERIA	2022-06-28 @ 11:00 am	2022-06-30 @ 1:00 pm	1.2	2022-07-01
11222153	CAFETERIA	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222154	CAFETERIA (DUPLICATE)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222187	CEGLIE (AP)	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222182	CEGLIE (P)	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.8	2022-07-01
11222185	CEGLIE (P) (BLANK)	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222183	CEGLIE (P) (DUPLICATE)	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
7369448	CHRISTOFFERSSON	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222140	COMPUTER LAB (IN L521)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222150	DARK ROOM (IN L606)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.2	2022-07-01
11221977	DELAUP OFFICE	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11222181	DURDY	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222115	FARM FRIG ROOM (IN L421)	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	1.0	2022-07-01
11222186	FLANIGAN	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222091	FUME HOOD ROOM	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.9	2022-07-01
11222119	FUME HOOD ROOM	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.6	2022-07-01
11221904	GERACI	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11222139	GRAD ROBES (IN L521)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222195	HASKELL	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222191	HEALTH	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
7369449	HUETS	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.5	2022-07-01
11222184	JAFFE	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11221910	KEYLER	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11222152	KILN ROOM (IN L610)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222085	L101	2022-06-28 @ 9:00 am	2022-06-30 @ 11:00 am	1.1	2022-07-01
11222172	L15 AUX. GYM	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222171	L15 AUX. GYM	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222086	L200	2022-06-28 @ 9:00 am	2022-06-30 @ 11:00 am	0.9	2022-07-01
11222108	L400	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11222107	L401	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.7	2022-07-01

Radon test result report for:  
**MOUNTAIN VISTA HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11222106	L402	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.5	2022-07-01
11222105	L403	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.5	2022-07-01
11222102	L404	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.8	2022-07-01
11222104	L404 (BLANK)	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	< 0.3	2022-07-01
11222103	L404 (DUPLICATE)	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.8	2022-07-01
11222101	L405	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.9	2022-07-01
11222100	L406	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	< 0.3	2022-07-01
11222099	L407	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11222098	L408	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	< 0.3	2022-07-01
11222096	L409	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.7	2022-07-01
11222095	L410	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11222093	L411	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.9	2022-07-01
11222094	L411 (DUPLICATE)	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11222092	L412	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.7	2022-07-01
11222090	L413	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.9	2022-07-01
11222089	L414	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11222088	L417	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	< 0.3	2022-07-01
11222112	L421	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222113	L421A	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222114	L421A (DUPLICATE)	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.6	2022-07-01
11222111	L423	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222109	L427	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.5	2022-07-01
11222110	L428	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.7	2022-07-01
11222116	L500	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222133	L501	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222134	L501 (DUPLICATE)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.5	2022-07-01
11222135	L502	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222132	L503	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222131	L504	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222130	L505	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222129	L506	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222128	L507	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222127	L508	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.6	2022-07-01
11222126	L509	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222125	L510	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	1.1	2022-07-01
11222122	L511	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222124	L511 (BLANK)	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01

Radon test result report for:  
**MOUNTAIN VISTA HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11222123	L511 (DUPLICATE)	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222121	L512	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.6	2022-07-01
11222120	L513	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222118	L514	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.7	2022-07-01
11222117	L517	2022-06-28 @ 10:00 am	2022-06-30 @ 12:00 pm	0.6	2022-07-01
11222138	L521	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222141	L523	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222137	L527	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.5	2022-07-01
11222136	L528	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.5	2022-07-01
11222142	L600	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.9	2022-07-01
11222144	L600 (BLANK)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	< 0.3	2022-07-01
11222143	L600 (DUPLICATE)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.6	2022-07-01
11222145	L602	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	0.8	2022-07-01
11222146	L603	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.0	2022-07-01
11222147	L604	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.2	2022-07-01
11222148	L606	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.1	2022-07-01
11222151	L610	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.2	2022-07-01
11222157	L701	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222162	L707 MAIN GYM	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222161	L707 MAIN GYM	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222160	L707 MAIN GYM	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222164	L707 MAIN GYM (BLANK)	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222163	L707 MAIN GYM (DUPLICATE)	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222169	L710	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222170	L711	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222173	L718	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222174	L718 (DUPLICATE)	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.5	2022-07-01
11222175	L722	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222176	L725	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222177	L726	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222178	L728	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.5	2022-07-01
11222179	L732	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222158	L742	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222159	L745	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	2.0	2022-07-01
7369447	LABRON	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222198	LAMONTE	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
7369450	LG. CONT. ROOM	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01

Radon test result report for:  
**MOUNTAIN VISTA HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7369444	LONG - OLD	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.7	2022-07-01
7369446	LONG - OLD (BLANK)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
7369445	LONG - OLD (DUPLICATE)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222149	MANNEQUIN ROOM (IN L606)	2022-06-28 @ 11:00 am	2022-06-30 @ 12:00 pm	1.7	2022-07-01
11221908	MONNET	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222199	MOTT	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222097	MVHS FIX+IT CLUB	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.6	2022-07-01
11221973	OFFICE (MICHAEL SCOTT)	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11222196	PAICH - OLD	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222188	PETERSON - OLD	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11221909	PJILLIPS	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221905	POST GRAD CENTER	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221906	POST GRAD CENTER (DUPLCIATE)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221928	QUIET ROOM IN U219	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222197	RAGAN	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.8	2022-07-01
11222193	SATE ROOM IN BOOKING	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222194	SATE ROOM IN BOOKING (DUPLICATE)	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11221902	SCOTT	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222087	SECURITY DESK	2022-06-28 @ 10:00 am	2022-06-30 @ 11:00 am	0.5	2022-07-01
11221911	SLAUGHTER	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221978	STAFF LOUNGE	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	0.6	2022-07-01
11221907	STAFFORD	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221963	STAGE	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221964	STAGE (WORKSHOP ROOM)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
7369443	STRAIT	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.9	2022-07-01
11221901	STURGEON	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221914	SUPPLIES (IN 207)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221916	SUPPLIES (IN 207) (BLANK)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221915	SUPPLIES (IN 207) (DUPLICATE)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222200	THORNTA	2022-06-28 @ 1:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11222189	TIMEOUT ROOM 1	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.7	2022-07-01
11222190	TIMEOUT ROOM 2	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222180	U100 - MAIN OFFICE RECEPTION	2022-06-28 @ 1:00 pm	2022-06-30 @ 1:00 pm	0.5	2022-07-01
11221912	U202	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221913	U207	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221917	U208	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.9	2022-07-01
11221918	U208 - STORAGE	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.7	2022-07-01

Radon test result report for:

**MOUNTAIN VISTA HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11221921	U210	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221919	U213	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221920	U213A	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.5	2022-07-01
11221922	U214	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221924	U214A	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221923	U214B	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221925	U217	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221926	U217 (DUPLICATE)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.7	2022-07-01
11221927	U219	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	0.6	2022-07-01
11221929	U220 (IN 219)	2022-06-28 @ 2:00 pm	2022-06-30 @ 2:00 pm	< 0.3	2022-07-01
11221930	U222	2022-06-28 @ 2:00 pm	2022-06-30 @ 3:00 pm	0.5	2022-07-01
11221931	U233	2022-06-28 @ 2:00 pm	2022-06-30 @ 3:00 pm	0.7	2022-07-01
11221932	U301	2022-06-28 @ 2:00 pm	2022-06-30 @ 3:00 pm	0.5	2022-07-01
11221933	U302	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221934	U303	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221936	U303 (BLANK)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221935	U303 (DUPLICATE)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221937	U304	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.7	2022-07-01
11221938	U305	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.5	2022-07-01
11221939	U305 STORAGE	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	1.4	2022-07-01
11221940	U307	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.5	2022-07-01
11221952	U309	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.9	2022-07-01
11221951	U310	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.7	2022-07-01
11221950	U311	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.9	2022-07-01
11221949	U312	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221948	U313	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221947	U314	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221945	U315	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	1.0	2022-07-01
11221946	U315 (DUPLICATE)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	1.1	2022-07-01
11221944	U316	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221943	U317	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.5	2022-07-01
11221942	U318	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221941	U319	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221960	U323	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.6	2022-07-01
11221953	U326	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221959	U328	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.9	2022-07-01
11221954	U331	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01

July 5, 2022

**\*\* LABORATORY ANALYSIS REPORT \*\***

Radon test result report for:  
**MOUNTAIN VISTA HIGH SCHOOL**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
11221956	U331 (BLANK)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221955	U331 (DUPLICATE)	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221957	U332	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221958	U333	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221961	U716	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	< 0.3	2022-07-01
11221962	U717	2022-06-28 @ 3:00 pm	2022-06-30 @ 3:00 pm	0.7	2022-07-01
11221968	U722	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11221974	U727	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	0.5	2022-07-01
11221976	U727 (BLANK)	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11221975	U727 (DUPLICATE)	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11221969	U729	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11221970	U730	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	0.5	2022-07-01
11221971	U731	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	0.6	2022-07-01
11221972	U733	2022-06-28 @ 4:00 pm	2022-06-30 @ 4:00 pm	< 0.3	2022-07-01
11222167	WEIGHT ROOM - EAST	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01
11222168	WEIGHT ROOM - OFFICE	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	0.6	2022-07-01
11222166	WEIGHT ROOM - WEST	2022-06-28 @ 12:00 pm	2022-06-30 @ 1:00 pm	< 0.3	2022-07-01

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498