



May 24, 2021

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Pine Lane Primary School
6485 Ponderosa Drive in Parker, CO 80138
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Pine Lane Primary School, located at 6485 Ponderosa Drive in Parker, Colorado.

Fifty-six (56) AirChek radon test kits were placed on May 17, 2021 and were retrieved on May 20, 2021. The attached laboratory report identifies all locations to be within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:
PINE LANE PRIMARY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9668860	101	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668862	102	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668861	103	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668863	103 (DUPLICATE)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668865	104	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668866	105	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668867	106	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9643428	141 (GYM OFFICE)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668868	201	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668869	202	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668870	203	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668875	204	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668876	205	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668877	206	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668874	209	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668884	301	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	0.5	2021-05-21
9668885	302	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	0.9	2021-05-21
9668886	303	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668888	304	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668889	305	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668890	306	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668887	309	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668894	38 (IN 502)	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643422	401	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	0.6	2021-05-21
9643424	401 (DUPLICATE)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	0.6	2021-05-21
9643423	402	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	1.0	2021-05-21
9668900	403	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668899	404	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668896	500 (ART)	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668891	502	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668893	502 (BLANK)	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668892	502 (DUPLICATE)	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668882	508	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668883	508 (DUPLICATE)	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668881	508A (BEAR CAVE)	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668880	509 (OFFICE IN LIBRARY WORK RM.)	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668878	512 LIBRARY	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21

Radon test result report for:
PINE LANE PRIMARY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9668871	513	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668873	513 (BLANK)	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668872	513 (DUPLICATE)	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668895	514	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668898	515	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643425	CAFETERIA (COAT WALL)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643426	CAFETERIA (RULES POSTER)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668897	CUSTODIAL OFFICE	2021-05-17 @ 1:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643429	GYM (E. WALL BY STAGE)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643430	GYM (S. WALL LIGHT CAGE)	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9643427	KITCHEN "OFFICE"	2021-05-17 @ 2:00 pm	2021-05-20 @ 1:00 pm	< 0.3	2021-05-21
9668879	LIBRARY WORK RM.	2021-05-17 @ 1:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668854	MAIN OFFICE	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668859	OFFICE (CONFERENCE RM.)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668855	OFFICE (HEALTH RM.)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668858	OFFICE (IRONS/PLS READ)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668857	OFFICE (MRS. CASA'S OFFICE)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668856	OFFICE (WORK RM.)	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21
9668864	STAFF LOUNGE	2021-05-17 @ 12:00 pm	2021-05-20 @ 12:00 pm	< 0.3	2021-05-21