



May 7, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Rock Canyon High School
5810 McArthur Ranch Road, Littleton, CO 80124
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Rock Canyon High School, located at 5810 McArthur Ranch Road in Littleton, Colorado.

Seventy-six (76) AirChek radon test kits were placed on April 30, 2024, and were retrieved on May 2, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Handwritten signature of Robert A. Woellner in black ink.

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Handwritten signature of Jake Gamble in black ink.

Jake Gamble
Industrial Hygienist

Handwritten signature of Larry Head in black ink.

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
ROCK CANYON HS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528948	100	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528950	200	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528949	200 OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528955	230	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528952	240	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528951	250	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528954	300	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	0.5	2024-05-03
11528953	300 OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528960	400	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528961	500	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528957	600	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528959	600 (B)	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528958	600 (D)	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528956	625	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528934	6450	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528936	6450 (B)	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528935	6450 (D)	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	0.6	2024-05-03
11528937	6775	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528938	6800	2024-04-30 @ 2:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528914	7100	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528928	7255	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528929	7300	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528930	7400	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528927	7500	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528910	8000	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528919	8025	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528909	8050	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528926	8100	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	0.7	2024-05-03
11528925	8125	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528923	8200	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528924	8200 (D)	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528922	8300	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528921	8400	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528920	8450	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528918	8500	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528917	8550	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528916	8600	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03

Radon test result report for:
ROCK CANYON HS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528915	8700	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528967	8800	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528911	8850	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528913	8850 (B)	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528912	8850 (D)	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528792	9000A	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528800	9000B	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.5	2024-05-03
11528901	9000B (D)	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528791	9025	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.5	2024-05-03
11528908	9100	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528907	9125	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.8	2024-05-03
11528905	9200	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.7	2024-05-03
11528906	9225	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528904	9300	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.5	2024-05-03
11528903	9400	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528902	9450	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528799	9500	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528798	9550	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	0.7	2024-05-03
11528797	9600	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528796	9700	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528795	9800	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528794	9850	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528793	9900	2024-04-30 @ 1:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528964	AUDITORIUM CONTROL ROOM	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	0.7	2024-05-03
11528962	AUDITORIUM EAST	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	0.9	2024-05-03
11528963	AUDITORIUM WEST	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	0.7	2024-05-03
11528939	AUX GYM NORTH	2024-04-30 @ 2:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528940	AUX GYM SOUTH	2024-04-30 @ 2:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528932	CAFETERIA NORTH	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528933	CAFETERIA SOUTH	2024-04-30 @ 2:00 pm	2024-05-02 @ 2:00 pm	< 0.3	2024-05-03
11528946	CUSTODIAL OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528947	CUSTODIAL OFFICE (D)	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528966	CUSTODIAL ROOM	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528945	KITCHEN OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528943	MAIN GYM NORTH	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528942	MAIN GYM SOUTH	2024-04-30 @ 2:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528941	WEIGHT ROOM	2024-04-30 @ 2:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03

May 3, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
ROCK CANYON HS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11528944	WEIGHT ROOM OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03
11528965	WRESTLING OFFICE	2024-04-30 @ 3:00 pm	2024-05-02 @ 3:00 pm	< 0.3	2024-05-03

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498