



May 7, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Renaissance Secondary School
3954 Trail Boss Lane, Castle Rock, CO 80104
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Renaissance Secondary School, located at 3954 Trail Boss Lane in Castle Rock, Colorado.

Thirty-eight (38) AirChek radon test kits were placed on May 1, 2024, and were retrieved on May 3, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Handwritten signature of Robert A. Woellner in black ink.

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Handwritten signature of Jake Gamble in black ink.

Jake Gamble
Industrial Hygienist

Handwritten signature of Larry Head in black ink.

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
DCSD - RENAISSANCE BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529148	A102	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.4	2024-05-06
11529147	A103	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.7	2024-05-06
11529146	A104	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.6	2024-05-06
11529142	A105	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.5	2024-05-06
11529145	A11	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.3	2024-05-06
11529143	A110	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.2	2024-05-06
11529144	A110 (D)	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.3	2024-05-06
11529151	B104	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.1	2024-05-06
11529135	B106	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.2	2024-05-06
11529134	B107	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.9	2024-05-06
11529136	B108	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.0	2024-05-06
11529141	B109	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.1	2024-05-06
11529137	B110	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	2.0	2024-05-06
11529138	B113	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	2.0	2024-05-06
11529139	B119	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.8	2024-05-06
11529157	B121	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.7	2024-05-06
11529154	B122	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.3	2024-05-06
11529156	B122 (B)	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	< 0.3	2024-05-06
11529155	B122 (D)	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.4	2024-05-06
11529163	B122 OFFICE	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.2	2024-05-06
11529153	B123	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.7	2024-05-06
11529162	C102	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	2.2	2024-05-06
11529161	C103	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.7	2024-05-06
11529160	C104	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.4	2024-05-06
11529158	C105	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.9	2024-05-06
11529152	C110	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.8	2024-05-06
11529159	C111	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.9	2024-05-06
11529164	CAFETERIA NORTH	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.3	2024-05-06
11529166	CAFETERIA OFFICE	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	0.5	2024-05-06
11529167	CAFETERIA OFFICE (D)	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	< 0.3	2024-05-06
11529165	CAFETERIA SOUTH	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.0	2024-05-06
11529171	D101	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	0.9	2024-05-06
11529170	D105	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	1.0	2024-05-06
11529149	D106	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	0.9	2024-05-06
11529150	D119	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.3	2024-05-06
11529168	GYM NORTH	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	0.5	2024-05-06
11529169	GYM SOUTH	2024-05-01 @ 1:00 pm	2024-05-03 @ 2:00 pm	0.5	2024-05-06

May 6, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
DCSD - RENAISSANCE BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529140	KITCHEN/STAFF LOUNGE	2024-05-01 @ 1:00 pm	2024-05-03 @ 1:00 pm	1.5	2024-05-06

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498