



May 15, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Pioneer Elementary School
10881 Riva Ridge Drive, Parker, CO 80138
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Pioneer Elementary School, located at 10881 Riva Ridge Drive, in Parker, Colorado.

Sixty-three (63) AirChek radon test kits were placed on May 8, 2024, and were retrieved on May 10, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
PIONEER ELEMENTARY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529270	101	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.9	2024-05-14
11529269	102	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.7	2024-05-14
11529268	103	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529260	104	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529259	105	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529258	106	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529261	107	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.7	2024-05-14
11529254	201	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529253	202	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.5	2024-05-14
11529251	203	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529242	203	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529252	203 (D)	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529239	204	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529241	204 (B)	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529240	204 (D)	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529238	205	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529237	206	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529233	301	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529232	302	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.8	2024-05-14
11529231	303	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.8	2024-05-14
11529226	304	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	1.0	2024-05-14
11529227	305	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529228	306	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.8	2024-05-14
11529229	306 (D)	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529230	307	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529276	404	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529277	405	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529278	407	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529246	501 A	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.6	2024-05-14
11529244	501 N	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529245	501 S	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529272	502	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529271	503	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529265	504	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.6	2024-05-14
11529256	505	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529262	506	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529264	506 (B)	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14

Radon test result report for:**PIONEER ELEMENTARY**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11529263	506 (D)	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529266	507	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	1.0	2024-05-14
11529255	508	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529248	510	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.5	2024-05-14
11529249	510 COPY ROOM	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529250	510 TELEPHONE ROOM	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529243	511	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529235	512	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529234	513	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529223	514A	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.5	2024-05-14
11529222	514C	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529221	514D	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529220	514E	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529273	CAFETERIA	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.5	2024-05-14
11529275	CAFETERIA (D)	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529224	COUNSELOR - HIRSCH	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529247	DRAKE	2024-05-08 @ 9:00 am	2024-05-10 @ 9:00 am	0.7	2024-05-14
11529274	GOLDEN	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529279	GYM N	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529280	GYM S	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	1.0	2024-05-14
11529052	KITCHEN OFFICE	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529219	MAIN OFFICE	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	< 0.3	2024-05-14
11529225	ROBBINS/WATSON	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	1.0	2024-05-14
11529257	TYLER	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	0.8	2024-05-14
11529267	VICK	2024-05-08 @ 9:00 am	2024-05-10 @ 10:00 am	< 0.3	2024-05-14
11529236	WALSH	2024-05-08 @ 8:00 am	2024-05-10 @ 9:00 am	0.5	2024-05-14