



December 12, 2022

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD; Soaring Hawk Elementary School
4665 Tanglevine Dr., Castle Rock, CO 80109
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Soaring Hawk Elementary School, located at 4665 Tanglevine Drive, in Castle Rock, Colorado.

Fifty (50) AirChek radon test kits were placed on December 6, 2022, and forty-nine (49) were retrieved on December 8, 2022. One (1) test kit was missing at from room M66 at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:
SOARING HAWK ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11632035	CAFETERIA	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.8	2022-12-09
11632034	CAFETERIA	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.1	2022-12-09
11632024	CENTRAL AREA - SSN	2022-12-06 @ 11:00 am	2022-12-08 @ 11:00 am	0.6	2022-12-09
11632054	L09	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632055	L11	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632056	L12	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.6	2022-12-09
11632057	L13	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632058	L14	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632062	L15	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632059	L16	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.6	2022-12-09
11632061	L16 (BLANK)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632060	L16 (DUPLICATE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632047	M11	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632048	M12	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632049	M13	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632050	M14	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.6	2022-12-09
11632051	M14 (DUPLICATE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632052	M15	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.6	2022-12-09
11632053	M16	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.6	2022-12-09
11632041	M22	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.8	2022-12-09
11632042	M22 (DUPLICATE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632043	M24	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.8	2022-12-09
11632044	M27	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632045	M28	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632033	M41 (ART)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632039	M45	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.0	2022-12-09
11632040	M48	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.0	2022-12-09
11632038	M50	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.7	2022-12-09
11632036	M51	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.0	2022-12-09
11632037	M51 - TELEPHONE ROOM	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.8	2022-12-09
11632028	M57 (GYM OFFICE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632032	M58 (MUSIC)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632017	M61	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.6	2022-12-09
11632019	M62	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.7	2022-12-09
11632025	M68	2022-12-06 @ 11:00 am	2022-12-08 @ 11:00 am	0.8	2022-12-09
11632020	M69	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.7	2022-12-09
11632021	M69 (DUPLICATE)	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	1.0	2022-12-09

Radon test result report for:
SOARING HAWK ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11632022	M70	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.8	2022-12-09
11632023	M70 - STORAGE	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.6	2022-12-09
11632026	M73 (GYM)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.0	2022-12-09
11632027	M73 (GYM)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	1.0	2022-12-09
11632046	M87	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632014	MAIN OFFICE - HEALTH	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.9	2022-12-09
11632016	MAIN OFFICE - M34	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	0.8	2022-12-09
11632015	MAIN OFFICE - M38	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	1.1	2022-12-09
11632013	MAIN OFFICE - RECEPTION	2022-12-06 @ 10:00 am	2022-12-08 @ 11:00 am	1.1	2022-12-09
11632029	SHE BOOKROOM (STORAGE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09
11632031	SHE BOOKROOM (STORAGE) (BLANK)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	< 0.3	2022-12-09
11632030	SHE BOOKROOM (STORAGE) (DUPLICATE)	2022-12-06 @ 11:00 am	2022-12-08 @ 12:00 pm	0.9	2022-12-09