May 29, 2024

Steve Aldrich
Director of Facilities and Grounds
Liberty School District
801 Kent Street
Liberty, Missouri 64068

Project: Limited Lead in Drinking Water Testing
Address: 1251 Camille Street, Liberty, Missouri 64068

Mr. Steve Aldrich

On March 20, 2024 and May 1, 2024, Bradly Young of Axiom Service Professionals (ASP), conducted lead in drinking water sampling at the above referenced address. Inspector certification is provided in Appendix A. A total of 120 samples were collected from various potential drinking water outlets including sources used for drinking, cooking, or cleaning of cooking and eating utensils throughout the building.

Drinking Water Standards

The use of lead solder and other lead-containing materials as defined in the EPA Safe Drinking Water Act in connecting household plumbing to public water supplies was prohibited as of 1986. The act established the definition of “lead free” to be less than 8% as a weighted average across wetted surfaces of a pipe, pipe fitting, plumbing fitting, and fixture and 0.2% lead for solder and flux. In 2011, the definition of “lead free” as it applied to wetted surfaces of a pipe, pipe fitting, and plumbing fitting and fixture was reduced from 8% to 0.25% as a weighted average. Many older structures still have lead pipe or lead-soldered plumbing internally, which may substantially increase the lead content of water at the tap. Nationwide regulations controlling the lead content of drinking-water coolers in schools went into effect in 1989.

In 1991, the EPA published the Lead and Copper Rule establishing limits on the amount of lead and copper in drinking water. This regulation can be found under 40 CFR Part 141, Subpart I. Reference: https://www.epa.gov/dwreginfo/lead-and-copper-rule

The EPA has set lead in drinking water standards as outlined below.

- For lead, the maximum contaminant level goal (MCLG) is zero. This is the levels determined to be safe by toxicological and biomedical considerations, independent of feasibility. EPA's National Primary Drinking Water Regulations for Lead establish a treatment level of **0.015 mg/L** or **15 ppb** (parts per billion) in municipal drinking water systems.

The Missouri Senate Bill 681 “Get the Lead Out of School Drinking Water Act”, passed in 2022, has set the standard summarized below.
Reference: https://www.senate.mo.gov/22info/BTS_Web/Bill.aspx?SessionType=R&BillID=71259862

- On or before January 1, 2024, each school shall conduct an inventory of all drinking water outlets and all outlets that are used for dispensing water for cooking or for cleaning cooking and eating utensils in each of the school’s buildings. A plan for testing should then be developed, prioritizing early childhood education programs and elementary schools, and made available to the public.
- The bill outlines that beginning in the 2023-2024 school year and for each subsequent school year, each school shall provide drinking water with a lead concentration below five parts per billion (**5 ppb**). Any school with greater than or equal to 5 ppb shall provide results and remediation plans to parents and staff within 7 business days of receiving results.

Drinking Fountain Identification

Drinking fountains throughout the school were visually assessed to determine if they matched those listed by the EPA to be lead-containing. The list of drinking fountains reported by the EPA to contain lead-lined holding tanks or solder joints is presented as Appendix B. Below is a list of drinking fountains within the school that match those reported by the EPA to be lead-containing.

Location	Make	Model #	Serial #
None Matching			

Water Sampling Methods:

Water samples were collected from each selected location as “first draw” and/or “flush”. First draw samples typically represent worst case sample results. A flush sample is typically collected to determine if an elevation is originating beyond the fixture in the fixture supply line or beyond. Samples were deposited into a non-preserved 250-milliliter sterile Nalgene screw top bottle. Immediately following sample collection, the samples were delivered to Keystone Laboratories located at 8857 Long Street, Lenexa, Kansas 66215. Upon arrival at the laboratory, samples were preserved through addition of nitric acid.

Keystone Laboratories is accredited through the Missouri Department of Natural Resources for analysis of lead in water.

Below is a summary of the water sampling results as reported in Appendix C by Keystone Laboratories. Results exceeding the applicable drinking water standards are shown in red text.

March 20, 2024 Water Sampling Results:

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-1-FD	Warren Hills - 001720-Conference 1B	Sink Tap	First Draw	<0.4
1251-2-FD	Warren Hills - 001717-Nurse's Office	Sink Tap	First Draw	<0.4
1251-3-FD	Warren Hills - 002519-Nurse's Office-Restroom	Sink Tap	First Draw	<0.4
1251-4-FD	Warren Hills - 001719-Staff Restroom by Nurse's Office	Sink Tap	First Draw	<0.4
1251-5-FD	Warren Hills - 001479-Art Room	Sink Tap	First Draw	<0.4
1251-6-FD	Warren Hills - 001712-Art Room	Sink Tap	First Draw	<0.4
1251-7-FD	Warren Hills - 001713-Art Room	Sink Tap	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-8-FD	Warren Hills - 001714-Art Room	Sink Tap	First Draw	<0.4
1251-9-FD	Warren Hills - 001478-Room 4	Sink Tap	First Draw	<0.4
1251-10-FD	Warren Hills - 001474-Boys Restroom by Room 4-Right	Sink Tap	First Draw	<0.4
1251-11-FD	Warren Hills - 002520-Boys Restroom by Room 4-Right	Sink Tap	First Draw	<0.4
1251-12-FD	Warren Hills - 001476-Girls Restroom by Room 4-Left	Sink Tap	First Draw	<0.4
1251-13-FD	Warren Hills - 001477-Girls Restroom by Room 4-Right	Sink Tap	First Draw	<0.4
1251-14-FD	Warren Hills - 001716-Hallway by Gym-Left	Drinking Fountain	First Draw	<0.4
1251-15-FD	Warren Hills - 001716-Hallway by Gym-Right	Drinking Fountain	First Draw	<0.4
1251-16-FD	Warren Hills - 001715-Gym-Left	Drinking Fountain	First Draw	<0.4
1251-17-FD	Warren Hills - 001715-Gym-Right	Drinking Fountain	First Draw	<0.4
1251-18-FD	Warren Hills - 001715F-Hallway by Gym	Bottle Filler	First Draw	<0.4
1251-19-FD	Warren Hills - 004669-Kitchen-Three Bay Sink	Sink Tap	First Draw	0.4
1251-20-FD	Warren Hills - 004670-Kitchen-Three Bay Sink	Sink Tap	First Draw	<0.4
1251-21-FD	Warren Hills - 004651-Kitchen-Three Bay Sink	Sink Tap	First Draw	0.4
1251-22-FD	Warren Hills - 004652-Kitchen-Dishwasher Room	Sink Tap	First Draw	<0.4
1251-23-FD	Warren Hills - 004653-Kitchen-Dishwasher Room	Sink Tap	First Draw	3.5
1251-24-FD	Warren Hills - 004654-Kitchen-Dishwasher Room	Sink Tap	First Draw	<0.4
1251-25-FD	Warren Hills - 004662-Kitchen-Staff Restroom	Sink Tap	First Draw	<0.4
1251-26-FD	Warren Hills - 004663-Kitchen-Outside Freezer	Sink Tap	First Draw	1.2
1251-27-FD	Warren Hills - 004664-Kitchen-Outside Freezer	Sink Tap	First Draw	0.5
1251-28-FD	Warren Hills - 004665-Kitchen-Serving Line Faucet	Sink Tap	First Draw	0.9
1251-29-FD	Warren Hills - 004666-Kitchen-Outside Office	Sink Tap	First Draw	<0.4
1251-30-FD	Warren Hills - 004667-Kitchen-Outside Office	Sink Tap	First Draw	1.5
1251-31-FD	Warren Hills - 004668-Kitchen-Outside Office	Sink Tap	First Draw	<0.4
1251-32-FD	Warren Hills - 004661-Kitchen-Handwashing by Restroom	Sink Tap	First Draw	<0.4
1251-33-FD	Warren Hills - 000961-Next to Room 8-Girls	Drinking Fountain	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-34-FD	Warren Hills - 000963-Next to Room 8	Drinking Fountain	First Draw	<0.4
1251-35-FD	Warren Hills - 000963-Next to Room 8-Boys	Bottle Filler	First Draw	<0.4
1251-36-FD	Warren Hills - 000962-Handwashing by Room 8	Sink Tap	First Draw	<0.4
1251-37-FD	Warren Hills - 001952-Room 100	Sink Tap	First Draw	6
1251-38-FD	Warren Hills - 001951-Staff Restroom by 100	Sink Tap	First Draw	<0.4
1251-39-FD	Warren Hills - 001953-Room 104-Restroom	Sink Tap	First Draw	<0.4
1251-40-FD	Warren Hills - 001955-Room 104	Sink Tap	First Draw	<0.4
1251-41-FD	Warren Hills - 001954-Room 104	Bubbler	First Draw	<0.4
1251-42-FD	Warren Hills - 001956-Room 106-Restroom	Sink Tap	First Draw	<0.4
1251-43-FD	Warren Hills - 001958-Room 106	Sink Tap	First Draw	<0.4
1251-44-FD	Warren Hills - 001957-Room 106	Bubbler	First Draw	<0.4
1251-45-FD	Warren Hills - 001959-Room 110-Restroom	Sink Tap	First Draw	<0.4
1251-46-FD	Warren Hills - 001961-Room 110	Sink Tap	First Draw	<0.4
1251-47-FD	Warren Hills - 001960-Room 110	Bubbler	First Draw	<0.4
1251-48-FD	Warren Hills - 001962-Room 112-Restroom	Sink Tap	First Draw	<0.4
1251-49-FD	Warren Hills - 001963-Room 112	Sink Tap	First Draw	0.5
1251-50-FD	Warren Hills - 001964-Room 112	Bubbler	First Draw	<0.4
1251-51-FD	Warren Hills - 001966-Room 113	Sink Tap	First Draw	0.6
1251-52-FD	Warren Hills - 001965-Room 113	Bubbler	First Draw	<0.4
1251-53-FD	Warren Hills - 001968-Room 111	Sink Tap	First Draw	0.5
1251-54-FD	Warren Hills - 001967-Room 111	Bubbler	First Draw	<0.4
1251-55-FD	Warren Hills - 001968-Room 107	Sink Tap	First Draw	<0.4
1251-56-FD	Warren Hills - 001970-Room 107	Bubbler	First Draw	<0.4
1251-57-FD	Warren Hills - 001972-Room 105	Sink Tap	First Draw	<0.4
1251-58-FD	Warren Hills - 001971-Room 105	Bubbler	First Draw	<0.4
1251-59-FD	Warren Hills - 000965-Room 9	Sink Tap	First Draw	1.1

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-60-FD	Warren Hills - 000964-Room 9	Bubbler	First Draw	<0.4
1251-61-FD	Warren Hills - 000966-Room 9-Restroom	Sink Tap	First Draw	<0.4
1251-62-FD	Warren Hills - 001946-10I	Sink Tap	First Draw	0.5
1251-63-FD	Warren Hills - 001947-Room 10I	Bubbler	First Draw	1.3
1251-64-FD	Warren Hills - 002522-Student Services Staff Restroom	Sink Tap	First Draw	<0.4
1251-65-FD	Warren Hills - 001944-Room 10H	Sink Tap	First Draw	<0.4
1251-66-FD	Warren Hills - 001943-Room 10H	Bubbler	First Draw	<0.4
1251-119-FD	Warren Hills - 002228-10G	Sink Tap	First Draw	0.9
1251-120-FD	Warren Hills - 001942-10F	Sink Tap	First Draw	<0.4
1251-69-FD	Warren Hills - 000967-Room 11-Restroom	Sink Tap	First Draw	<0.4
1251-70-FD	Warren Hills - 000969-Room 11	Sink Tap	First Draw	1.6
1251-71-FD	Warren Hills - 000968-Room 11	Bubbler	First Draw	0.5
1251-72-FD	Warren Hills - 001994-Room 204	Sink Tap	First Draw	0.7
1251-73-FD	Warren Hills - 001993-Room 204	Bubbler	First Draw	<0.4
1251-74-FD	Warren Hills - 001995-Room 206	Sink Tap	First Draw	1.4
1251-75-FD	Warren Hills - 001996-Room 206	Bubbler	First Draw	<0.4
1251-76-FD	Warren Hills - 001998-Room 210	Sink Tap	First Draw	14.2
1251-77-FD	Warren Hills - 001997-Room 210	Bubbler	First Draw	<0.4
1251-78-FD	Warren Hills - 001999-Room 212	Sink Tap	First Draw	<0.4
1251-79-FD	Warren Hills - 002000-Room 212	Bubbler	First Draw	<0.4
1251-80-FD	Warren Hills - 001991-Room 213	Sink Tap	First Draw	<0.4
1251-81-FD	Warren Hills - 001992-Room 213	Bubbler	First Draw	<0.4
1251-82-FD	Warren Hills - 000990-Room 211	Sink Tap	First Draw	<0.4
1251-83-FD	Warren Hills - 000989-Room 211	Bubbler	First Draw	<0.4
1251-84-FD	Warren Hills - 000987-Room 207	Sink Tap	First Draw	<0.4
1251-85-FD	Warren Hills - 000988-Room 207	Bubbler	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-86-FD	Warren Hills - 000986-Room 205	Sink Tap	First Draw	0.4
1251-87-FD	Warren Hills - 000985-Room 205	Bubbler	First Draw	<0.4
1251-88-FD	Warren Hills - 001948-Handwashing by Room 14	Sink Tap	First Draw	<0.4
1251-89-FD	Warren Hills - 001949-By Room 14-Girls	Drinking Fountain	First Draw	<0.4
1251-90-FD	Warren Hills - 001950-By Room 14-Boys	Drinking Fountain	First Draw	<0.4
1251-91-FD	Warren Hills - 000983-Room 304	Sink Tap	First Draw	2.2
1251-92-FD	Warren Hills - 000984-Room 304	Bubbler	First Draw	<0.4
1251-93-FD	Warren Hills - 000978-Room 306	Sink Tap	First Draw	0.4
1251-94-FD	Warren Hills - 000977-Room 306	Bubbler	First Draw	<0.4
1251-95-FD	Warren Hills - 000980-Room 310	Sink Tap	First Draw	0.6
1251-96-FD	Warren Hills - 000979-Room 310	Bubbler	First Draw	<0.4
1251-97-FD	Warren Hills - 000981-Room 312	Sink Tap	First Draw	0.4
1251-98-FD	Warren Hills - 000982-Room 312	Bubbler	First Draw	<0.4
1251-99-FD	Warren Hills - 000970-Room 313	Sink Tap	First Draw	0.9
1251-100-FD	Warren Hills - 000976-Room 311	Sink Tap	First Draw	0.6
1251-101-FD	Warren Hills - 000975-Room 311	Bubbler	First Draw	<0.4
1251-102-FD	Warren Hills - 000973-Room 307	Sink Tap	First Draw	0.4
1251-103-FD	Warren Hills - 000974-Room 307	Bubbler	First Draw	<0.4
1251-104-FD	Warren Hills - 000972-Room 305	Sink Tap	First Draw	<0.4
1251-105-FD	Warren Hills - 000971-Room 305	Bubbler	First Draw	<0.4
1251-106-FD	Warren Hills - 001936-Across from Room 302	Drinking Fountain	First Draw	<0.4
1251-107-FD	Warren Hills - 001936F-Across from 302	Bottle Filler	First Draw	<0.4
1251-108-FD	Warren Hills - 001937-Across from Room 302	Sink Tap	First Draw	<0.4
1251-109-FD	Warren Hills - 001938-Across from Room 302	Drinking Fountain	First Draw	<0.4
1251-110-FD	Warren Hills - 001940-Room 10D	Sink Tap	First Draw	<0.4
1251-111-FD	Warren Hills - 001939-Room 10D	Bubbler	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-112-FD	Warren Hills - 001934-Library	Drinking Fountain	First Draw	<0.4
1251-113-FD	Warren Hills - 001935-Library Restroom	Sink Tap	First Draw	<0.4
1251-114-FD	Warren Hills - 001933-AV Storage	Sink Tap	First Draw	<0.4
1251-115-FD	Warren Hills - 001931-Room 19A	Sink Tap	First Draw	0.7
1251-116-FD	Warren Hills - 001932-Room 19A	Bubbler	First Draw	<0.4
1251-117-FD	Warren Hills - 002230-Kitchen	Ice Machine	First Draw	0.6
1251-118-FD	Warren Hills - 002229-Kitchen	Pot Filler	First Draw	1

May 1, 2024 Water Sampling Results:

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
1251-67-FD	Warren Hills - 001941-Room 10-Left	Drinking Fountain	First Draw	<0.4
1251-68-FD	Warren Hills - 001941-Room 10-Right	Drinking Fountain	First Draw	<0.4

Photos of the sampling locations are provided in Appendix D. A diagram containing identifiers on the outlets tested is provided in Appendix E.

Short-Term Control Measures

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Take immediate steps to prevent use from the failed source(s).
- Shut-off problem outlets
- Post “Not for Drinking/Cooking” at Problem Outlets. If initial sample results from an outlet(s) exceed the remediation trigger level, but are not routinely used for human ingestion (e.g., handwashing), clear signage can be posted to notify people that the outlet is not to be used for drinking or cooking until the problem is resolved.
- Consider performing follow-up flush testing in order to attempt to identify what component within the system is the source of the elevated lead concentration. This testing will assist to pinpoint where lead is getting into drinking water (i.e., fixtures versus interior plumbing) so that appropriate corrective measures can be taken.
- Shut-off or disconnection of problem outlets can provide a permanent solution. If the outlet is frequently used, this likely is not a practical long-term solution.
- Provide point-of-use (POU) filters at problem taps. Filters need routine maintenance (e.g., cartridge filter units need to be replaced periodically) to remain effective.

Permanent Control Measures

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Replacement of Problem Outlets and any identified upstream plumbing components (e.g., valves, leaded solder) to permanently address the problem. EPA's revised March 2015 guidance, How to Identify Lead-Free Certification Marks for Drinking Water System & Plumbing Products, can be a useful resource selecting leadfree plumbing.
- Provide point-of-use filters (POU) at problem taps as a long-term or permanent control measure. When doing this, facilities should be sure to create maintenance schedules and identify a point of contact to be in charge of making sure they are properly maintained.
- Reconfigure Plumbing. Ongoing renovation of school or childcare buildings may provide an opportunity to modify the plumbing system to redirect water supplied for drinking or cooking to bypass sources of lead contamination. Before undertaking such an alternative, be certain that you have properly identified all of the sources of lead contamination in drinking water.
- Remove and replace any drinking water coolers or drinking water outlets that the United States Environmental Protection Agency has determined are not lead-free under the federal Lead Contamination Control Act of 1988, as amended; except the school shall not be required to replace those drinking water outlets or water coolers that tested in accordance with state regulations and have been determined to be dispensing drinking water with a lead concentration less than five (5) part per billion (ppb); however, such drinking water outlet or water cooler shall be subject to all testing requirements and shall not be excluded from testing under subsection 10 of the Missouri Senate Bills Nos. 681 & 662, Section 160.077.
- Consider filtration of incoming water at the point of entry (POE) to the building.

Required Communication

- Contact staff and parents via written notification within seven (7) business days after receiving the test result.
- The notification shall include at least:
- The test results and a summary that explains such results;
- A description of any remedial steps taken; and
- A description of general health effects of lead contamination and community specific resources; and
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.
- Submit such annual testing results to the Missouri Department of Health and Senior Services (DHSS).
- Before August 1, 2024, or the first day on which students will be present in the building, whichever is later, and annually thereafter, each school shall conduct testing for lead by first-draw and follow-up flush samples of a random sampling of at least twenty-five percent (25%) of remediated drinking water outlets until all remediated sources have been tested as recommended by the 2018 version of the United States Environmental Protection Agency's "Training, Testing, and Taking Action" program. The testing shall be conducted and the results analyzed for both types of tests by an entity or entities approved by the department.
- Any measures taken to remediate any elevated lead levels identified must be recorded and documented.

General Recommendations

- Retesting of all potential cooking and drinking water sources is required five (5) years from previous testing completed.
- If the condition changes or significant alterations to existing plumbing is undertaken, consider performing additional lead in drinking water sampling.
- Ensure that the plumbing system is not used as an electrical ground.
- If equipment is added that could affect water pH, alkalinity, or hardness, consider performing lead in drinking water sampling.

Any work resulting from this report should be conducted in accordance with the EPA Safe Drinking Water Act, Missouri SB 681 & 662, HUD Lead Regulations 24 CFR 35, EPA Lead Regulations 40 CFR 745, and Consumer Product Safety Commission document #5056.

If you have any questions concerning this report, please contact me at 816-678-7894.

Sincerely,



Jeff Hurst
Axiom Service Professionals LLC
jeffh@axiomservicepros.com

Limitations Drinking Water Testing

The presence or absence of lead and copper (if collected) in drinking water applies only to the test locations on the date of the field visit and it should be understood that conditions may change due to deterioration, pH, alkalinity, hardness, use levels, or maintenance. The results noted within this report were accurate at the time of the evaluation and in no way reflect the conditions at the property before or after the date of the evaluation. No other environmental concerns or conditions were addressed during this evaluation.

Appendix A
Certifications

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Bradly A. Young

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Inspector
Category of License

Issuance Date:	**10/4/2023**
Expiration Date:	**10/4/2025**
License Number:	**211004-300006201**

Paula F. Nickelson
Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey A. Hurst

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **8/1/2022**
Expiration Date: **8/1/2024**
License Number: **000801-200166567**



Paula F. Nickelson
Acting Director
t of Health and Senior Services

son City, MO 65102

Appendix B
EPA Listed Lead Containing Drinking Fountains

Table C-1
Water Coolers With Other Lead Components

EBCO Manufacturing

- All pressure bubbler water coolers with shipping dates from 1962 through 1977 have a bubbler valve containing lead. The units contain a single, 50-50 tin-lead solder joint on the bubbler valve. Model numbers for coolers in this category are not available.

- The following models of pressure bubbler coolers produced from 1978 through 1981 contain one 50-50 tin-lead solder joint each.

CP3	DP15W	DPM8	7P	13P	DPM8H	DP15M	DP3R	DP8A
DP16M	DP5S	C10E	PX-10	DP7S	DP13SM	DP7M	DP7MH	DP7WD
WTC10	DP13M-60	DP14M	CP10-50	CP5	CP5M	DP15MW	DP3R	DP14S
DP20-50	DP7SM	DP10X	DP13A	DP13A-50	EP10F	DP5M	DP10F	CP3H
CP3-50	DP13M	DP3RH	DP5F	CP3M	EP5F	13PL	DP8AH	DP13S
CP10	DP20	DP12N	DP7WM	DP14A-50/60				

Halsey Taylor

- Lead solder was used in these models of water coolers manufactured between 1978 and the last week of 1987:

WMA-1	SCWT/SCWT-A	SWA-1	DC/DHC-1
S3/5/10D	BFC-4F/7F/4FS/7FS	S300/500/100D	

- The following coolers manufactured for Haws Drinking Faucet Company (Haws) by Halsey Taylor from November 1984 through December 18, 1987 are not lead-free because they contain 2 tin-lead solder joints. The model designations for these units are as follows:

HC8WT	HC14F	HC6W	HWC7D	HC8WTH	HC14FH	HC8W	HC2F	HC14WT
HC14FL	HC14W	HC2FH	HC14WTH	HC8FL	HC4F	HC5F	HC14WL	HCBF7D
HC4FH	HC10F	HC16WT	HCBF7HO	HC8F	HC8FH	HC4W	HWC7	

Table C-2
Halsey Taylor Water Coolers With Lead-Lined Tanks

- The following six model numbers have one or more units in the model series with lead-lined tanks:

WM8A WT8A GC10ACR GC10A GC5A RWM13A

- The following models and serial numbers contain lead-lined tanks:

WM14A Serial No. 843034	WM14A Serial No. 843006	WT11A Serial No. 222650
WT21A Serial No. 64309550	WT21A Serial No. 64309542	LL14A Serial No. 64346908

PO Box 47166 Kansas City, MO 64188 • 816-678-7894 • www.axiomservicepros.com

Appendix C
Laboratory Analytical Report

MICROBAC®

Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HC0133

AXIOM Service Professionals

Jeff Hurst
PO Box 47166
Kansas City, MO 64188

Project Name: 1251 Camille Street

Project / PO Number: 1251 Camille Street
Received: 03/22/2024
Reported: 04/09/2024

Analytical Testing Parameters

Client Sample ID: 1251-1-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-01
Collected By: Bradley Young
Collection Date: 03/20/2024 0:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1643	RVV

Client Sample ID: 1251-2-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-02
Collected By: Bradley Young
Collection Date: 03/20/2024 0:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1646	RVV

Client Sample ID: 1251-3-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-03
Collected By: Bradley Young
Collection Date: 03/20/2024 0:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1648	RVV

Client Sample ID: 1251-4-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-04
Collected By: Bradley Young
Collection Date: 03/20/2024 0:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1651	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-5-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-05
Collected By: Bradley Young
Collection Date: 03/20/2024 0:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1654	RVV

Client Sample ID: 1251-6-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-06
Collected By: Bradley Young
Collection Date: 03/20/2024 0:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1657	RVV

Client Sample ID: 1251-7-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-07
Collected By: Bradley Young
Collection Date: 03/20/2024 0:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1700	RVV

Client Sample ID: 1251-8-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-08
Collected By: Bradley Young
Collection Date: 03/20/2024 0:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1703	RVV

Client Sample ID: 1251-9-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-09
Collected By: Bradley Young
Collection Date: 03/20/2024 0:33

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1706	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-10-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-10
Collected By: Bradley Young
Collection Date: 03/20/2024 0:33

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1715	RVV

Client Sample ID: 1251-11-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-11
Collected By: Bradley Young
Collection Date: 03/20/2024 0:33

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1718	RVV

Client Sample ID: 1251-12-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-12
Collected By: Bradley Young
Collection Date: 03/20/2024 0:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1721	RVV

Client Sample ID: 1251-13-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-13
Collected By: Bradley Young
Collection Date: 03/20/2024 0:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1724	RVV

Client Sample ID: 1251-14-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-14
Collected By: Bradley Young
Collection Date: 03/20/2024 0:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1727	RVV

Client Sample ID: 1251-15-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-15
Collected By: Bradley Young
Collection Date: 03/20/2024 0:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1730	RVV

Client Sample ID: 1251-16-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-16
Collected By: Bradley Young
Collection Date: 03/20/2024 0:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1733	RVV

Client Sample ID: 1251-17-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-17
Collected By: Bradley Young
Collection Date: 03/20/2024 0:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1736	RVV

Client Sample ID: 1251-18-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-18
Collected By: Bradley Young
Collection Date: 03/20/2024 0:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1739	RVV

Client Sample ID: 1251-19-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-19
Collected By: Bradley Young
Collection Date: 03/20/2024 0:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 1742	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-20-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-20
Collected By: Bradley Young
Collection Date: 03/20/2024 0:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1757	RVV

Client Sample ID: 1251-21-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-21
Collected By: Bradley Young
Collection Date: 03/20/2024 0:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 1806	RVV

Client Sample ID: 1251-22-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-22
Collected By: Bradley Young
Collection Date: 03/20/2024 0:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1809	RVV

Client Sample ID: 1251-23-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-23
Collected By: Bradley Young
Collection Date: 03/20/2024 0:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**3.5**	0.4	ppb	2		04/05/24 0936	04/05/24 1812	RVV

Client Sample ID: 1251-24-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-24
Collected By: Bradley Young
Collection Date: 03/20/2024 0:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1815	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-25-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-25
Collected By: Bradley Young
Collection Date: 03/20/2024 0:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1818	RVV

Client Sample ID: 1251-26-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-26
Collected By: Bradley Young
Collection Date: 03/20/2024 0:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.2**	0.4	ppb	2		04/05/24 0936	04/05/24 1827	RVV

Client Sample ID: 1251-27-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-27
Collected By: Bradley Young
Collection Date: 03/20/2024 0:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.5**	0.4	ppb	2		04/05/24 0936	04/05/24 1830	RVV

Client Sample ID: 1251-28-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-28
Collected By: Bradley Young
Collection Date: 03/20/2024 0:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.9**	0.4	ppb	2		04/05/24 0936	04/05/24 1833	RVV

Client Sample ID: 1251-29-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-29
Collected By: Bradley Young
Collection Date: 03/20/2024 0:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1836	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-30-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-30
Collected By: Bradley Young
Collection Date: 03/20/2024 0:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.5**	0.4	ppb	2		04/05/24 0936	04/05/24 1839	RVV

Client Sample ID: 1251-31-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-31
Collected By: Bradley Young
Collection Date: 03/20/2024 0:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1842	RVV

Client Sample ID: 1251-32-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-32
Collected By: Bradley Young
Collection Date: 03/20/2024 0:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1845	RVV

Client Sample ID: 1251-33-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-33
Collected By: Bradley Young
Collection Date: 03/20/2024 0:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1848	RVV

Client Sample ID: 1251-34-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-34
Collected By: Bradley Young
Collection Date: 03/20/2024 0:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1851	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-35-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-35
Collected By: Bradley Young
Collection Date: 03/20/2024 0:43

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1854	RVV

Client Sample ID: 1251-36-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-36
Collected By: Bradley Young
Collection Date: 03/20/2024 0:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1903	RVV

Client Sample ID: 1251-37-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-37
Collected By: Bradley Young
Collection Date: 03/20/2024 0:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**6.0**	0.4	ppb	2		04/05/24 0936	04/05/24 1906	RVV

Client Sample ID: 1251-38-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-38
Collected By: Bradley Young
Collection Date: 03/20/2024 0:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1909	RVV

Client Sample ID: 1251-39-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-39
Collected By: Bradley Young
Collection Date: 03/20/2024 0:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1912	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-40-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-40
Collected By: Bradley Young
Collection Date: 03/20/2024 0:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1921	RVV

Client Sample ID: 1251-41-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-41
Collected By: Bradley Young
Collection Date: 03/20/2024 0:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1930	RVV

Client Sample ID: 1251-42-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-42
Collected By: Bradley Young
Collection Date: 03/20/2024 0:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1938	RVV

Client Sample ID: 1251-43-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-43
Collected By: Bradley Young
Collection Date: 03/20/2024 0:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1941	RVV

Client Sample ID: 1251-44-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-44
Collected By: Bradley Young
Collection Date: 03/20/2024 0:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1944	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-45-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-45
Collected By: Bradley Young
Collection Date: 03/20/2024 0:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1947	RVV

Client Sample ID: 1251-46-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-46
Collected By: Bradley Young
Collection Date: 03/20/2024 0:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1950	RVV

Client Sample ID: 1251-47-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-47
Collected By: Bradley Young
Collection Date: 03/20/2024 0:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1953	RVV

Client Sample ID: 1251-48-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-48
Collected By: Bradley Young
Collection Date: 03/20/2024 0:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 1956	RVV

Client Sample ID: 1251-49-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-49
Collected By: Bradley Young
Collection Date: 03/20/2024 0:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.5**	0.4	ppb	2		04/05/24 0936	04/05/24 1959	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-50-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-50
Collected By: Bradley Young
Collection Date: 03/20/2024 0:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2002	RVV

Client Sample ID: 1251-51-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-51
Collected By: Bradley Young
Collection Date: 03/20/2024 0:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.6**	0.4	ppb	2		04/05/24 0936	04/05/24 2005	RVV

Client Sample ID: 1251-52-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-52
Collected By: Bradley Young
Collection Date: 03/20/2024 0:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2014	RVV

Client Sample ID: 1251-53-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-53
Collected By: Bradley Young
Collection Date: 03/20/2024 0:51

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.5**	0.4	ppb	2		04/05/24 0936	04/05/24 2017	RVV

Client Sample ID: 1251-54-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-54
Collected By: Bradley Young
Collection Date: 03/20/2024 0:51

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2020	RVV

Client Sample ID: 1251-55-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-55
Collected By: Bradley Young
Collection Date: 03/20/2024 0:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2023	RVV

Client Sample ID: 1251-56-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-56
Collected By: Bradley Young
Collection Date: 03/20/2024 0:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2026	RVV

Client Sample ID: 1251-57-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-57
Collected By: Bradley Young
Collection Date: 03/20/2024 0:53

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2029	RVV

Client Sample ID: 1251-58-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-58
Collected By: Bradley Young
Collection Date: 03/20/2024 0:53

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2032	RVV

Client Sample ID: 1251-59-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-59
Collected By: Bradley Young
Collection Date: 03/20/2024 0:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.1**	0.4	ppb	2		04/05/24 0936	04/05/24 2035	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-60-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-60
Collected By: Bradley Young
Collection Date: 03/20/2024 0:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2050	RVV

Client Sample ID: 1251-61-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-61
Collected By: Bradley Young
Collection Date: 03/20/2024 0:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2059	RVV

Client Sample ID: 1251-62-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-62
Collected By: Bradley Young
Collection Date: 03/20/2024 0:57

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.5**	0.4	ppb	2		04/05/24 0936	04/05/24 2102	RVV

Client Sample ID: 1251-63-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-63
Collected By: Bradley Young
Collection Date: 03/20/2024 0:57

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.3**	0.4	ppb	2		04/05/24 0936	04/05/24 2105	RVV

Client Sample ID: 1251-64-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-64
Collected By: Bradley Young
Collection Date: 03/20/2024 0:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2108	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-65-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-65
Collected By: Bradley Young
Collection Date: 03/20/2024 0:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2111	RVV

Client Sample ID: 1251-66-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-66
Collected By: Bradley Young
Collection Date: 03/20/2024 0:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2114	RVV

Client Sample ID: 1251-119-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-67
Collected By: Bradley Young
Collection Date: 03/20/2024 0:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.9**	0.4	ppb	2		04/05/24 0936	04/05/24 2117	RVV

Client Sample ID: 1251-120-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-68
Collected By: Bradley Young
Collection Date: 03/20/2024 0:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2126	RVV

Client Sample ID: 1251-69-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-69
Collected By: Bradley Young
Collection Date: 03/20/2024 1:00

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2129	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-70-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-70
Collected By: Bradley Young
Collection Date: 03/20/2024 1:00

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.6**	0.4	ppb	2		04/05/24 0936	04/05/24 2132	RVV

Client Sample ID: 1251-71-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-71
Collected By: Bradley Young
Collection Date: 03/20/2024 1:01

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.5**	0.4	ppb	2		04/05/24 0936	04/05/24 2135	RVV

Client Sample ID: 1251-72-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-72
Collected By: Bradley Young
Collection Date: 03/20/2024 1:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.7**	0.4	ppb	2		04/05/24 0936	04/05/24 2138	RVV

Client Sample ID: 1251-73-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-73
Collected By: Bradley Young
Collection Date: 03/20/2024 1:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2141	RVV

Client Sample ID: 1251-74-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-74
Collected By: Bradley Young
Collection Date: 03/20/2024 1:03

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.4**	0.4	ppb	2		04/05/24 0936	04/05/24 2144	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-75-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-75
Collected By: Bradley Young
Collection Date: 03/20/2024 1:03

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2148	RVV

Client Sample ID: 1251-76-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-76
Collected By: Bradley Young
Collection Date: 03/20/2024 1:03

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**14.2**	0.4	ppb	2		04/05/24 0936	04/05/24 2151	RVV

Client Sample ID: 1251-77-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-77
Collected By: Bradley Young
Collection Date: 03/20/2024 1:03

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2154	RVV

Client Sample ID: 1251-78-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-78
Collected By: Bradley Young
Collection Date: 03/20/2024 1:04

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2202	RVV

Client Sample ID: 1251-79-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-79
Collected By: Bradley Young
Collection Date: 03/20/2024 1:04

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2205	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-80-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-80
Collected By: Bradley Young
Collection Date: 03/20/2024 1:05

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2215	RVV

Client Sample ID: 1251-81-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-81
Collected By: Bradley Young
Collection Date: 03/20/2024 1:05

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2224	RVV

Client Sample ID: 1251-82-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-82
Collected By: Bradley Young
Collection Date: 03/20/2024 1:05

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2227	RVV

Client Sample ID: 1251-83-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-83
Collected By: Bradley Young
Collection Date: 03/20/2024 1:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2230	RVV

Client Sample ID: 1251-84-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-84
Collected By: Bradley Young
Collection Date: 03/20/2024 1:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2239	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-85-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-85
Collected By: Bradley Young
Collection Date: 03/20/2024 1:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2242	RVV

Client Sample ID: 1251-86-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-86
Collected By: Bradley Young
Collection Date: 03/20/2024 1:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 2245	RVV

Client Sample ID: 1251-87-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-87
Collected By: Bradley Young
Collection Date: 03/20/2024 1:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2248	RVV

Client Sample ID: 1251-88-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-88
Collected By: Bradley Young
Collection Date: 03/20/2024 1:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2251	RVV

Client Sample ID: 1251-89-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-89
Collected By: Bradley Young
Collection Date: 03/20/2024 1:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2254	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-90-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-90
Collected By: Bradley Young
Collection Date: 03/20/2024 1:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2257	RVV

Client Sample ID: 1251-91-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-91
Collected By: Bradley Young
Collection Date: 03/20/2024 1:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**2.2**	0.4	ppb	2		04/05/24 0936	04/05/24 2300	RVV

Client Sample ID: 1251-92-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-92
Collected By: Bradley Young
Collection Date: 03/20/2024 1:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2303	RVV

Client Sample ID: 1251-93-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-93
Collected By: Bradley Young
Collection Date: 03/20/2024 1:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 2306	RVV

Client Sample ID: 1251-94-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-94
Collected By: Bradley Young
Collection Date: 03/20/2024 1:12

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2315	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-95-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-95
Collected By: Bradley Young
Collection Date: 03/20/2024 1:12

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.6**	0.4	ppb	2		04/05/24 0936	04/05/24 2318	RVV

Client Sample ID: 1251-96-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-96
Collected By: Bradley Young
Collection Date: 03/20/2024 1:12

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2321	RVV

Client Sample ID: 1251-97-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-97
Collected By: Bradley Young
Collection Date: 03/20/2024 1:13

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 2324	RVV

Client Sample ID: 1251-98-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-98
Collected By: Bradley Young
Collection Date: 03/20/2024 1:13

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2327	RVV

Client Sample ID: 1251-99-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-99
Collected By: Bradley Young
Collection Date: 03/20/2024 1:13

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.9**	0.4	ppb	2		04/05/24 0936	04/05/24 2330	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID: 1251-100-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AA
Collected By: Bradley Young
Collection Date: 03/20/2024 1:14

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.6**	0.4	ppb	2		04/05/24 0936	04/05/24 2339	RVV

Client Sample ID: 1251-101-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AB
Collected By: Bradley Young
Collection Date: 03/20/2024 1:14

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2353	RVV

Client Sample ID: 1251-102-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AC
Collected By: Bradley Young
Collection Date: 03/20/2024 1:14

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.4**	0.4	ppb	2		04/05/24 0936	04/05/24 2356	RVV

Client Sample ID: 1251-103-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AD
Collected By: Bradley Young
Collection Date: 03/20/2024 1:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/05/24 2359	RVV

Client Sample ID: 1251-104-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AE
Collected By: Bradley Young
Collection Date: 03/20/2024 1:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0002	RVV

Client Sample ID: 1251-105-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AF
Collected By: Bradley Young
Collection Date: 03/20/2024 1:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0005	RVV

Client Sample ID: 1251-106-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AG
Collected By: Bradley Young
Collection Date: 03/20/2024 1:17

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0008	RVV

Client Sample ID: 1251-107-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AH
Collected By: Bradley Young
Collection Date: 03/20/2024 1:17

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0011	RVV

Client Sample ID: 1251-108-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AI
Collected By: Bradley Young
Collection Date: 03/20/2024 1:17

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0014	RVV

Client Sample ID: 1251-109-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AJ
Collected By: Bradley Young
Collection Date: 03/20/2024 1:17

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0017	RVV

CERTIFICATE OF ANALYSIS

3HC0133

Client Sample ID:	1251-110-FD		
Sample Matrix:	Drink Wtr	**Collected By:**	Bradley Young
Lab Sample ID:	3HC0133-AK	**Collection Date:**	03/20/2024 1:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0026	RVV

Client Sample ID:	1251-111-FD		
Sample Matrix:	Drink Wtr	**Collected By:**	Bradley Young
Lab Sample ID:	3HC0133-AL	**Collection Date:**	03/20/2024 1:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0029	RVV

Client Sample ID:	1251-112-FD		
Sample Matrix:	Drink Wtr	**Collected By:**	Bradley Young
Lab Sample ID:	3HC0133-AM	**Collection Date:**	03/20/2024 1:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0032	RVV

Client Sample ID:	1251-113-FD		
Sample Matrix:	Drink Wtr	**Collected By:**	Bradley Young
Lab Sample ID:	3HC0133-AN	**Collection Date:**	03/20/2024 1:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0035	RVV

Client Sample ID:	1251-114-FD		
Sample Matrix:	Drink Wtr	**Collected By:**	Bradley Young
Lab Sample ID:	3HC0133-AO	**Collection Date:**	03/20/2024 1:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0038	RVV

Client Sample ID: 1251-115-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AP
Collected By: Bradley Young
Collection Date: 03/20/2024 1:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.7**	0.4	ppb	2		04/05/24 0936	04/06/24 0041	RVV

Client Sample ID: 1251-116-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AQ
Collected By: Bradley Young
Collection Date: 03/20/2024 1:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		04/05/24 0936	04/06/24 0044	RVV

Client Sample ID: 1251-117-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AR
Collected By: Bradley Young
Collection Date: 03/20/2024 0:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**0.6**	0.4	ppb	2		04/05/24 0936	04/06/24 0047	RVV

Client Sample ID: 1251-118-FD
Sample Matrix: Drink Wtr
Lab Sample ID: 3HC0133-AS
Collected By: Bradley Young
Collection Date: 03/20/2024 0:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	**1.0**	0.4	ppb	2		04/05/24 0936	04/06/24 0050	RVV

Definitions

RL: Reporting Limit

Report Comments

Reviewed and Approved By:

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Victoria Bruck
Field Technician II
04/09/24 15:45

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:	Brady Young	NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:	WARREN HILLS	CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	LAB USE ONLY: Sample #
														Wk Order #:	3HC0133
														Short Hold:	
														Rush:	
														Temp: oC	19.7
1251-1-FD	3/20/2024	00:31	Warren Hills - Sink Tap - 001720-Conference 1B	1	Wt	Grab	X								01
1251-2-FD	3/20/2024	00:31	Warren Hills - Sink Tap - 001717-Nurse Office	1	Wt	Grab	X								02
1251-3-FD	3/20/2024	00:31	Warren Hills - Sink Tap - 002519-Nurse Office-Bathroom	1	Wt	Grab	X								03
1251-4-FD	3/20/2024	00:31	Warren Hills - Sink Tap - 001719-Staff Bathroom by Nurse Office	1	Wt	Grab	X								04
1251-5-FD	3/20/2024	00:32	Warren Hills - Sink Tap - 001479-Art Room-	1	Wt	Grab	X								05
1251-6-FD	3/20/2024	00:32	Warren Hills - Sink Tap - 001712-Art Room-	1	Wt	Grab	X								06
1251-7-FD	3/20/2024	00:32	Warren Hills - Sink Tap - 001713-Art Room-	1	Wt	Grab	X								07

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
				3/22/24		
	Time:			Time:		
				10:30		

3 H C 0 1 3 3

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	LAB USE ONLY: Sample #
														Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
1251-8-FD	3/20/2024	00:32	Warren Hills - Sink Tap - 001714-Art Room-	1	Wt	Grab	X								08
1251-9-FD	3/20/2024	00:33	Warren Hills - Sink Tap - 001478-Room 4	1	Wt	Grab	X								09
1251-10-FD	3/20/2024	00:33	Warren Hills - Sink Tap - 001474-Boys Bathroom by 4-Right	1	Wt	Grab	X								10
1251-11-FD	3/20/2024	00:33	Warren Hills - Sink Tap - 002520-Boys Bathroom by 4-Right	1	Wt	Grab	X								11
1251-12-FD	3/20/2024	00:34	Warren Hills - Sink Tap - 001476-Girls Bathroom by Room 4-Left	1	Wt	Grab	X								12
1251-13-FD	3/20/2024	00:34	Warren Hills - Sink Tap - 001477-Girls Bathroom by 4-Right	1	Wt	Grab	X								13
1251-14-FD	3/20/2024	00:34	Warren Hills - Drinking Fountain - 001716-Hallway by Gym-Left	1	Wt	Grab	X								14

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC01333

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-15-FD	3/20/2024	00:34	Warren Hills - Drinking Fountain - 001716-Hallway by Gym-Right	1	Wt	Grab	X								15
1251-16-FD	3/20/2024	00:35	Warren Hills - Drinking Fountain - 001715-Gym-Left	1	Wt	Grab	X								16
1251-17-FD	3/20/2024	00:35	Warren Hills - Drinking Fountain - 001715-Gym-	1	Wt	Grab	X								17
1251-18-FD	3/20/2024	00:35	Warren Hills - Bottle Filler - 001715F-Hallway by Gym-	1	Wt	Grab	X								18
1251-19-FD	3/20/2024	00:37	Warren Hills - Sink Tap - 004669-Kitchen-3 Bay Sink-	1	Wt	Grab	X								19
1251-20-FD	3/20/2024	00:37	Warren Hills - Sink Tap - 004670-Kitchen-3 Bay Sink-	1	Wt	Grab	X								20
1251-21-FD	3/20/2024	00:37	Warren Hills - Sink Tap - 004651-Kitchen-3 Bay Sink	1	Wt	Grab	X								21

LAB USE ONLY
Wk Order #:
Short Hold:
Rush:
Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-22-FD	3/20/2024	00:37	Warren Hills - Sink Tap - 004652-Kitchen-Dishwasher Room	1	Wt	Grab	X								22
1251-23-FD	3/20/2024	00:38	Warren Hills - Sink Tap - 004653-Kitchen-Dishwasher Room	1	Wt	Grab	X								23
1251-24-FD	3/20/2024	00:38	Warren Hills - Sink Tap - 004654-Kitchen-Dishwasher Room	1	Wt	Grab	X								24
1251-25-FD	3/20/2024	00:38	Warren Hills - Sink Tap - 004662-Kitchen-Staff Bathroom	1	Wt	Grab	X								25
1251-26-FD	3/20/2024	00:39	Warren Hills - Sink Tap - 004663-Kitchen-Outside Freezer	1	Wt	Grab	X								26
1251-27-FD	3/20/2024	00:39	Warren Hills - Sink Tap - 004664-Kitchen-Outside Freezer	1	Wt	Grab	X								27
1251-28-FD	3/20/2024	00:39	Warren Hills - Sink Tap - 004665-Kitchen-Serving Line Faucet	1	Wt	Grab	X								28

LAB USE ONLY: Wk Order #: ; Short Hold: ; Rush: ; Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-29-FD	3/20/2024	00:40	Warren Hills - Sink Tap - 004666-Kitchen-Outside Office	1	Wt	Grab	X								29
1251-30-FD	3/20/2024	00:40	Warren Hills - Sink Tap - 004667-Kitchen-Outside Office	1	Wt	Grab	X								30
1251-31-FD	3/20/2024	00:40	Warren Hills - Sink Tap - 004668-Kitchen-Outside Office	1	Wt	Grab	X								31
1251-32-FD	3/20/2024	00:41	Warren Hills - Sink Tap - 004661-Kitchen-Handwashing by Bathroom	1	Wt	Grab	X								32
1251-33-FD	3/20/2024	00:43	Warren Hills - Drinking Fountain - 000961-Next to Room 8-Girls	1	Wt	Grab	X								33
1251-34-FD	3/20/2024	00:43	Warren Hills - Drinking Fountain - 000963-Next to Room 8	1	Wt	Grab	X								34
1251-35-FD	3/20/2024	00:43	Warren Hills - Bottle Filler - 000963-Next to Room 8-Boys	1	Wt	Grab	X								35

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___ 3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X 835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___ 205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:	REPORT TO:	BILL TO:
SAMPLER:	NAME: Jeff Hurst	NAME: Jeff Hurst
SITE NAME:	CO. NAME:	CO. NAME:
ADDRESS: 1251 Camille Street	ADRESS: PO Box 47166	ADDRESS: PO Box 47166
CITY/ST/ZIP: Liberty, Missouri 64068	CITY/ST/ZIP: Kansas City, Missouri 64188	CITY/ST/ZIP: Kansas City, Missouri 64188
PHONE: 816-522-2275	PHONE: 816-678-7894	PHONE: 816-678-7894
	EMAIL: jeffh@axiomservicepros.com	EMAIL: jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-36-FD	3/20/2024	00:44	Warren Hills - Sink Tap - 000962-Handwashing by Room 8	1	Wt	Grab	X								36
1251-37-FD	3/20/2024	00:44	Warren Hills - Sink Tap - 001952-Room 100	1	Wt	Grab	X								37
1251-38-FD	3/20/2024	00:44	Warren Hills - Sink Tap - 001951-Staff Bathroom by 100	1	Wt	Grab	X								38
1251-39-FD	3/20/2024	00:45	Warren Hills - Sink Tap - 001953-Room 104-Bathroom	1	Wt	Grab	X								39
1251-40-FD	3/20/2024	00:45	Warren Hills - Sink Tap - 001955-Room 104	1	Wt	Grab	X								40
1251-41-FD	3/20/2024	00:45	Warren Hills - Bubbler - 001954-Room 104	1	Wt	Grab	X								41
1251-42-FD	3/20/2024	00:46	Warren Hills - Sink Tap - 001956-Room 106-Bathroom	1	Wt	Grab	X								42

LAB USE ONLY: Wk Order #: ___ Short Hold: ___ Rush: ___ Temp: oC ___

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC01333

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-43-FD	3/20/2024	00:46	Warren Hills - Sink Tap - 001958-Room 106	1	Wt	Grab	X								43
1251-44-FD	3/20/2024	00:46	Warren Hills - Bubbler - 001957-Room 106	1	Wt	Grab	X								44
1251-45-FD	3/20/2024	00:47	Warren Hills - Sink Tap - 001959-Room 110-Bathroom	1	Wt	Grab	X								45
1251-46-FD	3/20/2024	00:47	Warren Hills - Sink Tap - 001961-Room 110	1	Wt	Grab	X								46
1251-47-FD	3/20/2024	00:47	Warren Hills - Bubbler - 001960-Room 110	1	Wt	Grab	X								47
1251-48-FD	3/20/2024	00:49	Warren Hills - Sink Tap - 001962-Room 112-Bathroom	1	Wt	Grab	X								48
1251-49-FD	3/20/2024	00:49	Warren Hills - Sink Tap - 001963-Room 112	1	Wt	Grab	X								49

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___ 3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X 835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___ 205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-50-FD	3/20/2024	00:49	Warren Hills - Bubbler - 001964-Room 112	1	Wt	Grab	X								50
1251-51-FD	3/20/2024	00:50	Warren Hills - Sink Tap - 001966-Room 113	1	Wt	Grab	X								51
1251-52-FD	3/20/2024	00:50	Warren Hills - Bubbler - 001965-Room 113	1	Wt	Grab	X								52
1251-53-FD	3/20/2024	00:51	Warren Hills - Sink Tap - 001968-Room 111	1	Wt	Grab	X								53
1251-54-FD	3/20/2024	00:51	Warren Hills - Bubbler - 001967-Room 111	1	Wt	Grab	X								54
1251-55-FD	3/20/2024	00:52	Warren Hills - Sink Tap - 001968-Room 107	1	Wt	Grab	X								55
1251-56-FD	3/20/2024	00:52	Warren Hills - Bubbler - 001970-Room 107	1	Wt	Grab	X								56

LAB USE ONLY:
Wk Order #:
Short Hold:
Rush:
Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC01333

AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	LAB USE ONLY: Sample #
1251-57-FD	3/20/2024	00:53	Warren Hills - Sink Tap - 001972-Room 105	1	Wt	Grab	X								57
1251-58-FD	3/20/2024	00:53	Warren Hills - Bubbler - 001971-Room 105	1	Wt	Grab	X								58
1251-59-FD	3/20/2024	00:55	Warren Hills - Sink Tap - 000965-Room 9	1	Wt	Grab	X								59
1251-60-FD	3/20/2024	00:55	Warren Hills - Bubbler - 000964-Room 9	1	Wt	Grab	X								60
1251-61-FD	3/20/2024	00:55	Warren Hills - Sink Tap - 000966-Room 9-Bathroom	1	Wt	Grab	X								61
1251-62-FD	3/20/2024	00:57	Warren Hills - Sink Tap - 001946-10l	1	Wt	Grab	X								62
1251-63-FD	3/20/2024	00:57	Warren Hills - Bubbler - 001947-Room 10l	1	Wt	Grab	X								63

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC01333

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-64-FD	3/20/2024	00:58	Warren Hills - Sink Tap - 002522-Student Services Staff Bathroom	1	Wt	Grab	X								64
1251-65-FD	3/20/2024	00:58	Warren Hills - Sink Tap - 001944-Room 10H	1	Wt	Grab	X								65
1251-66-FD	3/20/2024	00:58	Warren Hills - Bubbler - 001943-Room 10H	1	Wt	Grab	X								66
1251-119-FD	3/20/2024	00:59	Warren Hills - Sink Tap - 002228-10G	1	Wt	Grab	X								67
1251-120-FD	3/20/2024	00:59	Warren Hills - Sink Tap - 001942-10F	1	Wt	Grab	X								68
1251-69-FD	3/20/2024	01:00	Warren Hills - Sink Tap - 000967-Room 11-Bathroom	1	Wt	Grab	X								69
1251-70-FD	3/20/2024	01:00	Warren Hills - Sink Tap - 000969-Room 11	1	Wt	Grab	X								70

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___ 3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X 835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___ 205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-71-FD	3/20/2024	01:01	Warren Hills - Bubbler - 000968-Room 11	1	Wt	Grab	X								71
1251-72-FD	3/20/2024	01:02	Warren Hills - Sink Tap - 001994-Room 204	1	Wt	Grab	X								72
1251-73-FD	3/20/2024	01:02	Warren Hills - Bubbler - 001993-Room 204	1	Wt	Grab	X								73
1251-74-FD	3/20/2024	01:03	Warren Hills - Sink Tap - 001995-Room 206	1	Wt	Grab	X								74
1251-75-FD	3/20/2024	01:03	Warren Hills - Bubbler - 001996-Room 206	1	Wt	Grab	X								75
1251-76-FD	3/20/2024	01:03	Warren Hills - Sink Tap - 001998-Room 210	1	Wt	Grab	X								76
1251-77-FD	3/20/2024	01:03	Warren Hills - Bubbler - 001997-Room 210	1	Wt	Grab	X								77

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-78-FD	3/20/2024	01:04	Warren Hills - Sink Tap - 001999-Room 212	1	Wt	Grab	X								78
1251-79-FD	3/20/2024	01:04	Warren Hills - Bubbler - 002000-Room 212	1	Wt	Grab	X								79
1251-80-FD	3/20/2024	01:05	Warren Hills - Sink Tap - 001991-Room 213	1	Wt	Grab	X								80
1251-81-FD	3/20/2024	01:05	Warren Hills - Bubbler - 001992-Room 213	1	Wt	Grab	X								81
1251-82-FD	3/20/2024	01:05	Warren Hills - Sink Tap - 000990-Room 211	1	Wt	Grab	X								82
1251-83-FD	3/20/2024	01:06	Warren Hills - Bubbler - 000989-Room 211	1	Wt	Grab	X								83
1251-84-FD	3/20/2024	01:06	Warren Hills - Sink Tap - 000987-Room 207	1	Wt	Grab	X								84

LAB USE ONLY
Wk Order #:
Short Hold:
Rush:
Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC01333

AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___ 3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X 835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___ 205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-85-FD	3/20/2024	01:06	Warren Hills - Bubbler - 000988-Room 207	1	Wt	Grab	X								85
1251-86-FD	3/20/2024	01:07	Warren Hills - Sink Tap - 000986-Room 205	1	Wt	Grab	X								86
1251-87-FD	3/20/2024	01:07	Warren Hills - Bubbler - 000985-Room 205	1	Wt	Grab	X								87
1251-88-FD	3/20/2024	01:09	Warren Hills - Sink Tap - 001948-Handwashing by 14	1	Wt	Grab	X								88
1251-89-FD	3/20/2024	01:09	Warren Hills - Drinking Fountain - 001949-By Room 14-Girls	1	Wt	Grab	X								89
1251-90-FD	3/20/2024	01:09	Warren Hills - Drinking Fountain - 001950-By Room 14-Boys	1	Wt	Grab	X								90
1251-91-FD	3/20/2024	01:11	Warren Hills - Sink Tap - 000983-Room 304	1	Wt	Grab	X								91

LAB USE ONLY: Wk Order #: ___ Short Hold: ___ Rush: ___ Temp: oC ___

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-92-FD	3/20/2024	01:11	Warren Hills - Bubbler - 000984-Room 304	1	Wt	Grab	X								92
1251-93-FD	3/20/2024	01:11	Warren Hills - Sink Tap - 000978-Room 306	1	Wt	Grab	X								93
1251-94-FD	3/20/2024	01:12	Warren Hills - Bubbler - 000977-Room 306	1	Wt	Grab	X								94
1251-95-FD	3/20/2024	01:12	Warren Hills - Sink Tap - 000980-Room 310	1	Wt	Grab	X								95
1251-96-FD	3/20/2024	01:12	Warren Hills - Bubbler - 000979-Room 310	1	Wt	Grab	X								96
1251-97-FD	3/20/2024	01:13	Warren Hills - Sink Tap - 000981-Room 312	1	Wt	Grab	X								97
1251-98-FD	3/20/2024	01:13	Warren Hills - Bubbler - 000982-Room 312	1	Wt	Grab	X								98

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___ 3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X 835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___ 205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-99-FD	3/20/2024	01:13	Warren Hills - Sink Tap - 000970-Room 313	1	Wt	Grab	X								99
1251-100-FD	3/20/2024	01:14	Warren Hills - Sink Tap - 000976-Room 311	1	Wt	Grab	X								AA
1251-101-FD	3/20/2024	01:14	Warren Hills - Bubbler - 000975-Room 311	1	Wt	Grab	X								AB
1251-102-FD	3/20/2024	01:14	Warren Hills - Sink Tap - 000973-Room 307	1	Wt	Grab	X								AC
1251-103-FD	3/20/2024	01:15	Warren Hills - Bubbler - 000974-Room 307	1	Wt	Grab	X								AD
1251-104-FD	3/20/2024	01:15	Warren Hills - Sink Tap - 000972-Room 305	1	Wt	Grab	X								AE
1251-105-FD	3/20/2024	01:15	Warren Hills - Bubbler - 000971-Room 305	1	Wt	Grab	X								AF

LAB USE ONLY: Wk Order #: ___ Short Hold: ___ Rush: ___ Temp: oC ___

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___	600 E. 17th St. S Newton, IA 50208 Phone: 641-792-8451	___	3012 Ansborough Ave Waterloo, IA 50701 Phone: 319-235-4440	X	835 S St. Paul Kansas City, KS 66105 Phone: 913-321-7856	___	205 E Van Buren St Centerville, IA 52544 Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-106-FD	3/20/2024	01:17	Warren Hills - Drinking Fountain - 001936-Across from 302	1	Wt	Grab	X								AG
1251-107-FD	3/20/2024	01:17	Warren Hills - Bottle Filler - 001936F-Across from 302	1	Wt	Grab	X								AH
1251-108-FD	3/20/2024	01:17	Warren Hills - Sink Tap - 001937-Across from 302	1	Wt	Grab	X								AI
1251-109-FD	3/20/2024	01:17	Warren Hills - Drinking Fountain - 001938-Across from 302	1	Wt	Grab	X								AJ
1251-110-FD	3/20/2024	01:18	Warren Hills - Sink Tap - 001940-Room 10D	1	Wt	Grab	X								AK
1251-111-FD	3/20/2024	01:18	Warren Hills - Bubbler - 001939-Room 10D	1	Wt	Grab	X								AL
1251-112-FD	3/20/2024	01:19	Warren Hills - Drinking Fountain - 001934-Library	1	Wt	Grab	X								AM

LAB USE ONLY: Wk Order #: ___ Short Hold: ___ Rush: ___ Temp: oC ___

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:		NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	LAB USE ONLY: Sample #
1251-113-FD	3/20/2024	01:19	Warren Hills - Sink Tap - 001935-Library Bathroom	1	Wt	Grab	X								AN
1251-114-FD	3/20/2024	01:19	Warren Hills - Sink Tap - 001933-AV Storage	1	Wt	Grab	X								AO
1251-115-FD	3/20/2024	01:20	Warren Hills - Sink Tap - 001931-Room 19A	1	Wt	Grab	X								AP
1251-116-FD	3/20/2024	01:20	Warren Hills - Bubbler - 001932-Room 19A	1	Wt	Grab	X								AQ
1251-117-FD	3/20/2024	00:41	Warren Hills - Ice Machine - 002230-Kitchen	1	Wt	Grab	X								AR
1251-118-FD	3/20/2024	00:41	Warren Hills - Pot Filler - 002229-Kitchen	1	Wt	Grab	X								AS

LAB USE ONLY: Wk Order #: | Short Hold: | Rush: | Temp: oC

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:			Time:		

3HC0133

AXIOM Service Professionals

PM: Carolyn Jackson

MICROBAC®

Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HE0038

AXIOM Service Professionals

Jeff Hurst
PO Box 47166
Kansas City, MO 64188

Project Name: Warren Hills

Project / PO Number: Warren Hills
Received: 05/02/2024
Reported: 05/10/2024

Work Order Special Information

Young, Bradly
Warren Hills

Analytical Testing Parameters

Client Sample ID: 1251-67-FD
Sample Matrix: Drinking Water
Lab Sample ID: 3HE0038-01
Collected By: Young, Bradly
Collection Date: 05/01/2024 23:05

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		05/07/24 1516	05/09/24 0702	RVV

Client Sample ID: 1251-68-FD
Sample Matrix: Drinking Water
Lab Sample ID: 3HE0038-02
Collected By: Young, Bradly
Collection Date: 05/01/2024 23:05

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		05/07/24 1516	05/09/24 0708	RVV

Definitions

RL: Reporting Limit

Report Comments

Reviewed and Approved By:

Carolyn Jackson
Project Manager
carolyn.jackson@microbac.com
05/10/24 13:21

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Keystone LABORATORIES
A Microbac Company

600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X
835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:		REPORT TO:		BILL TO:	
SAMPLER:	Bradly Young	NAME:	Jeff Hurst	NAME:	Jeff Hurst
SITE NAME:		CO. NAME:		CO. NAME:	
ADDRESS:	1251 Camille Street	ADRESS:	PO Box 47166	ADDRESS:	PO Box 47166
CITY/ST/ZIP:	Liberty, Missouri 64068	CITY/ST/ZIP:	Kansas City, Missouri 64188	CITY/ST/ZIP:	Kansas City, Missouri 64188
PHONE:	816-522-2275	PHONE:	816-678-7894	PHONE:	816-678-7894
		EMAIL:	jeffh@axiomservicepros.com	EMAIL:	jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Lead							LAB USE ONLY: Sample Condition	Sample #
1251-67-FD	5/1/2024	23:05	Warren Hills - Drinking Fountain - 001941-Room 10-Left	1	Wt	Grab	X								3HE0038-01
1251-68-FD	5/1/2024	23:05	Warren Hills - Drinking Fountain - 001941-Room 10-Right	1	Wt	Grab	X								02

LAB USE ONLY
Wk Order #: 3HE0038
Short Hold:
Rush:
Temp: oC 20.0

3 H E 0 0 3 8
AXIOM Service Professionals
PM: Carolyn Jackson

Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquied by: (Signature)	Date:		Received by: (Signature)	Date:	05/02/24	
			Carolyn L Jackson			
	Time:			Time:	12:00	

Appendix D
Photo Log



3/20/2024 - 1251-1 - Warren Hills - 001720-Conference 1B



3/20/2024 - 1251-2 - Warren Hills - 001717-Nurse's Office



3/20/2024 - 1251-3 - Warren Hills - 002519-Nurse's Office-Restroom



3/20/2024 - 1251-4 - Warren Hills - 001719-Staff Restroom by Nurse's Office



3/20/2024 - 1251-5 - Warren Hills - 001479-Art Room



3/20/2024 - 1251-6 - Warren Hills - 001712-Art Room



3/20/2024 - 1251-7 - Warren Hills - 001713-Art Room



3/20/2024 - 1251-8 - Warren Hills - 001714-Art Room



3/20/2024 - 1251-9 - Warren Hills - 001478-Room 4



3/20/2024 - 1251-10 - Warren Hills - 001474-Boys Restroom by Room 4-Right



3/20/2024 - 1251-11 - Warren Hills - 002520-Boys Restroom by Room 4-Right



3/20/2024 - 1251-12 - Warren Hills - 001476-Girls Restroom by Room 4-Left



3/20/2024 - 1251-13 - Warren Hills - 001477-Girls Restroom by Room 4-Right



3/20/2024 - 1251-14 - Warren Hills - 001716-Hallway by Gym-Left



3/20/2024 - 1251-15 - Warren Hills - 001716-Hallway by Gym-Right




3/20/2024 - 1251-16 - Warren Hills - 001715-Gym-Left



3/20/2024 - 1251-17 - Warren Hills - 001715-Gym-Right



3/20/2024 - 1251-18 - Warren Hills - 001715F-Hallway by Gym




3/20/2024 - 1251-19 - Warren Hills - 004669-Kitchen-Three Bay Sink



3/20/2024 - 1251-20 - Warren Hills - 004670-Kitchen-Three Bay Sink



3/20/2024 - 1251-21 - Warren Hills - 004651-Kitchen-Three Bay Sink



3/20/2024 - 1251-22 - Warren Hills - 004652-Kitchen-Dishwasher Room



3/20/2024 - 1251-23 - Warren Hills - 004653-Kitchen-Dishwasher Room



3/20/2024 - 1251-24 - Warren Hills - 004654-Kitchen-Dishwasher Room



3/20/2024 - 1251-25 - Warren Hills - 004662-Kitchen-Staff Restroom



3/20/2024 - 1251-26 - Warren Hills - 004663-Kitchen-Outside Freezer



3/20/2024 - 1251-27 - Warren Hills - 004664-Kitchen-Outside Freezer



3/20/2024 - 1251-28 - Warren Hills - 004665-Kitchen-Serving Line Faucet



3/20/2024 - 1251-29 - Warren Hills - 004666-Kitchen-Outside Office



3/20/2024 - 1251-30 - Warren Hills - 004667-Kitchen-Outside Office



3/20/2024 - 1251-31 - Warren Hills - 004668-Kitchen-Outside Office



3/20/2024 - 1251-32 - Warren Hills - 004661-Kitchen-Handwashing by Restroom



3/20/2024 - 1251-33 - Warren Hills - 000961-Next to Room 8-Girls



3/20/2024 - 1251-34 - Warren Hills - 000963-Next to Room 8



3/20/2024 - 1251-35 - Warren Hills - 000963-Next to Room 8-Boys



3/20/2024 - 1251-36 - Warren Hills - 000962-Handwashing by Room 8



3/20/2024 - 1251-37 - Warren Hills - 001952-Room 100



3/20/2024 - 1251-38 - Warren Hills - 001951-Staff Restroom by 100



3/20/2024 - 1251-39 - Warren Hills - 001953-Room 104-Restroom



3/20/2024 - 1251-40 - Warren Hills - 001955-Room 104



3/20/2024 - 1251-41 - Warren Hills - 001954- Room 104



3/20/2024 - 1251-42 - Warren Hills - 001956- Room 106-Restroom



3/20/2024 - 1251-43 - Warren Hills - 001958- Room 106



3/20/2024 - 1251-44 - Warren Hills - 001957- Room 106



3/20/2024 - 1251-45 - Warren Hills - 001959-Room 110-Restroom




3/20/2024 - 1251-46 - Warren Hills - 001961-Room 110



3/20/2024 - 1251-47 - Warren Hills - 001960-Room 110



3/20/2024 - 1251-48 - Warren Hills - 001962-Room 112-Restroom



3/20/2024 - 1251-49 - Warren Hills - 001963- Room 112



3/20/2024 - 1251-50 - Warren Hills - 001964- Room 112



3/20/2024 - 1251-51 - Warren Hills - 001966- Room 113



3/20/2024 - 1251-52 - Warren Hills - 001965- Room 113



3/20/2024 - 1251-53 - Warren Hills - 001968-Room 111



3/20/2024 - 1251-54 - Warren Hills - 001967-Room 111



3/20/2024 - 1251-55 - Warren Hills - 001968-Room 107



3/20/2024 - 1251-56 - Warren Hills - 001970-Room 107



3/20/2024 - 1251-57 - Warren Hills - 001972-
Room 105



3/20/2024 - 1251-58 - Warren Hills - 001971-
Room 105



3/20/2024 - 1251-59 - Warren Hills - 000965-
Room 9



3/20/2024 - 1251-60 - Warren Hills - 000964-
Room 9



3/20/2024 - 1251-61 - Warren Hills - 000966-Room 9-Restroom



3/20/2024 - 1251-62 - Warren Hills - 001946-10I



3/20/2024 - 1251-63 - Warren Hills - 001947-Room 10I



3/20/2024 - 1251-64 - Warren Hills - 002522-Student Services Staff Restroom



3/20/2024 - 1251-65 - Warren Hills - 001944- Room 10H



3/20/2024 - 1251-66 - Warren Hills - 001943- Room 10H



3/20/2024 - 1251-119 - Warren Hills - 002228-10G



3/20/2024 - 1251-120 - Warren Hills - 001942-10F



5/1/2024 - 1251-67 - Warren Hills - 001941- Room 10-Left



5/1/2024 - 1251-68 - Warren Hills - 001941- Room 10-Right



3/20/2024 - 1251-69 - Warren Hills - 000967- Room 11-Restroom



3/20/2024 - 1251-70 - Warren Hills - 000969- Room 11



3/20/2024 - 1251-71 - Warren Hills - 000968- Room 11



3/20/2024 - 1251-72 - Warren Hills - 001994- Room 204



3/20/2024 - 1251-73 - Warren Hills - 001993- Room 204



3/20/2024 - 1251-74 - Warren Hills - 001995- Room 206



3/20/2024 - 1251-75 - Warren Hills - 001996- Room 206



3/20/2024 - 1251-76 - Warren Hills - 001998- Room 210



3/20/2024 - 1251-77 - Warren Hills - 001997- Room 210



3/20/2024 - 1251-78 - Warren Hills - 001999- Room 212




3/20/2024 - 1251-79 - Warren Hills - 002000- Room 212




3/20/2024 - 1251-80 - Warren Hills - 001991- Room 213



3/20/2024 - 1251-81 - Warren Hills - 001992- Room 213



3/20/2024 - 1251-82 - Warren Hills - 000990- Room 211



3/20/2024 - 1251-83 - Warren Hills - 000989- Room 211



3/20/2024 - 1251-84 - Warren Hills - 000987- Room 207



3/20/2024 - 1251-85 - Warren Hills - 000988- Room 207



3/20/2024 - 1251-86 - Warren Hills - 000986- Room 205



3/20/2024 - 1251-87 - Warren Hills - 000985-Room 205



3/20/2024 - 1251-88 - Warren Hills - 001948-Handwashing by Room 14



3/20/2024 - 1251-89 - Warren Hills - 001949-By Room 14-Girls



3/20/2024 - 1251-90 - Warren Hills - 001950-By Room 14-Boys



3/20/2024 - 1251-91 - Warren Hills - 000983- Room 304



3/20/2024 - 1251-92 - Warren Hills - 000984- Room 304



3/20/2024 - 1251-93 - Warren Hills - 000978- Room 306



3/20/2024 - 1251-94 - Warren Hills - 000977- Room 306



3/20/2024 - 1251-95 - Warren Hills - 000980- Room 310



3/20/2024 - 1251-96 - Warren Hills - 000979- Room 310



3/20/2024 - 1251-97 - Warren Hills - 000981- Room 312



3/20/2024 - 1251-98 - Warren Hills - 000982- Room 312



3/20/2024 - 1251-99 - Warren Hills - 000970- Room 313



3/20/2024 - 1251-100 - Warren Hills - 000976- Room 311



3/20/2024 - 1251-101 - Warren Hills - 000975- Room 311



3/20/2024 - 1251-102 - Warren Hills - 000973- Room 307



3/20/2024 - 1251-103 - Warren Hills - 000974- Room 307



3/20/2024 - 1251-104 - Warren Hills - 000972- Room 305



3/20/2024 - 1251-105 - Warren Hills - 000971- Room 305



3/20/2024 - 1251-106 - Warren Hills - 001936- Across from Room 302



3/20/2024 - 1251-107 - Warren Hills - 001936F- Across from 302



3/20/2024 - 1251-108 - Warren Hills - 001937- Across from Room 302



3/20/2024 - 1251-109 - Warren Hills - 001938- Across from Room 302



3/20/2024 - 1251-110 - Warren Hills - 001940- Room 10D



3/20/2024 - 1251-111 - Warren Hills - 001939-Room 10D



3/20/2024 - 1251-112 - Warren Hills - 001934-Library



3/20/2024 - 1251-113 - Warren Hills - 001935-Library Restroom



3/20/2024 - 1251-114 - Warren Hills - 001933-AV Storage



3/20/2024 - 1251-115 - Warren Hills - 001931- Room 19A



3/20/2024 - 1251-116 - Warren Hills - 001932- Room 19A




3/20/2024 - 1251-117 - Warren Hills - 002230- Kitchen



3/20/2024 - 1251-118 - Warren Hills - 002229- Kitchen

Appendix E
Source Identification Diagram

ASP was provided sample locations by
Liberty School District



Map Design by: Curt Laven

Last Updated: 06/17/2021