

Lead in Water Testing Results  
 South Washington County Schools  
**District Service Center – 7362 E Pt. Douglas Rd S, Cottage Grove, MN 55016**

On March 8<sup>th</sup>, 2024, the District Service Center’s drinking water was tested for the concentration of lead.

The following water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULT (ppb)</b>
Room A114	SINK	2.54
Room A130	SINK	< 1.00
Room A163	SINK	3.11
Room A180	FOUNTAIN	1.58
Hallway	BOTTLE FILLER	< 1.00
Hallway	FOUNTAIN	< 1.00

The following water sources tested above the action level of 5 parts-per-billion (ppb) for the concentration of lead. These sources will not be used for consumption without remediation and re-testing. Actions taken are listed below.

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULT</b>	<b>ACTION</b>
Room A173	SINK	5.14	Identified and labeled as handwashing sink only