

Lead in Water Testing Results
 South Washington County Schools
District Program Center/Alternative High School
8400 E Pt. Douglas Rd S, Cottage Grove, MN 55016

On March 8th, 2024, the District Program Center and Alternative High School's drinking water was tested for the concentration of lead.

The following water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Room 117	SINK	1.75
Room 118	SINK	< 1.00
Room 123	SINK (right)	< 1.00
Room 124	SINK	2.28
Room 125	SINK (left)	1.14
Room 128	SINK (right)	1.85
Room 130	SINK (left)	1.79
Room 132	SINK (right)	4.15
Hallway, outside 108	BOTTLE FILLER	< 1.00
Hallway, outside 108	FOUNTAIN (left)	< 1.00
Hallway, outside 108	FOUNTAIN (right)	< 1.00
Hallway, outside 126	FOUNTAIN (left)	< 1.00
Hallway, outside 126	FOUNTAIN (right)	1.05
Hallway, outside 132	FOUNTAIN (left)	< 1.00
Hallway, outside 132	FOUNTAIN (right)	< 1.00
Hallway, outside gym	FOUNTAIN (left)	< 1.00
Hallway, outside gym	FOUNTAIN (right)	< 1.00
Kitchen	SINK	4.93
Kitchen	SINK (middle)	3.75
Kitchen	SINK (middle)	3.03
Lobby	FOUNTAIN (left)	< 1.00
Lobby	FOUNTAIN (right)	< 1.00
DPC Nurse's Office	SINK	3.07
Senior Center	SINK	< 1.00
Senior Center Kitchen	SPRAYER	< 1.00
Senior Center Workroom	SINK	1.24
Staff Dining	SINK	3.47

The following water sources tested above the action level of 5 parts-per-billion (ppb) for the concentration of lead. These sources will not be used for consumption without remediation and re-testing. Actions taken are listed below.

LOCATION	SOURCE	RESULT	ACTION
Room 123	SINK (left)	6.69	Identified and labeled as handwashing sink only
Room 125	SINK (right)	6.97	Identified and labeled as handwashing sink only
Room 126	SINK (left)	9.31	Identified and labeled as handwashing sink only
Room 126	SINK (right)	6.61	Identified and labeled as handwashing sink only
Kitchen	SINK	12.4	Identified and labeled as handwashing sink only
AHS Nurse's Office	SINK	12.2	Identified and labeled as handwashing sink only
Senior Center Kitchen	SINK (left)	9.09	Identified and labeled as handwashing sink only
Senior Center Kitchen	SINK (right)	9.57	Identified and labeled as handwashing sink only