

Lead in Water Testing Results
 South Washington County Schools
Oltman Middle School – 6625 Goodview Ave S, Cottage Grove, MN 55016

On March 8th, 2024 Oltman Middle School’s drinking water was tested for the concentration of lead.

All water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Room 110B	SINK (left)	< 1.00
Room 110B	SINK (right)	< 1.00
Room 110B	SPRAYER (left)	2.75
Room 110B	SPRAYER (right)	3.43
Hallway, 2 nd floor south	BOTTLE FILLER	< 1.00
Hallway, 2 nd floor south	FOUNTAIN (left)	< 1.00
Hallway, 2 nd floor south	FOUNTAIN (right)	< 1.00
Hallway, 2 nd floor north	BOTTLE FILLER	< 1.00
Hallway, 2 nd floor north	FOUNTAIN (left)	< 1.00
Hallway, 2 nd floor north	FOUNTAIN (right)	< 1.00
Hallway, by M186	BOTTLE FILLER	< 1.00
Hallway, by M186	FOUNTAIN (left)	< 1.00
Hallway, by M186	FOUNTAIN (right)	< 1.00
Hallway, by M166	BOTTLE FILLER	< 1.00
Hallway, by M166	FOUNTAIN (left)	< 1.00
Hallway, by M166	FOUNTAIN (right)	< 1.00
Hallway, by 149	BOTTLE FILLER	< 1.00
Hallway, by 149	FOUNTAIN (left)	< 1.00
Hallway, by 149	FOUNTAIN (right)	< 1.00
Hallway, by 107	FOUNTAIN (left)	< 1.00
Hallway, by 107	FOUNTAIN (right)	< 1.00
Cafeteria	BOTTLE FILLER	< 1.00
Cafeteria	FOUNTAIN (left)	< 1.00
Cafeteria	FOUNTAIN (right)	< 1.00
Hallway, by kitchen	BOTTLE FILLER	< 1.00
Hallway, by kitchen	FOUNTAIN (left)	< 1.00
Hallway, by kitchen	FOUNTAIN (right)	< 1.00
Kitchen	SINK	< 1.00
Kitchen	SPRAYER	< 1.00
Nurse’s Office	SINK	< 1.00
Pool	BOTTLE FILLER	< 1.00
Pool	FOUNTAIN (left)	< 1.00

Pool	FOUNTAIN (right)	< 1.00
Staff Dining	SINK	< 1.00
Staff Workroom	SINK	< 1.00