

Lead in Water Testing Results
 South Washington County Schools
Woodbury Elementary School – 1251 School Drive, Woodbury, MN 55125

On March 5thth, 2024, Woodbury Elementary School’s drinking water was tested for the concentration of lead.

The following water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Room 103	SINK	4.60
Room 104	SINK	2.34
Room 105	SINK	< 1.00
Room 106	SINK	4.39
Room 107	SINK	4.03
Room 108	SINK	4.67
Room 110	SINK	3.16
Room 112	SINK	2.30
Room 114	SINK	2.57
Room 116	SINK	2.78
Room 118	SINK	1.97
Room 120	SINK	1.22
Room 122	SINK	< 1.00
Hallway, by 214	BOTTLE FILLER	< 1.00
Room 126	SINK	1.32
Room 127	SINK	4.85
Room 128	SINK	3.17
Room 207	SINK	4.27
Room 209	SINK	2.12
Room 210	SINK	1.02
Room 213	SINK	2.25
Room 214C	SINK	2.68
Room 220	SINK	3.67
Cafeteria	BOTTLE FILLER	< 1.00
Cafeteria	FOUNTAIN	< 1.00
Hallway, by 120	FOUNTAIN (left)	< 1.00
Hallway, by 214	FOUNTAIN	< 1.00
Hallway, by gym	BOTTLE FILLER	< 1.00
Hallway, by gym	FOUNTAIN	< 1.00
Kitchen	SINK	1.90
Kitchen	SPRAYER	2.81

Nurse	SINK	1.83
Staff	SINK	< 1.00

The following water sources tested above the action level of 5 parts-per-billion (ppb) for the concentration of lead. These sources will not be used for consumption without remediation and re-testing. Actions taken are listed below.

LOCATION	SOURCE	RESULT	ACTION
Room 101	SINK	17.7	Identified and labeled as handwashing sink only
Room 102	SINK	7.82	Identified and labeled as handwashing sink only
Room 109	SINK	5.25	Identified and labeled as handwashing sink only
Room 111	SINK	41.2	Identified and labeled as handwashing sink only
Room 202	SINK	41.1	Identified and labeled as handwashing sink only
Room 203	SINK	5.44	Identified and labeled as handwashing sink only
Room 204	SINK	10.5	Identified and labeled as handwashing sink only
Room 205	SINK	14.2	Identified and labeled as handwashing sink only
Room 206	SINK	11.8	Identified and labeled as handwashing sink only
Room 208	SINK	5.0	Identified and labeled as handwashing sink only
Room 211	SINK	10.2	Identified and labeled as handwashing sink only
Room 216	SINK	5.16	Identified and labeled as handwashing sink only
Room 218	SINK	11.1	Identified and labeled as handwashing sink only
Room 219	SINK	12.7	Identified and labeled as handwashing sink only
Room 221	SINK	7.49	Identified and labeled as handwashing sink only
Media Center Wrkrm	SINK	6.49	Identified and labeled as handwashing sink only