St. Helens School District

## Water Testing Results - Family Resource Center

Action Level is 15 parts per billion (ppb)

| Fixture Location/Description | Fixture ID # | Test Date | Test Result (ppb) | |
|---|---|---|---|---|
| P-4 Kitchen Sink Faucet | 19480504-001KF24A | 1/31/2024 | 2.99 | |
| P-4 Drinking Fountain | 19480504-002DW24A | 1/31/2024 | ND | |
| P-4 Bottle Filler | 19480504-003WB24A | 1/31/2024 | ND | |
| P-4 Women's RR Faucet | 19480504-004BF24A | 1/31/2024 | 2.91 | |
| P-4 Men's RR Faucet | 19480504-005BF24A | 1/31/2024 | 3.08 | |
| P-5 Women's RR Faucet | 19480503-001BF24A | 1/31/2024 | **36.2** | (temporarily removed from service) |
| P-5 Women's RR Faucet | 19480503-001BF24B | 5/3/2024 | **56.7** | (temporarily removed from service) |
| P-5 Women's RR Faucet | 19480503-001BF24C | 5/22/2024 | 9.04 | (post remediation) |
| P-5 Men's RR Faucet | 19480503-002BF24A | 1/31/2024 | 0.576 | |