

**Regulatory Compliance
245 Albany Avenue
Thornwood, New York 10594
(914) 439-6513**

**10 NYCRR Subpart 67-4
Testing and Water Management Plan
For
Lead In Drinking Water**

For

**Blind Brook-Rye UFSD
390 North Ridge Street
Rye Brook, NY 10573**

at

**High/Middle School
40 King Street
Rye Brook, NY 10573**

**Bruno M. Ponterio Ridge Street School
390 North Ridge Street
Rye Brook, NY 10573**

Project Number: BB.1083.23.IH

Date of Surveys:
October 17, 2023
October 18, 2023
October 19, 2023

Field Work performed by:
Ernest Coon, MS, RPIH, HEM
Russell Coonrod

Report Written by:
Ernest Coon, MS, RPIH, HEM




TABLE OF CONTENTS

1. SCOPE OF WORK	3
2. INTRODUCTION	3
3. RECOMMENDED/REQUIRED SAMPLING LOCATIONS	3
4. SAMPLING METHODOLOGY	5
5. SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION	6
6. RESPONSE AND CORRECTIVE ACTIONS	7
7. POST-REMEDATION TESTING	8
8. PUBLIC NOTIFICATION REQUIREMENTS	8
9. ELECTRONIC REPORTING IN HCS/HERDS	9
10. RECORDKEEPING REQUIREMENTS	9
11. BEST MANAGEMENT PRACTICES TO REDUCE LEAD IN DRINKING WATER	10
12. LEAD IN DRINKING WATER SURVEY FACT SHEET	11

Appendix

Appendix A	Tabulated Results
Appendix B	Laboratory Data Sheets
Appendix C	Remediation/ Corrective Actions

1.0 SCOPE OF WORK

Blind Brook-Rye UFSD retained Regulatory Compliance to test water fixtures in select areas identified by the district for lead content. The overall objective is to determine the lead content in drinking water in the district's buildings.

2.0 INTRODUCTION

Lead is a toxic metal that can be harmful when ingested (or inhaled), and young children are particularly sensitive to the effects of lead. Lead can get into drinking water by being present in the source water, or by interaction of the water with plumbing materials containing lead (through corrosion). Common sources of lead in drinking water include: solder, fluxes, pipes and pipefittings, fixtures, and sediments. Thus, it is possible that different water outlets in a given building could have dissimilar concentrations of lead. Lead in drinking water is regulated under the Safe Drinking Water Act (1974) as amended. The Lead Contamination Control Act (LCCA) amended the Safe Drinking Water Act and is aimed at identifying and reducing lead in drinking water in schools (and day care facilities). In April 1994, EPA prepared two guidance documents to assist municipalities in meeting the requirements of the LCCA. On September 6, 2016, the Department of Health DOH issued emergency regulations for the implementation of the new law, *Lead Testing in School Drinking Water*, the regulations became Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rule and Regulations of the State of New York. A revised 67-4 went into effect on December 22, 2022.

The following information provided in sections 3-11 are taken from 10 NYCRR Subpart 67-4 and the NYSDOH slide presentation "Lead Testing in School Drinking Water - Program Review and Updates Environmental Health Conference," from October 25, 2022.

3.0 RECOMMENDED/REQUIRED SAMPLING LOCATIONS

Outlets that should be sampled may be located anywhere on school property including external outlets (hose bibs) if the outlet may be used for drinking or cooking (including food preparation).

Samples must be collected at all outlets used or potentially used for drinking or cooking, including but not limited to:

- bubblers/drinking fountains
- classroom sinks
- classroom combination sinks and drinking fountains
- kitchen sinks
- kitchen kettle filler outlets
- bathroom sinks
- family and consumer sciences room sinks

- teachers' lounge sinks
- nurse's office sinks
- athletic field outlets and any other sink known to be or potentially used for consumption (e.g., coffeemaker or cups are nearby)

Applicable VS. Non-Applicable Outlets

Superintendents or their designees have the responsibility to identify which outlets on a school property meet the regulation requirements for sampling ("applicable outlets").

If a Superintendent or their designee determines that they have outlets that fall outside of the scope of the regulation (outlets not used or potentially used for drinking or cooking), the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes ("non- applicable outlets").

- Food washing sinks: Food washing faucets must be sampled as they are used for cooking (including food preparation) and potentially for drinking.
- Ice machines: The ice made in an ice machine should be sampled for lead.
- Combination bottle fill station and drinking fountain: A sample should be collected from both outlets. The Department recommends sampling the outlet that is most frequently used first.
- Hand washing outlets: In general, all hand washing outlets in a bathroom should be sampled as bathroom outlets may be used to obtain water for drinking and/or food preparation.
- Foot level operated multi-outlet gang sink: In general, samples should be collected from each outlet of a gang sink, however, if the gang sink design does not allow sample collection from each outlet, the schools should contact the local health department or the Department to discuss.
- Traditional outlet with hot and cold-water handle: Samples must be collected from each outlet but only the cold water should be turned on for sampling

Non-Applicable Outlets

In general, any outlet in a room or office within a school that is not used by students (pre-kindergarten through grade 12) and does not provide water for drinking or cooking does not require sampling.

- Dishwashing sinks: If an outlet is designated for dish washing only and involves no opportunity for drinking or cooking (including food preparation), the outlet does not require sampling

- Point of entry: Samples from the point of entry are not required under Subpart 67-4. Point of entry is the location where water enters the building from the distribution system of a public water system.
- Science/Art room outlets: Typically, classrooms in these settings prohibit eating and/or drinking. The school Superintendent has the authority to determine whether these outlets may be used for drinking or cooking and whether they require sampling.
- Tempered outlets: The Department and the US EPA recommend that hot or tempered water not be used for drinking or cooking as warm or hot water increase the leaching of lead into the water.
- Bus garage: Outlets in bus garage buildings do not require sampling unless the building is occupied by students (e.g., BOCES classes).
- Custodial closet outlets: If the outlet is only used for custodial purposes and not for drinking, then the outlet does not need to be sampled.
- Any outlet excluded from sampling should be documented in the Remedial Action Plan (and consider additional controls such locks, signs, and education).

4.0 SAMPLING METHODOLOGY

Samples were collected in accordance with the *Lead Testing in School Drinking Water – 10* NYCRR Subpart 67-4.3. A first-draw sample was collected in a wide mouth 250 mL bottle and collected from a cold water outlet before the water is used. The water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours prior to collection.

Sampling Collection Guidance:

- Pre-stagnation flushing: The Department does not allow for pre-stagnation flushing prior to sampling unless a school is directed to do so by the Department or local health department.
- Aerators: Aerators should not be removed prior to sampling

5.0 SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION

Sampling Date: October 17-19, 2023

The following water fixtures as identified by the school were tested: water fountains (bubblers/bottle fillers) and sinks from the Blind Brook-Rye UFSD.

A total of two hundred thirty-nine (239) samples (including blanks) were collected and analyzed for lead contaminates. All of the samples collected were within NYSDOH action level and compliant, with the exception of the water fixtures noted below. The sample results for all water fixtures tested are located in Appendix A.

HS/MS Water Fixtures that exceeded the NYSDOH Action Level of 0.005mg/L

Sample #	Building	Sample location	Fixture	Results (mg/L)	Remediation
14	HS/MS	Cafeteria serving Line	Coffee maker	0.011	Required
19	HS/MS	Gina's Office (The Commons Area)	Sink	0.020	Required
32	HS/MS	Auditorium Girls Bathroom Room	Sink #1	0.020	Required
33	HS/MS	Auditorium Girls Bathroom Room	Sink #2	0.017	Required
34	HS/MS	Auditorium Girls Bathroom Room	Sink #3	0.006	Required
39	HS/MS	Room 202	Sink #1	0.006	Required
40	HS/MS	Room 202	Sink #15 (Teacher's Desk)	0.014	Required
41	HS/MS	Science Prep Room	Sink #1	0.018	Required
42	HS/MS	Science Prep Room	Sink #1	0.006	Required
43	HS/MS	H203	Sink #13	0.021	Required
44	HS/MS	H203	Sink #14	0.028	Required
45	HS/MS	H204	Sink #7	0.314	Required
46	HS/MS	H204	Sink #8	0.013	Required
50	HS/MS	H216	Sink #1	0.044	Required
51	HS/MS	H216 Prep Room	Sink	0.024	Required
71	HS/MS	Consumer Sciences	Sink #4	0.013	Required

85	HS/MS	M200	Sink #2	0.068	Required
86	HS/MS	M201	Sink (Teacher's Desk)	0.058	Required
96	HS/MS	M211	Sink #2	0.022	Required

Note: If there are more than one water fixture in a room, fixtures are counted from left to right.

Ridge Street School Water Fixtures the exceeded that NYSDOH Action Level of 0.005mg/L

Sample #	Building	Sample location	Fixture	Results (mg/L)	Remediation
18	Ridge Street	Room 111	Sink	0.006	Required
40	Ridge Street	Room 500	Sink	0.054	Required
61	Ridge Street	Cafeteria Pot Filler	Pot Filler	0.053	Required
125	Ridge Street	Room 315	Sink	0.007	Required
126	Ridge Street	Room 314	Sink	0.014	Required
127	Ridge Street	Resources Room Kitchen	Sink	0.061	Required

Note: If there are more than one water fixture in a room, fixtures are counted from left to right.

In accordance with *Lead Testing in School Drinking Water – 10 NYCRR Subpart 67-4*, outlets that exceed the NYS Action Level are obligated to take corrective action. The required actions, notifications, reporting and recordkeeping requirements are listed in the appropriate sections of this report.

The district implemented corrective actions as indicated in appendix C.

For all outlets not used or potentially used for drinking or cooking, the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes (“non- applicable outlets”).

If any inoperable water fixtures during the time of the survey are made operable in the future or new water fixtures are installed, they must be tested prior to use and incorporated into the Water Management Plan.

6.0 RESPONSE AND CORRECTIVE ACTIONS

Steps following an Action Level Exceedance Immediate Response

- Prohibit the use of the outlet immediately (take outlet out of service or turn off) until:
(1) A lead remedial action plan is implemented to mitigate the lead level at the outlet, and
(2) Post-remediation test results indicate that the lead levels are at or below the action level;
- Provide building occupants with an adequate supply of water for drinking and cooking until remediation is performed;
- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report;
- Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the School received the laboratory report.

Corrective Actions / Remediation Options

- Permanent removal of an outlet
- Outlet replacement with “lead-free” plumbing materials
- Pipe replacement with “lead-free” plumbing materials
- Remove other sources of lead (lead pipe, lead solder joints, and brass plumbing components with “lead-free” materials)
- Flushing (systematic flushing program)
- Point of Use (POU) Filters
- Supervision
- Engineering controls
- Education
- Signage

Signage Options:



7.0 Post-Remediation Testing

- Follow-up samples collected after an outlet has been remediated must also be “first-draw” samples. Schools may choose to perform additional sampling (i.e., 30-second flush, etc.) to determine the contribution of lead from plumbing to guide remediation decisions.
- Only those outlets that exceed the action level need to be resampled (following remediation).
- All remediated outlets will likely require flushing prior to being placed back into service.
- Post-remediation tests results need to be reported:
 - in the Department’s HERDS application on HCS, and
 - on the school’s website within the same reporting timeframes/requirements as specified for the initial sampling (addressed in next section).

8.0 Public Notification Requirements

- Within 1 business day of receipt of laboratory reports:
 - Report any and all exceedances (lead result greater than 5 ppb) to the local health department
- Within 10 business days of receipt of laboratory reports:

- Report all exceedances to all staff, parents, and guardians in writing school. A physical written notification is required.
- Report test results (including post-remediation results) in the Department’s electronic reporting system, HERDS accessed through HCS. This information is posted on the Department’s website for the public
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school’s website. This should remain posted on the school’s website for the duration of the compliance period (i.e. 2020-2024)
- Report any lead-free buildings on the school’s website
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school’s website. Laboratory reports must be included. This should remain posted on the school’s website for the duration of the compliance period (i.e. 2023-2025)

9.0 Electronic Reporting in HCS/HERDS

- Within 10 business days of receipt of laboratory reports: Summary data must be reported in the Department’s electronic reporting system, HERDS accessed through HCS. Summary data includes:
 - General information (lead-free status, website address)
 - Sampling information
 - Lead analysis results
 - Response and remediation
- Do not submit laboratory reports directly to the Department or local health department unless otherwise directed.

10.0 Recordkeeping Requirements

- Schools must retain all records of:
 - Test results
 - Remedial action plans
 - Determinations that a building is lead-free; and
 - Waiver requests (only applicable to compliance year 2016)
- Per Subpart 67-4, schools must retain records for 10 years following document creation (Note: other agencies may have additional records retention requirements, i.e., NYS Department of Labor)
- Copies of documents must be provided to the Department, the NY State Education Department, or the local health department upon request
- Department recommends that all records be kept in a centrally located and accessible repository for each school building

11.0 Best Management Practices to Reduce Lead in Drinking Water

- Aerator cleaning
- Routine flushing practices (after vacations and long weekends)
- Use only certified lead-free materials when performing plumbing work
- Follow the manufacturer's recommendations for water softener settings to ensure an appropriate level of hardness
- Temperature control
- Educating staff and students of the benefits of running water at a tap briefly prior to using it for drinking or food preparation. Letting the water run for 30- 60 seconds or until the water feels cold can reduce the potential levels of lead in the drinking water

12.0 Lead in Drinking Water Survey Fact Sheet

Name and Address of Building/Structure Owner:

Blind Brook-Rye UFSD
390 North Ridge Street
Rye Brook, NY 10573

Name and Address of Buildings/Structures Surveyed:

High/Middle School
40 King Street
Rye Brook, NY 10573

Bruno M. Ponterio Ridge Street School
390 North Ridge Street
Rye Brook, NY 10573

Name of the Firm & Person Conducting the Survey:

Regulatory Compliance
Ernest Coon
Russell Coonrod
PO Box 132
Thornwood, New York 10594

Date Survey Was Conducted:

October 17, 2023
October 18, 2023
October 19, 2023

Appendix A
Tabulated Results

Blind Brook-Rye UFSD - High/Middle School								
Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation	Comments
1	High School Faculty Lunch Room	Water Cooler	11.17.23	BDL <0.001	0.005	Y	NA	
2	High School Faculty Lunch Room	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
3	High School Faculty Bathroom	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
4	High School Loading Dock Entrance - Kitchen	Sink #1	11.17.23	BDL <0.001	0.005	Y	NA	
5	High School Loading Dock Entrance - Kitchen	Sink #2	11.17.23	BDL <0.001	0.005	Y	NA	
6	High School Loading Dock Entrance - Kitchen	Sink #3	11.17.23	0.005	0.005	Y	NA	
7	High School Loading Dock Entrance - Kitchen	Sink #4	11.17.23	BDL <0.001	0.005	Y	NA	
8	High School Loading Dock Entrance - Kitchen	Sink #5	11.17.23	BDL <0.001	0.005	Y	NA	
9	High School Loading Dock Entrance - Kitchen - Sink #6	Sink #6	11.17.23	BDL <0.001	0.005	Y	NA	
10	High School Loading Dock Entrance - Kitchen	Sink #7	11.17.23	BDL <0.001	0.005	Y	NA	
11	High School Loading Dock Entrance - Kitchen	Sink #8	11.17.23	BDL <0.001	0.005	Y	NA	
12	High School Serving Line	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
13A/B	High School Ice Machine (Combine Samples)	Ice Machine	11.17.23	BDL <0.001	0.005	Y	NA	
14	Cafeteria serving Line	Coffe Maker	11.17.23	0.011	0.005	N	Required	

15	H106 (Band Room)	Sink	11.17.23	0.001	0.005	Y	NA	
16	Commons	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
17	Commons	Water Fountain - Bottle Filler	11.17.23	BDL <0.001	0.005	Y	NA	
18	Commons	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
19	Gina's Office	Sink	11.17.23	0.02	0.005	N	Required	
20	Commons - Girls Bathroom	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
21	Commons - Boys Bathroom	Sink #1	11.17.23	0.001	0.005	Y	NA	
22	Commons - Boys Bathroom	Sink #2	11.17.23	0.001	0.005	Y	NA	
23	Commons - Boys Bathroom	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
24	Commons - Boys Bathroom	Sink #4	11.17.23	BDL <0.001	0.005	Y	NA	
25	Nurse's Office	Water Cooler	11.17.23	BDL <0.001	0.005	Y	NA	
26	Nurse's Office Main Room	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
27	Nurse's Office Room #4	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
28	Auditorium	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
29	Auditorium	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
30	Auditorium Mens	Sink #2	11.17.23	BDL <0.001	0.005	Y	NA	
31	Auditorium Mens	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
32	Auditorium Girls Bathroom	Sink #1	11.17.23	0.02	0.005	N	Required	

33	Auditorium Girls Bathroom	Sink #2	11.17.23	0.017	0.005	N	Required	
34	Auditorium Girls Bathroom	Sink #3	11.17.23	0.006	0.005	N	Required	
35	Auditorium Girls Bathroom	Sink #4	11.17.23	0.004	0.005	Y	NA	
36	High School Main Office Copy Room	Water Cooler	11.17.23	BDL <0.001	0.005	Y	NA	
37	High School Main Office Copy Room	Sink	11.17.23	0.001	0.005	Y	NA	
38	Hallway Water Fountain Near H221	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
39	Room 202	Sink #1	11.17.23	0.006	0.005	N	Required	
40	Room 202 (Teacher Desk)	Sink #15	11.17.23	0.014	0.005	N	Required	
41	Science Prep Room	Sink #1	11.17.23	0.018	0.005	N	Required	
42	Science Prep Room	Sink #2	11.17.23	0.006	0.005	N	Required	
43	H203	Sink #13	11.17.23	0.021	0.005	N	Required	
44	H203	Sink #14	11.17.23	0.028	0.005	N	Required	
45	H204	Sink #7	11.17.23	0.314	0.005	N	Required	
46	H204	Sink #8	11.17.23	0.013	0.005	N	Required	
47	H210A	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
48	Mens Bathroom Near H215	Sink #1	11.17.23	BDL <0.001	0.005	Y	NA	
49	Mens Bathroom Near H215	Sink #2	11.17.23	0.001	0.005	Y	NA	
50	H216n	Sink	11.17.23	0.044	0.005	N	Required	
51	H216 Prep Room	Sink	11.17.23	0.024	0.005	N	Required	
52	H217	Sink #1	11.17.23	0.003	0.005	Y	NA	
53	Athletic Dir. - Faculty Bathroom	Sink	11.17.23	0.004	0.005	Y	NA	

54	Library Office	Water Cooler	11.17.23	0.001	0.005	Y	NA	
55	Middle School Main Office	Water Cooler	11.17.23	BDL <0.001	0.005	Y	NA	
56	Middle School Main Office	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
57	Middle School Main Office Faculty Bathroom	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
58	Boys Bathroom Near Middle School Main Office	Sink #1	11.17.23	BDL <0.001	0.005	Y	NA	
59	Boys Bathroom Near Middle School Main Office	Sink #2	11.17.23	BDL <0.001	0.005	Y	NA	
60	Middle School Main Office Hallway Water Fountain	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
61	Middle School Main Office Hallway Water Fountain	Water Fountain - Bottle Filler	11.17.23	BDL <0.001	0.005	Y	NA	
62	Middle School Main Office Hallway Water Fountain	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
63	Middle School Main Office Hallway Girls Bathroom	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
64	Gymnasium Girls Bathroom	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
65	Gymnasium Boys Bathroom	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
66	Gymnasium Coaches Office Bathroom	Sink	11.17.23	BDL <0.001	0.005	Y	NA	

67	M101B	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
68	Consumer Sciences	Sink #1	11.17.23	0.001	0.005	Y	NA	
69	Consumer Sciences	Sink #2	11.17.23	0.001	0.005	Y	NA	
70	Consumer Sciences	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
71	Consumer Sciences	Sink #4	11.17.23	0.013	0.005	N	Required	
72	M10B	Sink #2	11.17.23	BDL <0.001	0.005	Y	NA	
73	Faculty Bathroom Near M211	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
74	Faculty Room Near M211	Water Cooler	11.17.23	BDL <0.001	0.005	Y	NA	
75	Faculty Room Near M211	Sink	11.17.23	BDL <0.001	0.005	Y	NA	
76	Boys Bathroom Near M202	Sink #1	11.17.23	BDL <0.001	0.005	Y	NA	
77	Boys Bathroom Near M202	Sink #3	11.17.23	BDL <0.001	0.005	Y	NA	
78	Hallway Water Fountain Near Boys Bathroom	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
79	Hallway Water Fountain Near Girls Bathroom	Water Fountain - Bubbler	11.17.23	BDL <0.001	0.005	Y	NA	
80	Blank	Blank	11.17.23	BDL <0.001	0.005	Y	NA	
81	Girls Bathroom Near M100	Sink #1	11.18.23	BDL <0.001	0.005	Y	NA	
82	Girls Bathroom Near M100	Sink #3	11.18.23	0.001	0.005	Y	NA	
83	Faculty Bathroom Near M100	Sink	11.18.23	BDL <0.001	0.005	Y	NA	
84	M200	Sink #1	11.18.23	BDL <0.001	0.005	Y	NA	
85	M200	Sink #2	11.18.23	0.068	0.005	N	Required	
86	M201 (Teacher's Desk)	Sink	11.18.23	0.058	0.005	N	Required	

87	Girls Bathroom Near M201	Sink #1	11.18.23	BDL <0.001	0.005	Y	NA	
88	Girls Bathroom Near M201	Sink #2	11.18.23	BDL <0.001	0.005	Y	NA	
89	Girls Bathroom Near M201	Sink #3	11.18.23	BDL <0.001	0.005	Y	NA	
90	Hallway Water Fountain Near M201 Upper	Water Fountain - Bubbler	11.18.23	BDL <0.001	0.005	Y	NA	
91	Hallway Water Fountain Near M201 Lower	Water Fountain - Bubbler	11.18.23	BDL <0.001	0.005	Y	NA	
92	Boys Bathroom Near M201	Sink #1	11.18.23	BDL <0.001	0.005	Y	NA	
93	Boys Bathroom Near M201	Sink #3	11.18.23	BDL <0.001	0.005	Y	NA	
94	Faculty Bathroom Near	Sink	11.18.23	BDL <0.001	0.005	Y	NA	
95	M211	Sink #1	11.18.23	0.004	0.005	Y	NA	
96	M211	Sink #2	11.18.23	0.022	0.005	N	Required	
97	M211	Sink #3	11.18.23	0.054	0.005	N	Required	
98	M211	Sink #4	11.18.23	0.085	0.005	N	Required	
99	M211	Sink #5	11.18.23	0.061	0.005	N	Required	
100	Outside Water Fountain Upper	Water Fountain - Bubbler	11.18.23	BDL <0.001	0.005	Y	NA	
101	Outside Girls Bathroom	Sink #1	11.18.23	BDL <0.001	0.005	Y	NA	
102	Outside Girls Bathroom	Sink #2	11.18.23	BDL <0.001	0.005	Y	NA	
103	Outside Boys Bathroom	Sink #2	11.18.23	BDL <0.001	0.005	Y	NA	
104A/B	Outside Ice Machine (Combine Samples)	Ice machine	11.18.23	BDL <0.001	0.005	Y	NA	
105	FAB Lab	Sink	11.18.23	BDL <0.001	0.005	Y	NA	
106	FAB Lab - Water Fountain Near Room 108 Upper	Water Fountain - Bubbler	11.18.23	BDL <0.001	0.005	Y	NA	

107	FAB Lab - Water Fountain Near Room 108 Upper	Water Fountain - Bottle Filler	11.18.23	BDL <0.001	0.005	Y	NA	
108	FAB Lab - Water Fountain Near Room 108 Lower	Water Fountain - Bubbler	11.18.23	BDL <0.001	0.005	Y	NA	
109	FAB Lab - Bathroom Closest to Water Fountain	Sink	11.18.23	BDL <0.001	0.005	Y	NA	
110	FAB Lab - Bathroom Closest to Room 108	Sink	11.18.23	BDL <0.001	0.005	Y	NA	

NA = Not Applicable

NYS Lead Action Level 0.005 mg/L

*Sinks are counted from Left to Right

Blind Brook-Rye UFSD - Ridge Street School

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation	Comments
1	Room #101, Main Office, Kitchen	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
2	Room #113	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
3	Cafeteria Outside Water Fountain	Water Fountain Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
4	Cafeteria Outside Water Fountain	Water Fountain Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
5	Cafeteria Inside Water Fountain	Water Fountain Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
6	Cafeteria Inside Water Fountain	Water Fountain Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
7	Cafeteria Hand Wash Station 1	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
8	Cafeteria Hand Wash Station 1	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
9	Cafeteria Hand Wash Station 1	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
10	Cafeteria Hand Wash Station 2	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
11	Cafeteria Hand Wash Station 2	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
12	Cafeteria Hand Wash Station 2	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
13	Men's Room #100J	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
14	Men's Room 100J	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
15	Women's Room #100H	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
16	Women's Room #100H	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
17	Women's Room #100H	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
18	Room #111	Sink	10/19-20/23	0.006	0.005	N	Required	
19	Room #110	Sink	10/19-20/23	0.002	0.005	Y	NA	
20	Room #108	Sink	10/19-20/23	0.004	0.005	Y	NA	
21	Room #107	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
22	Upper Gym	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	

23	Boy's Room #106	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
24	Boy's Room #106	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
25	Boy's Room #106	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
26	Girl's Room #105	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
27	Girl's Room #105	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
28	Girl's Room #105	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
29	Room #104	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
30	Room #103	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
31	Room #103	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
32	Outside Room #103	Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
33	Room #102	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
34	Room #102	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
35	Room #102	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
36	Room #102 Hand Wash	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
37	Room #102 Hand Wash	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
38	Room #102 Hand Wash	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
39	Room #102	Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
40	Room #500	Sink	10/19-20/23	0.054	0.005	N	Required	
41	Girl's Room #511	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
42	Girl's Room #511	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
43	Outside Room #511	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
44	Boy's Room #512	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
45	Boy's Room #512	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
46	Boy's Room #512	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
47	Boy's Room #410	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
48	Boy's Room #410	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
49	Boy's Room #410	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
50	Outside Room #410	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
51	Girl's Room #411	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
52	Room #402	Sink #1	10/19-20/23	0.003	0.005	Y	NA	
53	Room #402	Sink #2	10/19-20/23	0.003	0.005	Y	NA	
54	Room #402	Sink #3	10/19-20/23	0.001	0.005	Y	NA	
55	Room #402	Sink #4	10/19-20/23	0.002	0.005	Y	NA	

56	Room #402	Sink #5	10/19-20/23	0.001	0.005	Y	NA	
57	Room #402	Sink #6	10/19-20/23	0.001	0.005	Y	NA	
58	DO3C	Sink	10/19-20/23	0.001	0.005	Y	NA	
59	Business Office Kitchen	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
60	Cafeteria Hand Wash	Sink #1	10/19-20/23	0.001	0.005	Y	NA	
61	Cafeteria Pot Filler	Pot Filler	10/19-20/23	0.053	0.005	N	Required	
62	Cafeteria Hand Wash	Sink #2	10/19-20/23	0.004	0.005	Y	NA	
63	Cafeteria	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
64	Cafeteria	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
65	Cafeteria Dish	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
66	Cafeteria Dish	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
67	Cafeteria Sprayer 1	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
68	Cafeteria Sprayer 2	Sink #2	10/19-20/23	0.001	0.005	Y	NA	
69	Service Line	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
70	Service Line	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
71	Service Line	Sink #3	10/19-20/23	0.003	0.005	Y	NA	
72	Room #201	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
73	Room #201 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
74	Outside Room #202	Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
75	Room #202	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
76	Room #202 Restroom	Sink	10/19-20/23	0.003	0.005	Y	NA	
77	Room #203	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
78	Room #203 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
79	Room #204	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
80	Room #204 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
81	Room #205	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
82	Room #205 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
83	Outside Room #205	Bubbler #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
84	Outside Room #205	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
85	Outside Room #205	Bubbler #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
86	Restroom #206A	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
87	Room #213	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
88	Room #214	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	

89	Room #217 Bathroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
90	Room #217D	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
91	Room #218	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
92	Room #220	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
93	Girl's Room #224	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
94	Girl's Room #224	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
95	Girl's Room #224	Sink #3	10/19-20/23	BDL <0.001	0.005	Y	NA	
96	Boy's Room #222	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
97	Boy's Room #222	Sink #2	10/19-20/23	0.001	0.005	Y	NA	
98	Room #224	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
99	Room #225	Sink	10/19-20/23	0.004	0.005	Y	NA	
100	Room #301	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
101	Room #301 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
102	Room #302	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
103	Room #302 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
104	Room #303	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
105	Room #303 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
106	Outside Room #303	Bubbler	10/19-20/23	BDL <0.001	0.005	Y	NA	
107	Room #304	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
108	Room #304 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
109	Room #305	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
110	Room #305 Restroom	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
111	Outside Room #305	Bubbler #1	10/19-20/23	BDL <0.001	0.005	Y	NA	
112	Outside Room #305	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
113	Outside Room #305	Bubbler #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
114	S 137	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
115	306 B	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
116	Room #310	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
117	Room #311	Sink	10/19-20/23	BDL <0.001	0.005	Y	NA	
118	Room #319	Sink	10/19-20/23	0.004	0.005	Y	NA	
119	Outside Room #312	Bottle Filler	10/19-20/23	BDL <0.001	0.005	Y	NA	
120	Room #318	Sink	10/19-20/23	0.005	0.005	Y	NA	
121	Boy's Room #317	Sink #1	10/19-20/23	BDL <0.001	0.005	Y	NA	

122	Boy's Room #317	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
123	Girl's Room #316	Sink #2	10/19-20/23	BDL <0.001	0.005	Y	NA	
124	Girl's Room #316	Sink #3	10/19-20/23	0.001	0.005	Y	NA	
125	Room #315	Sink	10/19-20/23	0.007	0.005	N	Required	
126	Room #314	Sink	10/19-20/23	0.014	0.005	N	Required	
127	Resources Room Kitchen	Sink	10/19-20/23	0.061	0.005	N	Required	
128	Resources Room	Bubbler	10/19-20/23	0.001	0.005	Y	NA	
129	Blank	Blank	10/19-20/23	BDL <0.001	0.005	Y	NA	

NA = Not Applicable

NYS Lead Action Level 0.005 mg/L

*Sinks are counted from Left to Right

Appendix B
Laboratory Data Sheets

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2959097	High School Faculty Lunch Room - Water Cooler	Water	BDL < 0.001 mg/L
2 2959098	High School Faculty Lunch Room - Sink	Water	BDL < 0.001 mg/L
3 2959099	High School Faculty Bathroom - Sink	Water	BDL < 0.001 mg/L
4 2959100	High School Loading Dock Entrance - Kitchen - Sink #1	Water	BDL < 0.001 mg/L
5 2959101	High School Loading Dock Entrance - Kitchen - Sink #2	Water	BDL < 0.001 mg/L
6 2959102	High School Loading Dock Entrance - Kitchen - Sink #3	Water	0.005 mg/L
7 2959103	High School Loading Dock Entrance - Kitchen - Sink #4	Water	BDL < 0.001 mg/L
8 2959104	High School Loading Dock Entrance - Kitchen - Sink #5	Water	BDL < 0.001 mg/L
9 2959105	High School Loading Dock Entrance - Kitchen - Sink #6	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2959106	High School Loading Dock Entrance - Kitchen - Sink #7	Water	BDL < 0.001 mg/L
11 2959107	High School Loading Dock Entrance - Kitchen - Sink #8	Water	BDL < 0.001 mg/L
12 2959108	High School Serving Line - Sink	Water	BDL < 0.001 mg/L
13A/B 2959109	High School Ice Machine (Combine Samples)	Water	BDL < 0.001 mg/L
14 2959110	Coffe Maker	Water	0.011 mg/L
15 2959111	H106 (Band Room) - Sink	Water	0.001 mg/L
16 2959112	Commons - Water Fountain - Bubbler	Water	BDL < 0.001 mg/L
17 2959113	Commons - Water Fountain - Bottle Filler	Water	BDL < 0.001 mg/L
18 2959114	Commons - Water Fountain - Bubbler	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2959115	Gina's Office - Sink	Water	0.020 mg/L
20 2959116	Commons - Girls Bathroom - Sink #3	Water	BDL < 0.001 mg/L
21 2959117	Commons - Boys Bathroom - Sink #1	Water	0.001 mg/L
22 2959118	Commons - Boys Bathroom - Sink #2	Water	0.001 mg/L
23 2959119	Commons - Boys Bathroom - Sink #3	Water	BDL < 0.001 mg/L
24 2959120	Commons - Boys Bathroom - Sink #4	Water	BDL < 0.001 mg/L
25 2959121	Nurse's Office Water Cooler	Water	BDL < 0.001 mg/L
26 2959122	Nurse's Office Main - Sink	Water	BDL < 0.001 mg/L
27 2959123	Nurse's Office Room #4 - Sink	Water	BDL < 0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2959124	Auditorium Water Fountain Upper - Bubblers	Water	BDL < 0.001 mg/L
29 2959125	Auditorium Water Fountain Lower - Bubblers	Water	BDL < 0.001 mg/L
30 2959126	Auditorium Mens Bathroom - Sink #2	Water	BDL < 0.001 mg/L
31 2959127	Auditorium Mens Bathroom - Sink #3	Water	BDL < 0.001 mg/L
32 2959128	Auditorium Girls Bathroom - Sink #1	Water	0.020 mg/L
33 2959129	Auditorium Girls Bathroom - Sink #2	Water	0.017 mg/L
34 2959130	Auditorium Girls Bathroom - Sink #3	Water	0.006 mg/L
35 2959131	Auditorium Girls Bathroom - Sink #4	Water	0.004 mg/L
36 2959132	High School Main Office Copy Room - Water Cooler	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
37 2959133	High School Main Office Copy Room - Sink	Water	0.001 mg/L
38 2959134	Hallway Water Fountain Near H221 - Bubbler	Water	BDL < 0.001 mg/L
39 2959135	Room 202 - Sink #1	Water	0.006 mg/L
40 2959136	Room 202 - Sink #15 (Teacher Desk)	Water	0.014 mg/L
41 2959137	Science Prep Room - Sink #1	Water	0.018 mg/L
42 2959138	Science Prep Room - Sink #2	Water	0.006 mg/L
43 2959139	H203 - Sink #13	Water	0.021 mg/L
44 2959140	H203 - Sink #14	Water	0.028 mg/L
45 2959141	H204 - Sink #7	Water	0.314 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
46 2959142	H204 - Sink #8	Water	0.013 mg/L
47 2959143	H210A - Sink	Water	BDL < 0.001 mg/L
48 2959144	Mens Bathroom Near H215 - Sink #1	Water	BDL < 0.001 mg/L
49 2959145	Mens Bathroom Near H215 - Sink #2	Water	0.001 mg/L
50 2959146	H216 - Sink #1	Water	0.044 mg/L
51 2959147	H216 Prep Room - Sink	Water	0.024 mg/L
52 2959148	H217 - Sink #1	Water	0.003 mg/L
53 2959149	Athletic Dir. - Faculty Bathroom - Sink	Water	0.004 mg/L
54 2959150	Library Office - Water Cooler	Water	0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
55 2959151	Middle School Main Office - Water Cooler	Water	BDL < 0.001 mg/L
56 2959152	Middle School Main Office - Sink	Water	BDL < 0.001 mg/L
57 2959153	Middle School Main Office Faculty Bathroom - Sink	Water	BDL < 0.001 mg/L
58 2959154	Boys Bathroom Near Middle School Main Office - Sink #1	Water	BDL < 0.001 mg/L
59 2959155	Boys Bathroom Near Middle School Main Office - Sink #2	Water	BDL < 0.001 mg/L
60 2959156	Middle School Main Office Hallway Water Fountain - Bubblers	Water	BDL < 0.001 mg/L
61 2959157	Middle School Main Office Hallway Water Fountain - Bottle Filler	Water	BDL < 0.001 mg/L
62 2959158	Middle School Main Office Hallway Water Fountain - Bubblers	Water	BDL < 0.001 mg/L
63 2959159	Middle School Main Office Hallway Girls Bathroom - Sink #3	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
64 2959160	Gymnasium Girls Bathroom - Sink	Water	BDL < 0.001 mg/L
65 2959161	Gymnasium Boys Bathroom - Sink	Water	BDL < 0.001 mg/L
66 2959162	Gymnasium Coaches Office Bathroom - Sink	Water	BDL < 0.001 mg/L
67 2959163	M101B - Sink	Water	BDL < 0.001 mg/L
68 2959164	Consumer Sciences - Sink #1	Water	0.001 mg/L
69 2959165	Consumer Sciences - Sink #2	Water	0.001 mg/L
70 2959166	Consumer Sciences - Sink #3	Water	BDL < 0.001 mg/L
71 2959167	Consumer Sciences - Sink #4	Water	0.013 mg/L
72 2959168	M10B - Sink #2	Water	BDL < 0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-10XX-23-IH - Blind Book - HS/MS

Date Collected: 11/17/2023
 Collected By: Ernest Coon
 Date Received: 10/17/2023
 Date Analyzed: 10/18/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
73 2959169	Faculty Bathroom Near M211 - Sink	Water	BDL < 0.001 mg/L
74 2959170	Faculty Room Near M211 - Water Cooler	Water	BDL < 0.001 mg/L
75 2959171	Faculty Room Near M211 - Sink	Water	BDL < 0.001 mg/L
76 2959172	Boys Bathroom Near M202 - Sink #1	Water	BDL < 0.001 mg/L
77 2959173	Boys Bathroom Near M202 - Sink #3	Water	BDL < 0.001 mg/L
78 2959174	Hallway Water Fountain Near Boys Bathroom - Bubblers	Water	BDL < 0.001 mg/L
79 2959175	Hallway Water Fountain Near Girls Bathroom - Bubblers	Water	BDL < 0.001 mg/L
80 2959176	Not Applicable	Blank	BDL < 0.001 mg/L

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN BB-1083-23-IH - Blind Book UFSD - HS/MS

Date Collected: 10/18/2023
 Collected By: Ernest Coon
 Date Received: 10/18/2023
 Date Analyzed: 10/19/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
81 2959228	Girls Bathroom Near M100 - Sink #1	Water	BDL < 0.001 mg/L
82 2959229	Girls Bathroom Near M100 - Sink #3	Water	0.001 mg/L
83 2959230	Faculty Bathroom Near M100 - Sink	Water	BDL < 0.001 mg/L
84 2959231	M200 - Sink #1	Water	BDL < 0.001 mg/L
85 2959232	M200 - Sink #2	Water	0.068 mg/L
86 2959233	M201 - Sink (Teacher's Desk)	Water	0.058 mg/L
87 2959234	Girls Bathroom Near M201 - Sink #1	Water	BDL < 0.001 mg/L
88 2959235	Girls Bathroom Near M201 - Sink #2	Water	BDL < 0.001 mg/L
89 2959236	Girls Bathroom Near M201 - Sink #3	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN BB-1083-23-IH - Blind Book UFSD - HS/MS

Date Collected: 10/18/2023
 Collected By: Ernest Coon
 Date Received: 10/18/2023
 Date Analyzed: 10/19/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
90 2959237	Hallway Water Fountain Near M201 Upper - Bubblers	Water	BDL < 0.001 mg/L
91 2959238	Hallway Water Fountain Near M201 Lower - Bubblers	Water	BDL < 0.001 mg/L
92 2959239	Boys Bathroom Near M201 - Sink #1	Water	BDL < 0.001 mg/L
93 2959240	Boys Bathroom Near M201 - Sink #3	Water	BDL < 0.001 mg/L
94 2959241	Faculty Bathroom Near M211 - Sink	Water	BDL < 0.001 mg/L
95 2959242	M211 - Sink #1	Water	0.004 mg/L
96 2959243	M211 - Sink #2	Water	0.022 mg/L
97 2959244	M211 - Sink #3	Water	0.054 mg/L
98 2959245	M211 - Sink #4	Water	0.085 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-1083-23-IH - Blind Book UFSD - HS/MS

Date Collected: 10/18/2023
 Collected By: Ernest Coon
 Date Received: 10/18/2023
 Date Analyzed: 10/19/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
99 2959246	M211 - Sink #5	Water	0.061 mg/L
100 2959247	Outside Water Fountain Upper - Bubbler	Water	BDL < 0.001 mg/L
101 2959248	Outside Girls Bathroom - Sink #1	Water	BDL < 0.001 mg/L
102 2959249	Outside Girls Bathroom - Sink #2	Water	BDL < 0.001 mg/L
103 2959250	Outside Boys Bathroom - Sink #2	Water	BDL < 0.001 mg/L
104A/B 2959251	Outside Ice Machine (Combine Samples)	Water	BDL < 0.001 mg/L
105 2959252	FAB Lab - Sink	Water	BDL < 0.001 mg/L
106 2959253	FAB Lab - Water Fountain Near Room 108 Upper - Bubbler	Water	BDL < 0.001 mg/L
107 2959254	FAB Lab - Water Fountain Near Room 108 Upper - Bottle Filler	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN BB-1083-23-IH - Blind Book UFSD - HS/MS

Date Collected: 10/18/2023
 Collected By: Ernest Coon
 Date Received: 10/18/2023
 Date Analyzed: 10/19/2023
 Analyzed By: Michael K. Trojan/Ernest Sanchez
 Signature: *Michael Trojan Ernest Sanchez*
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
108 2959255	FAB Lab - Water Fountain Near Room 108 Lower - Bubbler	Water	BDL < 0.001 mg/L
109 2959256	FAB Lab - Bathroom Closest to Water Fountain - Sink	Water	BDL < 0.001 mg/L
110 2959257	FAB Lab - Bathroom Closest to Room 108 - Sink	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client: Regulatory Compliance

No. of Samples: 129

Analyte: **Asbestos** PLM
 NOB PLM Only
 NOB TEM Only
 NOB PLM/TEM
 NOB TEM/PLM
 Air 7400 (PCM)
 Air AHERA (TEM)
 Air 7402 (TEM)
 Water (TEM)
 Other _____

Lead Solid
 Dust
 Air
 Water
 Other _____

Fungi Spore Trap
 Tape Lift
Other Analyte _____

TCLP
 Pb Only
 8 RCRA

Turn-Around 03Hr 06Hr 12Hr 24Hr 30Hr
 48Hr 72Hr 96Hr 5Day Other 2WK

Shipped Via: US Mail Walk In
 FedEx US Exp
 UPS Courier
 Drop Box Other _____

State of Origin: NY CT NJ PA MA
 RI ME VT Other _____

Sample Disposition: (Std.) _____ (Return)

Client Project Name/Number:

Blind Brook UFSD - Ridge Street School BB-1083-22-JH

Sampled By:

Name (Print or Type)

Signature

Date

Submitted By:

Name (Print or Type)

Signature

Date

Comments:

FOR LABORATORY USE ONLY

Account Number: _____

Received By:

Gregory H. Hayes
Name (Print)

GH
Signature

Oct 20 '23
Date

9:00
Time

Logged-In By: _____

Prepped By: _____

Analyzed By: _____

Re-Analyzed By: _____

Checked By: _____

Logged-Out By: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/19/2023
 Collected By: Raymond Lee
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
 RE: BB-1083-23-1H

BLIND Beck WASH
RIDGE Smeat School

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other

2 wk

Sample Number	Sample Location	Sample Description	Result
2960217	RM 101, MAIN OFFICE, KITCHEN SINK		
2960218	RM 113 SINK		
2960219	CARESPA CURTAIN WASH FOUNTAIN	BUBBLED	
2960220		BOTTLE FILLER	
2960221		FIBRE WATER FOUNTAIN TAPBLK	
2960222		BOTTLE FILLER	
2960223	CARESPA HAND WASH STATION 1		
2960224			
2960225			
2960226	CARESPA HAND WASH STATION 2		

Comments: _____

OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 Client Project Number/Name: RE: 33-1083-23-11

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2wk

Sample Number	Sample Location	Sample Description	Result
2960227 11	CHERIE'S HANDWASH STATION 2, 2		
2960228 12	↓ ↓ ↓		
2960229 13	↓ ↓ ↓	Men's Room 1003 SINK, 1	
2960230 14	↓ ↓ ↓		
2960231 15	↓ ↓ ↓	Women's Room 100H, 1	
2960232 16	↓ ↓ ↓		
2960233 17	↓ ↓ ↓		
2960234 18	↓ ↓ ↓	RM # 111 SINK	
2960235 19	↓ ↓ ↓	RM # 110 SINK	

Comments: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
 RE: 3B-1083-23-114

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 24hr

Sample Number	Sample Location	Sample Description	Result
2960236 20	RM # 108 SINK		
2960237 21	RM # 109 SINK		
2960238 22	UPPER GYM BATTLE FILLER		
2960239			
2960240	Boy's Room 106 SINK, 1		
2960241 25	↓ ↓ ↓	2	
2960242		3	
2960243	Girl's Room 105 SINK, 1		
2960244 26	↓ ↓ ↓	2	
2960245 29	RM # 104 SINK	3	

Comments: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

RE: 33-1083-23-114
 Client Project Number/Name

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 24hr

Sample Number	Sample Location	Sample Description	Result
2960246	30 RM #103 SLUK, 1		
2960247	31 RM #103 SLUK, 2		
2960248	32 Resolux cartridge RM # 103		
2960249	33 RM # 102 SLUK, 1		
2960250	34 RM # 102 SLUK, 2		
2960251	35 RM # 102 SLUK, 3		
2960252	36 Washed, 1		
2960253	37 Washed, 2		
2960254	38 Washed, 3		
2960255	39 Resolux		

Comments: _____

OCT 28 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 RE: 33-1083-23-114
 Client Project Number/Name: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2wk

Sample Number	Sample Location	Sample Description	Result
2960256	40 RM # 500 SINK		
2960257	41 Girls' Room 511 SINK, 1		
2960258	42 ↓ ↓ ↓ 2		
2960259	43 Bottle Filler outside RM # 511		
2960260	44 Boys' Room 512 SINK, 1		
2960261	45 ↓ ↓ ↓ 2		
2960262	46 ↓ ↓ ↓ 3		
2960263	47 Boys' Room 410 SINK 1		
2960264	48 2		
2960265	49 3	OCT 20 '23 9:00	

Comments: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
 RE: BB-1083-23-FH

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2wk

Sample Number	Sample Location	Sample Description	Result
2960266	50	BOTTLE FILLER around RM #410	
2960267	51	Gravel Room WH sink 1	
2960268	52	RM # 402 sink, 1	
2960269	53	2	
2960270	54	3	
2960271	55	4	
2960272	56	5	
2960273	57	6	
2960274	58	DO3C sink	
2960275	59	Bas. Office Kitchen sink	

Comments: _____

OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 Client Project Number/Name: RE: 33-1083-23-11

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2wk

Sample Number	Sample Location	Sample Description	Result
2960276	60	Chertown Warehouse sink 1	
2960277	61	Rot Filter	
2960278	62	Warehouse sink 2	
2960279	63	Sink 1	
2960280	64	Sink 2	
2960281	65	Dish Sink 1	
2960282	66	Sink 2	
2960283	67	Sewer 1	
2960284	68	Sink 2	
2960285	69	Sewer Line Sink 1	

Comments: _____

OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____
 Collected By: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 RE: 33-1083-23-114
 Client Project Number/Name: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2wk

Sample Number	Sample Location	Sample Description	Result
2960286 70	Service Lab sink 2		
2960287 71	↓ ↓ 3		
2960288 72	Rm # 201 sink		
2960289 73	↓ Restroom sink		
2960290 74	Restroom outside Rm 202		
2960291 75	Rm # 202 sink		
2960292 76	↓ Restroom sink		
2960293 77	Rm # 203 sink		
2960294 78	↓ Restroom sink		
2960295 79	Rm # 204 sink		

Comments: _____

OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: _____ EAS Client: Secondary Compliance
 Collected By: _____ Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____ Client Project Number/Name
 Time: _____ RE: 3B-1013-22-1H
 Signature: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2960296 80	Rm # 204, Restroom sink		
2960297 81	Rm # 205 sink		
2960298 92	↓ Restroom sink		
2960299 83	Restroom 1 outside rm 205		
2960300 84	Restroom Filter		
2960301 85	Restroom 2		
2960302 86	Restroom 205A sink		

Comments: _____

OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/30/2023 EAS Client: Remedy Computers
 Collected By: Justin Cooper Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

RE: 98-1083-23-14
 Client Project Number/Name: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other: 2 Wks

Sample Number	Sample Location	Sample Description	Result
2960303	RM # 213 SINK		
2960304	RM #214 SINK		
2960305	RM #217 BACKROOM SINK		
2960306	RM #219D SINK		
2960307	RM #218 SINK		
2960308	RM #220 SINK		
2960309	GUEST ROOM #224 SINK		
2960310	QA		
2960311	QA		
2960312	QA		

Comments: _____
 OCT 20 '23 9:00

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/20/2023
 Collected By: Rustell Looney
 Date Received: _____
 Date Analyzed By: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reston City Compliance
 Address: _____
 Client Project Number/Name
 RE: 08-1083-23-1A

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2 wks

Sample Number	Sample Location	Sample Description	Result
2960313	977	Boys' Room 222 SINK 2	
2960314	946	RM # 224 SINK	
2960315	999	RM # 225 SINK	
2960316	100	RM # 201 SINK	
2960317	101	↓ Restroom SINK	
2960318	102	RM # 302 SINK	
2960319	103	↓ Restroom SINK	
2960320	104	RM # 303 SINK	
2960321	105	↓ Restroom SINK	
2960322	106	Restroom outside RM # 503	

Comments: _____

OCT 20 '23 9:01

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/20/2023 EAS Client: Regulatory Compliance
 Collected By: Rachel Cassano Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____ Client Project Number/Name
 Time: _____ RE: BB-1083-23-14
 Signature: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2 wks

Sample Number	Sample Location	Sample Description	Result
2960323	107	Rm # 304 SINK	
2960324	108	↓ RECEPTION SINK	
2960325	109	Rm # 305 SINK	
2960326	110	↓ RECEPTION SINK	
2960327	111	BUBBLER 1 OUTSIDE RM # 305	
2960328	112	BOTTLE FILLER	
2960329	113	RECEPTION 2	
2960330	114	S 107 SINK	
2960331	115	306 B SINK	
2960332	116	Rm # 310 SINK	

Comments: _____

OCT 20 2023 9:01

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/20/2023
 Collected By: 10/20/2023
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Restonary Compliance
 Address: _____

Client Project Number/Name
 RE: 915-10883-23-14

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2 Wks

Sample Number	Sample Location	Sample Description	Result
2960333 119	Rm # 311 SINK		
2960334 116	Rm # 319 SINK		
2960335 114	Garage Filler CURSORS Rm # 312		
2960336 120	Rm # 318 SINK		
2960337 121	Garage Room 317 SINK 1		
2960338 122	↓ ↓ SINK 2		
2960339 125	Garage Room 316 SINK 2		
2960340 124	↓ ↓ SINK 3		
2960341 125	Rm # 315 SINK		
2960342 126	Rm # 314 SINK		

Comments: _____

OCT 20 '23 9:01

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/20/2023
 Collected By: Rustyn Campbell
 Date Received: _____
 Date Analyzed By: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 Client Project Number/Name: _____
 RE: BB - 1083 - 23 - 14

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other 2 wks

Sample Number	Sample Location	Sample Description	Result
2960343 1257	Resource room Kitchen sink		
2960344 1256	↓ Basement		
2960345 1291	Blank.		

Comments: _____

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client: Regcom

No. of Samples: 30

Analyte: **Asbestos**
 PLM
 NOB PLM Only
 NOB TEM Only
 NOB PLM/TEM
 NOB TEM/PLM
 Air 7400 (PCM)
 Air AHERA (TEM)
 Air 7402 (TEM)
 Water (TEM)
 Other _____

Lead
 Solid
 Dust
 Air
 Water
 Other _____

Fungi
 Spore Trap
 Tape Lift
Other Analyte

TCLP
 Pb Only
 8 RCRA

Turn-Around: 03Hr 06Hr 12Hr 24Hr 30Hr
 48Hr 72Hr 96Hr 5Day Other 2wk

Shipped Via: US Mail Walk In
 FedEx US Exp
 UPS Courier
 Other 2wk

State of Origin: NY CT NJ PA MA
 RI ME VT Other _____

Sample Disposition: (Std.) _____ (Return)

Client Project Name/Number: BLIND BROOK WFSO- ITS/MS BB-1003-23-14

Sampled By: ENRIST COON _____ 10/18/23
Name (Print or Type) Signature Date

Submitted By: ENRIST COON _____ 10/18/23
Name (Print or Type) Signature Date

Comments: _____

FOR LABORATORY USE ONLY

Account Number: _____

Received By: E. Sanchez _____ OCT 18 '23 8:18
Name (Print) Signature Date Time

Logged-In By: _____

Prepped By: _____

Analyzed By: _____

Re-Analyzed By: _____

Checked By: _____

Logged-Out By: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/18/23
 Collected By: EC
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____
 RE: 33-1083-23-114
 Client Project Number/Name: HS/MS
GLWD-Blind Beck WESD

Turn- 03 Hr 06 Hr
 Around 012 Hr 024 Hr
 030 Hr 048 Hr
 072 Hr 096 Hr
 05 Day Other 200C

Sample Number	Sample Location	Sample Description	Result
2959228	G11s Bathroom Near M100 - SINK	#1 150	
2959229	" " " - SINK	#3	
2959230	Faculty Bathroom Near M100 - SINK		
2959231	M200 SINK #1		
2959232	M200 SINK #2		
2959233	M201 SINK (TEACHERS DESK)		
2959234	G11s Bathroom NEAR M201 SINK #1		
2959235	" " " " #2		
2959236	" " " " #3		
2959237	Hallway Water Fountain NEAR M201 UPPER	Bubbler	

Comments:

OCT 18 '23 8:18

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/18/23 EAS Client: Peapack
 Collected By: Esom Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____ RE: BR-1083-23-14
 Signature: _____ Client Project Number/Name: _____
 _____ 15/m5

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959239	91 hallway water fountain near M201 house bubbler	120	
2959240	92 Boys Bathroom near M201 sink #1		
2959241	93 " " " " #3		
2959242	94 Faculty Bathroom near M211 sink		
2959243	95 M211 sink #1		
2959244	96 M211 sink #2		
2959245	97 " " #3		
2959246	98 " " #4		
2959247	99 " " #5		
2959248	100 OUTSIDE water fountain w peer - bubbler		

OCT 18 '23 8:18

Comments: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/18/23 EAS Client: Logcom
 Collected By: Escon Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____ RE: BB-1083-23-112
 Signature: _____ Client Project Number/Name: _____
 _____ MS/HS

Turn- 003 Hr 006 Hr
 Around 012 Hr 024 Hr
 030 Hr 048 Hr
 072 Hr 096 Hr
 05 Day Other 24k

Sample Number	Sample Location	Sample Description	Result
2959248	101 OUTSIDE Girls Bathroom. Sink #1	126	
2959249	102 " " " " #2		
2959250	103 " Boys Bathroom - Sink #2		
2959251	104A OUTSIDE Ice Machine	} Combine Samples	
	104B " " "		
2959252	105 FAB LAB - SINK		
2959253	106 FAB LAB - WATER Fountain near Em108	UPPER - Bubble	
2959254	107 " " " "	" " - ^{BOTTLE} Filler	
2959255	108 " " " "	" " LOWER - Bubble	
2959256	109 " " Bathroom closest to WATER Fountain - SINK		OCT 18 '23 8:18

Comments: _____

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client: Regulatory Compliance
PO Box 132
Hoboken, NJ 10594

No. of Samples: 80

Analyte: **Asbestos**
 PLM
 NOB PLM Only
 NOB TEM Only
 NOB PLM/TEM
 NOB TEM/PLM
 Air 7400 (PCM)
 Air AHERA (TEM)
 Air 7402 (TEM)
 Water (TEM)
 Other _____

Lead
 Solid
 Dust
 Air
 Water
 Other _____

Fungi
 Spore Trap
 Tape Lift
Other Analyte

TCLP
 Pb Only
 8 RCRA

Turn-Around 03Hr 06Hr 12Hr 24Hr 30Hr
 48Hr 72Hr 96Hr 5Day Other 2wk

Shipped Via: US Mail Walk In
 FedEx US Exp
 UPS Courier
 Drop Box Other _____

State of Origin: NY CT NJ PA MA
 RI ME VT Other _____

Sample Disposition (Std.) (Return)

Client Project Name/Number: BB-10XX-23-IH

Sampled By: ERNEST LEON
Name (Print or Type)

[Signature]
Signature

10/17/23
Date

Submitted By: ERNEST LEON
Name (Print or Type)

[Signature]
Signature

10/17/23
Date

Comments: _____

FOR LABORATORY USE ONLY

Account Number: _____

OCT 17 '23 9:02

Received By: F. Sanchez
Name (Print)

[Signature]
Signature

Date

Time

Logged-In By: _____

Prepped By: _____

Analyzed By: _____

Re-Analyzed By: _____

Checked By: _____

Logged-Out By: _____

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 1-7
 Collected By: E. COON
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name: BR-10XY-23-T4
 RE: BLIND BROOK - Hs/ms

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other Swirls

Sample Number	Sample Location	Sample Description	Result
2959097	Hs Faculty Lunch Room - 120 ^{collected}		120
2959098	Hs Faculty Lunch Room - SINK		
2959099	Hs Faculty BATHROOM - SINK		
2959100	Hs Loading dock ENTRANCE - Kitchen - SINK #1		
2959101	" "	SINK #2	
2959102	" "	SINK #3	
2959103	" "	SINK #4	
2959104	" "	SINK #5	
2959105	" "	SINK #6	
2959106	" "	SINK #7	

Comments:

06/17/23 9:02

EASTERN ANALYTICAL SERVICES, INC.
BULK SAMPLE DATA SHEET

Date Collected: 10/17/23 EAS Client: RayCom
 Collected By: E Coen Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____ RE: _____
 Signature: _____ Client Project Number/Name: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959107	HS Loading Dock Entrance - Kitchen - Sink # 8		1B/C
2959109	HS Serving Line - Sink		
2959109	HS ICE Machine (Combine Samples)		
2959110	Coffee Maker		
2959111	H106 (Bathroom) Sink		
2959112	Commons Water Fountain - Bubble		
2959113	" " " - Bottle Filler		
2959114	" " " - Bubble		
2959115	Girls Office - Sink		
2959116	Commons Girls Bathroom - Sink # 3		

Comments:

OC11723

9:02
 BULKDATA.FRM
 04/16/2014

EASTERN ANALYTICAL SERVICES, INC.
BULK SAMPLE DATA SHEET

Date Collected: 10/17/23 EAS Client: Regem
 Collected By: C. Carr Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____ RE: _____
 Signature: _____ Client Project Number/Name: _____

Turn - 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959117	Commons - Boys Bathroom - Sink #1		120
2959118	" " " " #2		
2959119	" " " " #3		
2959120	" " " " #4		
2959121	Nurses Office Water Cooler		
2959122	" " Main-Sink		
2959123	" " Room #4 - Sink		
2959124	Auditorium Water Fountain Upper - Bubble		
2959125	" " " " Lower - Bubble		
2959126	" " Mens Bathroom Sink #2		

Comments: _____

OCT 17 '23 9:02

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/17/23 EAS Client: Roysum
 Collected By: E COEN Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____ Client Project Number/Name: _____
 Time: _____ RE: _____
 Signature: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959127	31 Auditorium MEN'S Bathroom Sink#3	IBC	
2959128	32 " Girls Bathroom Sink#1		
2959129	33 " " " Sink#2		
2959130	34 " " " Sink#3		
2959131	35 " " " Sink#4		
2959132	36 HS Main Office Copy Room - Water Cooler		
2959133	37 " " " Sink		
2959134	38 Hallway Water Fountain NEAR H221 - Bubble		
2959135	39 Room 202 Sink#1		
2959136	40 " " Sink#15 (TEACHER DESK)		

Comments: _____

OCT17'23 9:02

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/17/23 EAS Client: _____
 Collected By: ELC Address: _____
 Date Received: _____
 Date Analyzed By: _____
 Analyzed By: _____
 Time: _____ RE: _____
 Signature: _____ Client Project Number/Name _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959137	41 Science Prep Room - Sink#1	1720	
2959138	42 " " Sink#2		
2959139	43 H203 - Sink#13		
2959140	44 " - Sink#14		
2959141	45 H204 - Sink#7		
2959142	46 " - Sink#8		
2959143	47 H210A Sink		
2959144	48 Mens Bathroom Near H215 - Sink#1		
2959145	49 " " Sink#2		
2959146	50 H216 Sink#1		

Comments:

OCT 17 '23 9:02

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/17/23
 Collected By: E. Coccia
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: LogCom
 Address: _____
 Client Project Number/Name: _____
 RE: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other

Sample Number	Sample Location	Sample Description	Result
2959147	H2K Prep Room	SINK	1720
2959148	H217	SINK#1	
2959149	Athletic Dir. - Faculty Bathroom	SINK	
2959150	Library Office	Water cooler	SINK
2959151	MS Main Office	Water cooler	
2959152	"	" SINK	
2959153	"	" Faculty Bathroom	SINK
2959154	Boys Bathroom	NENE MS Main Office	SINK#1
2959155	"	"	SINK#2
2959156	MS Main Office	Hallway Water Fountain	BUBBLER STAVE#3

Comments: 10/17/23 9:02

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 10/17/23 EAS Client: Regcom
 Collected By: E. Leary Address: _____
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____ Client Project Number/Name: _____
 Time: _____ RE: _____
 Signature: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959157	M/S Main Office Hallway Water Fountain	BOTTLE FILLER	120
2959158	" " " " " "	Bubblee	
2959159	" " " " Girls Bathroom - SINK # 3		
2959160	Gymnasium Girls Bathroom - SINK		
2959161	" " Boys " - SINK		
2959162	" " Coaches Office Bathroom - SINK		
2959163	M101B - SINK		
2959164	Consumer Sciences - SINK # 1		
2959165	" " " " 2		
2959166	" " " " 3		

Comments:

OCT17'23 9:03

EASTERN ANALYTICAL SERVICES, INC.
BULK SAMPLE DATA SHEET

Date Collected: 10/17/23
 Collected By: E. Cerny
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regem
 Address: _____
 Client Project Number/Name: _____
 RE: _____

Turn- 03 Hr 06 Hr
 Around 12 Hr 24 Hr
 30 Hr 48 Hr
 72 Hr 96 Hr
 5 Day Other _____

Sample Number	Sample Location	Sample Description	Result
2959167			
71	Consumer Sciences - Sink #4		120
2959168			
72	MIOB Sink #2		
2959169			
73	Faculty Bathroom Near M211 - Sink		
2959170			
74	Faculty Room " " Water Cooler		
2959171			
75	" " " Sink		
2959172			
76	Boys Bathroom Near M202 - Sink #1		
2959173			
77	" " " Sink #3		
2959174			
78	Hallway Water Fountain Near Boys Bathroom - Bubble		
2959175			
79	" " " Girls Bathroom - Bubble		
2959176			
80	Blank		

Comments: _____

Appendix C
Remediation Corrective Actions

Remediation/ Corrective Actions

HS/MS Water Fixtures that exceeded the NYSDOH Action Level of 0.005mg/L

Sample #	Building	Sample location	Fixture	Results (mg/L)	Date Resampled	Remediation Method	Corrective Actions
14	HS/MS	Cafeteria serving Line	Coffee Maker	0.011	Required	Required	Disconnected - Removed from Service
19	HS/MS	Gina's Office (The Commons Area)	Sink	0.020	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
32	HS/MS	Auditorium Girls Bathroom Room	Sink #1	0.020	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
33	HS/MS	Auditorium Girls Bathroom Room	Sink #2	0.017	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
34	HS/MS	Auditorium Girls Bathroom Room	Sink #3	0.006	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
39	HS/MS	Room 202	Sink #1	0.006	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
40	HS/MS	Room 202	Sink #15 (Teacher's Desk)	0.014	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
41	HS/MS	Science Prep Room	Sink #1	0.018	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
42	HS/MS	Science Prep Room	Sink #1	0.006	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
43	HS/MS	H203	Sink #13	0.021	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
44	HS/MS	H203	Sink #14	0.028	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
45	HS/MS	H204	Sink #7	0.314	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
46	HS/MS	H204	Sink #8	0.013	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
50	HS/MS	H216	Sink #1	0.044	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.

51	HS/MS	H216 Prep Room	Sink	0.024	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
71	HS/MS	Consumer Sciences	Sink #4	0.013	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
85	HS/MS	M200	Sink #2	0.068	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
86	HS/MS	M201	Sink (Teacher's Desk)	0.058	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
96	HS/MS	M211	Sink #2	0.022	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.

Sample #	Building	Sample location	Fixture	Results (mg/L)	Date Resampled	Remediation Method	Corrective Actions
18	Ridge Street	Room 111	Sink	0.006	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
40	Ridge Street	Room 500	Sink	0.054	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
61	Ridge Street	Cafeteria Pot Filler	Pot Filler	0.053	NA	NA	Disconnected - Removed from Service
125	Ridge Street	Room 315	Sink	0.007	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
126	Ridge Street	Room 314	Sink	0.014	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.
127	Ridge Street	Resources Room Kitchen	Sink	0.061	NA	NA	Sign posted in accordance with 10 NYCRR Subpart 67-4.