





## Analysis Report

Total Lead by ICP-MS

**Chain of Custody:** Pb-0059

**Facility:** Gainesville R-V

**Sample Matrix:** Water

**Method of Analysis:** EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0059-001	GNV-GYM-COAC-RRF-PS-001	NSPCR			
Pb-0059-002	GNV-GYM-COAC-RRF-MTP-PS-002	9/8/2023	Draw	ND	1.0
Pb-0059-003	GNV-JH-13HALL-RRFG1-PS-003	NSPCR			
Pb-0059-004	GNV-JH-13HALL-RRFG2-PS-004	NSPCR			
Pb-0059-005	GNV-JH-13HALL-DFR-PS-005	9/8/2023	Draw	1.71	1.0
Pb-0059-006	GNV-JH-13HALL-DWR PS-006	9/8/2023	Draw	3.14	1.0
Pb-0059-007	GNV-JH-13HALL-DFL PS-007	9/8/2023	Draw	2.18	1.0
Pb-0059-008	GNV-JH-13HALL-DWL PS-008	9/8/2023	Draw	3.40	1.0
Pb-0059-009	GNV-JH-RM13-SCI-HS PS-009	NSPCR			
Pb-0059-010	GNV-RM21-ART-HS1 PS-010	NSPCR			
Pb-0059-011	GNV-RM21-ART-HS2 PS-011	NSPCR			
Pb-0059-012	GNV-RM21-ART-HS3 PS-012	NSPCR			
Pb-0059-013	GNV-RM21-ART-HS4 PS-013	NSPCR			
Pb-0059-014	GNV-RM21-ART-HS5 PS-014	NSPCR			
Pb-0059-015	GNV-RM21-ART-HS6 PS-015	NSPCR			
Pb-0059-016	GNV-RM21-ART-HS7 PS-016	NSPCR			
Pb-0059-017	GNV-RM21-ART-HS8 PS-017	NSPCR			
Pb-0059-018	GNV-TCHR-LNGE-HS PS-018	NSPCR			
Pb-0059-019	GNV-CAFÉ-HALL-RRFGR PS-019	NSPCR			
Pb-0059-020	GNV-CAFÉ-HALL-RRFGL PS-020	NSPCR			
Pb-0059-021	GNV-CAFÉ-HALL-RRFBR PS-021	NSPCR			
Pb-0059-022	GNV-CAFÉ-HALL-RRFBL PS-022	NSPCR			
Pb-0059-023	GNV-CAFÉ-HALL-DF PS-023	9/8/2023	Draw	ND	1.0
Pb-0059-024	GNV-CAFÉ-HALL-DW PS-024	9/8/2023	Draw	ND	
Pb-0059-025	GNV-STFF-RRFR PS-025	NSPCR			
Pb-0059-026	GNV-STFF-RRFL PS-026	NSPCR			
Pb-0059-027	GNV-STFF-IM PS-027	9/8/2023	Draw	ND	1.0
Pb-0059-028	GNV-JAN-HS PS-028	NSPCR			
Pb-0059-029	GNV-FACS-FP1 PS-029	NSPCR			
Pb-0059-030	GNV-FACS-FP-SC1 PS-030	NSPCR			
Pb-0059-031	GNV-FACS-FP2 PS-031	NSPCR			
Pb-0059-032	GNV-FACS-FP-SC2 PS-032	NSPCR			
Pb-0059-033	GNV-FACS-FP3 PS-033	NSPCR			
Pb-0059-034	GNV-FACS-FP-SC3 PS-034	NSPCR			
Pb-0059-035	GNV-FACS-FP4 PS-035	NSPCR			
Pb-0059-036	GNV-FACS-FP-SC4 PS-036	NSPCR			

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



## Analysis Report

Total Lead by ICP-MS

**Chain of Custody:** Pb-0059  
**Facility:** Gainesville R-V

**Sample Matrix:** Water  
**Method of Analysis:** EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0059-037	GNV-FACS-HALL-DF PS-037	9/8/2023	Draw	ND	1.0
Pb-0059-038	GNV-FACS-HALL-DW PS-038	9/8/2023	Draw	ND	1.0
Pb-0059-039	GNV-SCI-HS PS-039	NSPCR			
Pb-0059-040	GNV-KITCH-HS PS-040	9/8/2023	Draw	4.63	1.0
Pb-0059-041	GNV-KITCH-FP1 PS-041	9/8/2023	Draw	1.80	1.0
Pb-0059-042	GNV-KITCH-FP2 PS-042	9/8/2023	Draw	ND	1.0
Pb-0059-043	GNV-KITCH-SC PS-043	9/8/2023	Draw	1.28	1.0
Pb-0059-044	GNV-RM18-AG-HS1 PS-044	NSPCR			
Pb-0059-045	GNV-RM18-AG-HS2 PS-045	NSPCR			
Pb-0059-046	GNV-RM18-AG-HS3 PS-046	NSPCR			
Pb-0059-047	GNV-RM18-AG-RRFR PS-047	NSPCR			
Pb-0059-048	GNV-RM18-AG-RRFL PS-048	NSPCR			
Pb-0059-049	GNV-RM18-AG-DF PS-049	9/8/2023	Draw	ND	1.0
Pb-0059-050	GNV-RM18-AG-DW PS-050	9/8/2023	Draw	1.17	1.0
Pb-0059-051	GNV-SUPER-OFF-RRFG PS-051	NSPCR			
Pb-0059-052	GNV-SUPER-OFF-RRFB PS-052	NSPCR			
Pb-0059-053	GNV-SUPER-OFF-DF PS-053	NSPCR			
Pb-0059-054	GNV-AUTO-HS1 PS-054	NSPCR			
Pb-0059-055	GNV-AUTO-HS2 PS-055	NSPCR			
Pb-0059-056	GNV-AUTO-HS3 PS-056	NSPCR			
Pb-0059-057	GNV-AUTO-RRF PS-057	NSPCR			
Pb-0059-058	GNV-AUTO-DW PS-058	9/8/2023	Draw	1.73	1.0
Pb-0059-059	GNV-GRNHS-HS PS-059	NSPCR			
Pb-0059-060	GNV-GRNHS-SC PS-060	NSPCR			
Pb-0059-061	GNV-GRNHS-OUT-SPGT PS-061	NSPCR			
Pb-0059-062	GNV-BUS-BARN-HS1 PS-062	NSPCR			
Pb-0059-063	GNV-BUS-BARN-HS2 PS-063	NSPCR			
Pb-0059-064	GNV-GRN-BLDG-HS PS-064	NSPCR			
Pb-0059-065	GNV-GRY-BLDG-SPGT PS-065	NSPCR			
Pb-0059-066	GNV-GRY-BLDG-SPGT-MTP PS-066	NSPCR			
Pb-0059-067	GNV-GRY-BLDG-RRF PS-067	NSPCR			
Pb-0059-068	GNV-GRY-BLDG-RRFGR PS-068	NSPCR			
Pb-0059-069	GNV-GRY-BLDG-RRFGL PS-069	NSPCR			
Pb-0059-070	GNV-GRY-BLDG-RRFBR PS-070	NSPCR			
Pb-0059-071	GNV-GRY-BLDG-RRFBL PS-071	NSPCR			
Pb-0059-072	GNV-FEMA-RRFGR PS-072	NSPCR			

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



## Analysis Report

Total Lead by ICP-MS

**Chain of Custody:** Pb-0059  
**Facility:** Gainesville R-V

**Sample Matrix:** Water  
**Method of Analysis:** EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0059-073	GNV-FEMA-RRFGL PS-073	NSPCR			
Pb-0059-074	GNV-FEMA-RRFBR PS-074	NSPCR			
Pb-0059-075	GNV-FEMA-RRFBL PS-075	NSPCR			
Pb-0059-076	GNV-FEMA-DFR PS-076	9/8/2023	Draw	ND	1.0
Pb-0059-077	GNV-FEMA-DFL PS-077	9/8/2023	Draw	ND	1.0
Pb-0059-078	GNV-FEMA-DW PS-078	9/8/2023	Draw	ND	1.0
Pb-0059-079	GNV-FEMA-CONC-FP PS-079	9/8/2023	Draw	ND	1.0
Pb-0059-080	GNV-FEMA-GLKRM-HSR PS-080	NSPCR			
Pb-0059-081	GNV-FEMA-GLKRM-HSL-MTP PS-081	9/8/2023	Draw	ND	1.0
Pb-0059-082	GNV-FEMA-GLKRM-HSL PS-082	NSPCR			
Pb-0059-083	GNV-FEMA-GLKRM-SH PS-083	NSPCR			
Pb-0059-084	GNV-FEMA-BLKRM-HSR PS-084	NSPCR			
Pb-0059-085	GNV-FEMA-BLKRM-HSL PS-085	NSPCR			
Pb-0059-086	GNV-FEMA-BLKRM-SH PS-086	NSPCR			
Pb-0059-087	GNV-PRIN-OFF-RRF PS-087	NSPCR			
Pb-0059-088	GNV-PREK-FP PS-088	9/8/2023	Draw	ND	1.0
Pb-0059-089	GNV-PREK-HS PS-089	9/8/2023	Draw	ND	1.0
Pb-0059-090	GNV-PREK-RRFG PS-090	9/8/2023	Draw	2.16	1.0
Pb-0059-091	GNV-PREK-RRFB PS-091	9/8/2023	Draw	2.38	1.0
Pb-0059-092	GNV-ELEM-KITCH-FP PS-092	9/8/2023	Draw	1.70	1.0
Pb-0059-093	GNV-ELEM-KITCH-SC PS-093	9/8/2023	Draw	ND	1.0
Pb-0059-094	GNV-ELEM-KITCH-HS PS-094	9/8/2023	Draw	1.21	1.0
Pb-0059-095	GNV-ELEM-MAIN-DFR PS-095	9/8/2023	Draw	ND	1.0
Pb-0059-096	GNV-ELEM-MAIN-DWR PS-096	9/8/2023	Draw	ND	1.0
Pb-0059-097	GNV-ELEM-MAIN-DFL PS-097	9/8/2023	Draw	ND	1.0
Pb-0059-098	GNV-ELEM-MAIN-DWL PS-098	9/8/2023	Draw	ND	1.0
Pb-0059-099	GNV-ELEM-5TH-HALL-DFR PS-099	9/8/2023	Draw	ND	1.0
Pb-0059-100	GNV-ELEM-5TH-HALL-DWR PS-100	9/8/2023	Draw	ND	1.0
Pb-0059-101	GNV-ELEM-5TH-HALL-DFL PS-101	9/8/2023	Draw	ND	1.0
Pb-0059-102	GNV-ELEM-5TH-HALL-DWL PS-102	9/8/2023	Draw	ND	1.0
Pb-0059-103	GNV-ELEM-KHALL-DWR PS-103	9/8/2023	Draw	ND	1.0
Pb-0059-104	GNV-ELEM-KHALL-DFL PS-104	9/8/2023	Draw	ND	1.0
Pb-0059-105	GNV-ELEM-KHALL-DWL PS-105	9/8/2023	Draw	ND	1.0
Pb-0059-106	GNV-ELEM-RM21-IM PS-106	9/8/2023	Draw	ND	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.