

May 13, 2021

Mr. James Hart
North Tonawanda City School District
Director of Facilities
176 Walck Road
North Tonawanda, New York 14120

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Hart:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the North Tonawanda City School District, including:

- North Tonawanda Middle School – 455 Meadow Drive, North Tonawanda, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 10, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 17 sources of potable water in the Middle School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to North Tonawanda City School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

North Tonawanda City School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of March 10, 2021

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- North Tonawanda Middle School – 455 Meadow Drive, North Tonawanda, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Middle School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Middle School	3/10/2021	91	74	17	N/A	N/A

** Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.3-13	Room 120	Sink	38.8
185.3-14	Room 120	Bubbler	49.8
185.3-15	Room 117	Sink	34.1
185.3-16	Room 117	Bubbler	47.5
185.3-17	Room 115	Sink	137
185.3-18	Room 115	Bubbler	399
185.3-23	Room 112	Bubbler	27.0
185.3-25	Room 110	Bubbler	53.8
185.3-28	Room 103	Sink	77.0
185.3-30	Room 102	Sink	51.8
185.3-31	Room 102	Bubbler	40.5
185.3-40	Room 135	Sink	19.5
185.3-48	Room 137	Sink	16.2
185.3-50	Room 142	Sink	31.0
185.3-52	Room 139	Sink	26.5
185.3-54	Room 144	Sink	38.3
185.3-61	Kitchen 148 2 Bay Sink	Sink	24.6

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-03-03478

Received Date: 03/16/2021
Reported Date: 04/12/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455 Meadow Drive; North
Tonawanda, NY 14120

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03478-001	185.3-1	03/10/2021	FACS 121 SOUTH	1.22	04/08/2021	
21-03-03478-002	185.3-2	03/10/2021	FACS 121 SE	<1.00	04/08/2021	
21-03-03478-003	185.3-3	03/10/2021	FACS 121 NE	1.41	04/08/2021	
21-03-03478-004	185.3-4	03/10/2021	FACS 121 NORTH	<1.00	04/08/2021	
21-03-03478-005	185.3-5	03/10/2021	BOYS LAV 126 L	6.72	04/08/2021	
21-03-03478-006	185.3-6	03/10/2021	BOYS LAV 126 R	6.76	04/08/2021	
21-03-03478-007	185.3-7	03/10/2021	GIRLS LAV 122 L	7.27	04/08/2021	
21-03-03478-008	185.3-8	03/10/2021	GIRLS LAV 122 R	3.77	04/08/2021	
21-03-03478-009	185.3-9	03/10/2021	FACS 119 SOUTH	<1.00	04/08/2021	
21-03-03478-010	185.3-10	03/10/2021	FACS 119 SE	<1.00	04/08/2021	
21-03-03478-011	185.3-11	03/10/2021	FACS 119 NE	<1.00	04/08/2021	
21-03-03478-012	185.3-12	03/10/2021	FACS 119 NORTH	<1.00	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03478

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455 Meadow Drive; North Tonawanda, NY 14120

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03478-013	185.3-13	03/10/2021	ROOM 120	38.8	04/08/2021	
21-03-03478-014	185.3-14	03/10/2021	ROOM 120	49.8	04/08/2021	
21-03-03478-015	185.3-15	03/10/2021	ROOM 117	34.1	04/08/2021	
21-03-03478-016	185.3-16	03/10/2021	ROOM 117	47.5	04/08/2021	
21-03-03478-017	185.3-17	03/10/2021	ROOM 115	137	04/08/2021	
21-03-03478-018	185.3-18	03/10/2021	ROOM 115	399	04/08/2021	
21-03-03478-019	185.3-19	03/10/2021	BOILER ROOM 113 FACULTY LAV	4.30	04/08/2021	
21-03-03478-020	185.3-20	03/10/2021	NURSE 114 MAIN	<1.00	04/08/2021	
21-03-03478-021	185.3-21	03/10/2021	NURSE 114 LAV	1.21	04/08/2021	
21-03-03478-022	185.3-22	03/10/2021	ROOM 112	9.90	04/08/2021	
21-03-03478-023	185.3-23	03/10/2021	ROOM 112	27.0	04/08/2021	
21-03-03478-024	185.3-24	03/10/2021	ROOM 110	7.82	04/08/2021	
21-03-03478-025	185.3-25	03/10/2021	ROOM 110	53.8	04/08/2021	
21-03-03478-026	185.3-26	03/10/2021	WOMENS FAC LAV 106	2.67	04/08/2021	
21-03-03478-027	185.3-27	03/10/2021	MENS FAC LAV 108	7.18	04/08/2021	
21-03-03478-028	185.3-28	03/10/2021	ROOM 103	77.0	04/08/2021	
21-03-03478-029	185.3-30	03/10/2021	ROOM 102	51.8	04/08/2021	
21-03-03478-030	185.3-31	03/10/2021	ROOM 102	40.5	04/08/2021	
21-03-03478-031	185.3-32	03/10/2021	ROOM 101 L	1.81	04/08/2021	
21-03-03478-032	185.3-33	03/10/2021	ROOM 101 R	1.45	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03478

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455 Meadow Drive; North Tonawanda, NY 14120

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03478-033	185.3-34	03/10/2021	ROOM 100 L	2.13	04/08/2021	
21-03-03478-034	185.3-35	03/10/2021	ROOM 100 R	2.26	04/08/2021	
21-03-03478-035	185.3-36	03/10/2021	ROOM 125 LAV 125A	5.70	04/08/2021	
21-03-03478-036	185.3-37B	03/10/2021	DF BETWEEN 129/131	1.27	04/08/2021	
21-03-03478-037	185.3-38	03/10/2021	ROOM 131 FAR RIGHT	2.42	04/08/2021	
21-03-03478-038	185.3-40	03/10/2021	ROOM 135	19.5	04/08/2021	
21-03-03478-039	185.3-42	03/10/2021	GIRLS LAV 136 L	9.83	04/08/2021	
21-03-03478-040	185.3-43	03/10/2021	GIRLS LAV 135 C	6.70	04/08/2021	
21-03-03478-041	185.3-44	03/10/2021	GIRLS LAV 136 R	9.21	04/08/2021	
21-03-03478-042	185.3-45	03/10/2021	BOYS LAV 140 L	11.2	04/08/2021	
21-03-03478-043	185.3-46	03/10/2021	BOYS LAV 140 C	11.6	04/08/2021	
21-03-03478-044	185.3-47	03/10/2021	BOYS LAV 140 R	9.58	04/08/2021	
21-03-03478-045	185.3-48	03/10/2021	ROOM 137	16.2	04/08/2021	
21-03-03478-046	185.3-50	03/10/2021	ROOM 142	31.0	04/08/2021	
21-03-03478-047	185.3-52	03/10/2021	ROOM 139	26.5	04/08/2021	
21-03-03478-048	185.3-54	03/10/2021	ROOM 144	38.3	04/08/2021	
21-03-03478-049	185.3-56	03/10/2021	ROOM 141	11.9	04/08/2021	
21-03-03478-050	185.3-57	03/10/2021	ROOM 141	14.5	04/08/2021	
21-03-03478-051	185.3-58	03/10/2021	KITCHEN 148 CENTER PREP	1.88	04/08/2021	
21-03-03478-052	185.3-59	03/10/2021	KITCHEN 148 HANDWASH NEAR 146	1.98	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03478

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455 Meadow Drive; North Tonawanda, NY 14120

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03478-053	185.3-60	03/10/2021	KITCHEN LAV 148E	1.11	04/08/2021	
21-03-03478-054	185.3-61	03/10/2021	KITCHEN 148 2 BAY SINK	24.6	04/08/2021	
21-03-03478-055	185.3-62	03/10/2021	KITCHEN 148 3 BAY LEFT	2.48	04/08/2021	
21-03-03478-056	185.3-63	03/10/2021	KITCHEN 148 3 BAY RIGHT	2.60	04/08/2021	
21-03-03478-057	185.3-64	03/10/2021	KITCHEN 148 SINGLE SINK SOUTH WALL	3.68	04/08/2021	
21-03-03478-058	185.3-65	03/10/2021	KITCHEN 148 HANDWASH NEAR SERVING	1.43	04/08/2021	
21-03-03478-059	185.3-66	03/10/2021	KITCHEN 148 SERVING NORTH	6.32	04/08/2021	
21-03-03478-060	185.3-67	03/10/2021	KITCHEN 148 SERVING SOUTH	3.40	04/08/2021	
21-03-03478-061	185.3-68	03/10/2021	KITCHEN DISH ROOM 148A SPRAYER	<1.00	04/08/2021	
21-03-03478-062	185.3-69	03/10/2021	KITCHEN DISH ROOM 148A HANDWASH	1.18	04/08/2021	
21-03-03478-063	185.3-70	03/10/2021	FACULTY ROOM 151	1.23	04/08/2021	
21-03-03478-064	185.3-71	03/10/2021	BAND ROOM 188	<1.00	04/08/2021	
21-03-03478-065	185.3-72	03/10/2021	ROOM 159	1.66	04/08/2021	
21-03-03478-066	185.3-73	03/10/2021	ROOM 161	1.91	04/08/2021	
21-03-03478-067	185.3-75	03/10/2021	ROOM 154	1.18	04/08/2021	
21-03-03478-068	185.3-76	03/10/2021	GIRLS LAV 156 L	<1.00	04/08/2021	
21-03-03478-069	185.3-77	03/10/2021	GIRLS LAV 156 C	<1.00	04/09/2021	
21-03-03478-070	185.3-78	03/10/2021	GIRLS LAV 156 R	<1.00	04/09/2021	
21-03-03478-071	185.3-79	03/10/2021	BOYS LAV 160 L	<1.00	04/09/2021	
21-03-03478-072	185.3-80	03/10/2021	BOYS LAV 160 C	1.32	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03478

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455
Meadow Drive; North Tonawanda, NY 14120

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03478-073	185.3-82B	03/10/2021	DF OUTSIDE CAFETERIA	<1.00	04/09/2021	
21-03-03478-074	185.3-83	03/10/2021	TECH ROOM 170 L	3.06	04/09/2021	
21-03-03478-075	185.3-84	03/10/2021	TECH ROOM 170 C	3.60	04/09/2021	
21-03-03478-076	185.3-85	03/10/2021	TECH ROOM 170 R	4.40	04/09/2021	
21-03-03478-077	185.3-86	03/10/2021	TECH ROOM 172 L	6.26	04/09/2021	
21-03-03478-078	185.3-87	03/10/2021	TECH ROOM 172 C	7.26	04/09/2021	
21-03-03478-079	185.3-88	03/10/2021	TECH ROOM 172 R	5.99	04/09/2021	
21-03-03478-080	185.3-89	03/10/2021	MEN'S LAV 173 L	1.27	04/09/2021	
21-03-03478-081	185.3-90	03/10/2021	MEN'S LAV 173 R	1.55	04/09/2021	
21-03-03478-082	185.3-91B	03/10/2021	DF BETWEEN 173/175	<1.00	04/09/2021	
21-03-03478-083	185.3-92	03/10/2021	WOMENS LAV 175 L	1.29	04/09/2021	
21-03-03478-084	185.3-93	03/10/2021	WOMENS LAV 175 R	1.56	04/09/2021	
21-03-03478-085	185.3-94	03/10/2021	GYM FAC LAV 179	<1.00	04/09/2021	
21-03-03478-086	185.3-95	03/10/2021	GYM FAC LAV 183	<1.00	04/09/2021	
21-03-03478-087	185.3-96	03/10/2021	DF OUTSIDE GYM	<1.00	04/09/2021	
21-03-03478-088	185.3-97	03/10/2021	BOYS LOCKER 177 LEFT	<1.00	04/09/2021	
21-03-03478-089	185.3-98	03/10/2021	BOYS LOCKER 177 RIGHT	<1.00	04/09/2021	
21-03-03478-090	185.3-99	03/10/2021	GIRLS LOCKER 181 LEFT	<1.00	04/09/2021	
21-03-03478-091	185.3-100	03/10/2021	GIRLS LOCKER 181 RIGHT	<1.00	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03478

Project/Test Address: 2020L-185.3; North Tonawanda Middle School; 455
Meadow Drive; North Tonawanda, NY 14120

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021
Revised April 02, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK
STATE OF
OPPORTUNITY.

Department
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.3

Client: North Tonawanda CSD Contact: Jim Hart

Building: North Tonawanda Middle School Location: 455 Meadow Drive North Tonawanda, NY 14120

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.3-1	Facs 121 South	S	2:45
185.3-2	Facs 121 SE	S	2:46
185.3-3	Facs 121 NE	S	2:47
185.3-4	Facs 121 North	S	2:48
185.3-5	Boys Lav 126 L	S	2:49
185.3-6	Boys Lav 126 R	S	2:50
185.3-7	Girls Lav 122 L	S	2:51
185.3-8	Girls Lav 122 R	S	2:52
185.3-9	Facs 119 South	S	2:53
185.3-10	Facs 119 SE	S	2:54
185.3-11	Facs 119 NE	S	2:55
185.3-12	Facs 119 North	S	2:56
185.3-13	Room 120	S	2:57
185.3-14	Room 120	B	2:58
185.3-15	Room 117	S	2:59
185.3-16	Room 117	B	3:00
185.3-17	Room 115	S	3:01
185.3-18	Room 115	B	3:02

21-03-03478



Due Date:

04/13/2021

(Tuesday)

AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/10/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3-16-21 Time: 4:05 pm

Sample Login (Name / Lab): Trace Bloom / Trace Bloom Date: 4/5/21 Time: 9:45 AM

Analysis (Name / Lab): Young Oee Date: 4/9/21 Time: 1:05 AM

QA/QC Review (Name / Lab): Michael Date: 4/12/21 Time: 5pm

Archived / Released: QA/QC InterLAB Use: Date: Time:



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLNENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.3

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda Middle School

Location: 455 Meadow Drive North Tonawanda, NY 14120

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.3-19	Boiler Room 113 Faculty Lav	S	3:03
185.3-20	Nurse 114 Main	S	3:04
185.3-21	Nurse 114 Lav	S	3:05
185.3-22	Room 112	S	3:06
185.3-23	Room 112	B	3:07
185.3-24	Room 110	S	3:08
185.3-25	Room 110	B	3:09
185.3-26	Womens Fac Lav 106	S	3:10
185.3-27	Men's Fac Lav 108	S	3:11
185.3-28	Room 103	S	3:12
185.3-30	Room 102	S	3:13
185.3-31	Room 102	B	3:14
185.3-32	Room 101 L	S	3:15
185.3-33	Room 101 R	S	3:16
185.3-34	Room 100 L	S	3:17
185.3-35	Room 100 R	S	3:18
185.3-36	Room 125 Lav (125A)	S	3:19
185.3-37B	DF Between 129/131	DFB	3:20

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/10/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KTHARRIS Date: 3/16/21 Time: 4:05 PM

Sample Login (Name / Lab): Traici Bloom / Traici Bloom Date: 4/5/21 Time: 948 AM

Analysis (Name / Lab): Gary Ocel Date: 4/9/21 Time: 1:05 PM

QA/QC Review (Name / Lab): Mehmet Date: 4/14/21 Time: 5pm

Archived / Released: QA/QC InterLAB Use: Date: Time:



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.3

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda Middle School

Location: 455 Meadow Drive North Tonawanda, NY 14120

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.3-38	Room 131 Far Right	S	3:21
185.3-40	Room 135	S	3:22
185.3-42	Girls Lav 136 L	S	3:23
185.3-43	Girls Lav 135 C	S	3:24
185.3-44	Girls Lav 136 R	S	3:25
185.3-45	Boys Lav 140 L	S	3:26
185.3-46	Boys Lav 140 C	S	3:27
185.3-47	Boys lav 140 R	S	3:28
185.3-48	Room 137	S	3:29
185.3-50	Room 142	S	3:30
185.3-52	Room 139	S	3:31
185.3-54	Room 144	S	3:32
185.3-56	Room 141	S	3:33
185.3-57	Room 141	B	3:34
185.3-58	Kitchen 148 Center Prep	S	3:35
185.3-59	Kitchen 148 Handwash Near 146	S	3:36
185.3-60	Kitchen Lav 148E	S	3:37
185.3-61	Kitchen 148 2 Bay Sink	S	3:38

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/10/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3.16.21 Time: 4:05 pm

Sample Login (Name / Lab): Traci Blom / Traci Blom Date: 4/5/21 Time: 9:54 AM

Analysis (Name / Lab): Young D Date: 4/9/21 Time: 1:00 PM

QA/QC Review (Name / Lab): Meluh Date: 4/12/21 Time: 5pm

Archived / Released: QA/QC InterLAB Use: Date: Time:



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.3

Client: North Tonawanda CSD Contact: Jim Hart

Building: North Tonawanda Middle School Location: 455 Meadow Drive North Tonawanda, NY 14120

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.3-62	Kitchen 148 3 Bay Left	S	3:39
185.3-63	Kitchen 148 3 Bay Right	S	3:40
185.3-64	Kitchen 148 Single Sink South Wall	S	3:41
185.3-65	Kitchen 148 Handwash Near Serving	S	3:42
185.3-66	Kitchen 148 Serving North	S	3:43
185.3-67	Kitchen 148 Serving South	S	3:44
185.3-68	Kitchen Dish Room 148A Sprayer	S	3:45
185.3-69	'Kitchen Dish Room 148A Handwash	S	3:46
185.3-70	Faulty Room 151	S	3:47
185.3-71	Band Room 188	S	3:48
185.3-72	Room 159	S	3:49
185.3-73	Room 161	S	3:50
185.3-75	Room 154	S	3:51
185.3-76	Girls Lav 156 L	S	3:52
185.3-77	Girls Lav 156 C	S	3:53
185.3-78	Girls Lav 156 R	S	3:54
185.3-79	Boys Lav 160 L	S	3:55
185.3-80	Boys Lav 160 C	S	3:56

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/10/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KTHABBY Date: 3-16-21 Time: 4:05 pm

Sample Login (Name / Lab): Traci Bloom / Fran Bloom Date: 4/6/21 Time: 8:00 AM

Analysis (Name / Lab): Young O'ee Date: 4/9/21 Time: 1:05 PM

QA/QC Review (Name / Lab): Meluh Date: 4/12/21 Time: 5pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.3

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda Middle School

Location: 455 Meadow Drive North Tonawanda, NY 14120

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.3-82B	DF Outside Cafeteria	DFB	3:57
185.3-83	Tech Room 170 L	S	3:58
185.3-84	Tech Room 170 C	S	3:59
185.3-85	Tech Room 170 R	S	4:00
185.3-86	Tech Room 172 L	S	4:01
185.3-87	Tech Room 172 C	S	4:02
185.3-88	Tech Room 172 R	S	4:03
185.3-89	Men's Lav 173 L	S	4:04
185.3-90	Men's Lav 173 R	S	4:05
185.3-91B	DF Between 173/175	DFB	4:06
185.3-92	Women Lav 175 L	S	4:07
185.3-93	Womens Lav 175 R	S	4:08
185.3-94	Gym Fac Lav 179	S	4:09
185.3-95	Gym Fac Lav 183	S	4:10
185.3-96	DF Outside Gym	DF	4:11
185.3-97	Boys Locker 177 Left	S	4:12
185.3-98	Boys Locker 177 Right	S	4:13
185.3-99	Girls Locker 181 Left	S	4:14

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/10/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): RTM BRS Date: 3/16/21 Time: 4:05pm

Sample Login (Name / Lab): Traai Blom / Vlier Blom Date: 4/6/21 Time: 8:03AM

Analysis (Name / Lab): Mary O'Neil Date: 4/9/21 Time: 1:05 AM

QA/QC Review (Name / Lab): M. O'Neil Date: 4/12/21 Time: 5pm

Archived / Released: QA/QC InterLAB Use: Date: Time:



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM