

May 13, 2021

Mr. James Hart  
North Tonawanda City School District  
Director of Facilities  
176 Walck Road  
North Tonawanda, New York 14120

**RE: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Hart:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the North Tonawanda City School District, including:

- Drake Elementary – 388 Drake Drive, North Tonawanda, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 11, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 18 sources of potable water in Drake Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to North Tonawanda City School District.

Sincerely,  
Stohl Environmental, LLC.



Eric Henderson Jr.  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**North Tonawanda City School District**

**Prepared by:**



**3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**

**Conditions as of March 11, 2021**

## **Summary Tabulation**

### **Lead in Drinking Water Investigation**

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Drake Elementary – 388 Drake Drive, North Tonawanda, New York.

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Drake Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Drake Elementary	3/11/2021	76	58	18	N/A	N/A

\*\* Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

**Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:**

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.4-3	Room 24	Sink	27.4
185.4-4	Room 24	Bubbler	42.4
185.4-5	Room 25	Sink	17.7
185.4-6	Room 25	Bubbler	28.0
185.4-7	Room 22	Sink	17.8
185.4-8	Room 22	Bubbler	26.2
185.4-11	Room 21	Sink	39.2
185.4-13	Room 20 Large	Sink	47.1
185.4-14	Room 20	Bubbler	46.7
185.4-14.5	Room 20 By Bubbler	Sink	67.4
185.4-23	Boys Locker Room Bathroom	Sink	32.6
185.4-25	Old Girls Locker Room Bathroom	Sink	61.6
185.4-26	Room 17	Sink	38.1
185.4-28.5	Room 13	Sink	17.4
185.4-32	Room 18 Main	Sink	34.3
185.4-36	Room 16 Main	Sink	17.2
185.4-52B	Hallway Between Staff Lavs	Bottle Fill	N/A
185.4-65	Room 3	Bubbler	40.2
185.4-69	Room 4 Main	Sink	852

N/A = Not Analyzed. The laboratory received the sample empty and was not able to be analyzed. Location should be resampled and analyzed at a later date.

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports by Building





Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

Report Number: 21-03-03489  
Received Date: 03/16/2021  
Reported Date: 04/13/2021  
Sampled By: Christine Schultz  
Tech Certification #:

Project/Test Address: 2020L-185.4; Drake Elementary; 388 Drake Drive; North Tonawanda, NY

Client Number:  
33-5980

# Laboratory Results

Fax Number:  
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03489-001	185.4-3	03/11/2021	24	27.4	04/08/2021	
21-03-03489-002	185.4-4	03/11/2021	24	42.4	04/08/2021	
21-03-03489-003	185.4-5	03/11/2021	25	17.7	04/08/2021	
21-03-03489-004	185.4-6	03/11/2021	25	28.0	04/08/2021	
21-03-03489-005	185.4-7	03/11/2021	22	17.8	04/08/2021	
21-03-03489-006	185.4-8	03/11/2021	22	26.2	04/08/2021	
21-03-03489-007	185.4-9	03/11/2021	23	9.00	04/08/2021	
21-03-03489-008	185.4-11	03/11/2021	21	39.2	04/08/2021	
21-03-03489-009	185.4-13	03/11/2021	20 LARGE	47.1	04/08/2021	
21-03-03489-010	185.4-14	03/11/2021	20	46.7	04/08/2021	
21-03-03489-011	185.4-14.5	03/11/2021	20 BY BUB	67.4	04/08/2021	
21-03-03489-012	185.4-15	03/11/2021	GIRLS BATHROOM LEFT	2.27	04/08/2021	
21-03-03489-013	185.4-16	03/11/2021	GIRLS BATHROOM CENTER	1.84	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03489

Project/Test Address: 2020L-185.4; Drake Elementary; 388 Drake Drive; North  
Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03489-014	185.4-17	03/11/2021	GIRLS BATHROOM RIGHT	1.75	04/08/2021	
21-03-03489-015	185.4-18A	03/11/2021	HALLWAY	<1.00	04/08/2021	
21-03-03489-016	185.4-18B	03/11/2021	HALWAY	<1.00	04/08/2021	
21-03-03489-017	185.4-19	03/11/2021	BOYS BATHROOM LEFT	2.63	04/08/2021	
21-03-03489-018	185.4-20	03/11/2021	BOYS BATHROOM CENTER	2.81	04/08/2021	
21-03-03489-019	185.4-21	03/11/2021	BOYS BATHROOM RIGHT	2.42	04/08/2021	
21-03-03489-020	185.4-22	03/11/2021	BOYS LOCKER ROOM	8.88	04/08/2021	
21-03-03489-021	185.4-23	03/11/2021	BOYS LOCKER ROOM BATHROOM	32.6	04/08/2021	
21-03-03489-022	185.4-25	03/11/2021	OLD GIRLS LOCKER ROOM BATHROOM	61.6	04/08/2021	
21-03-03489-023	185.4-26	03/11/2021	17	38.1	04/08/2021	
21-03-03489-024	185.4-27	03/11/2021	15	3.93	04/08/2021	
21-03-03489-025	185.4-28	03/11/2021	13 LAV	10.3	04/08/2021	
21-03-03489-026	185.4-28.5	03/11/2021	13	17.4	04/09/2021	
21-03-03489-027	185.4-29	03/11/2021	11 MAIN	11.6	04/08/2021	
21-03-03489-028	185.4-30	03/11/2021	11	11.8	04/08/2021	
21-03-03489-029	185.4-32	03/11/2021	18 MAIN	34.3	04/08/2021	
21-03-03489-030	185.4-33	03/11/2021	18	3.61	04/08/2021	
21-03-03489-031	185.4-34	03/11/2021	18 LAV	2.27	04/08/2021	
21-03-03489-032	185.4-35	03/11/2021	STORAGE LAV SINK	5.42	04/08/2021	
21-03-03489-033	185.4-36	03/11/2021	16 MAIN	17.2	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03489

Project/Test Address: 2020L-185.4; Drake Elementary; 388 Drake Drive; North  
Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03489-034	185.4-37	03/11/2021	16	8.77	04/08/2021	
21-03-03489-035	185.4-38	03/11/2021	16 LAV	2.88	04/08/2021	
21-03-03489-036	185.4-39	03/11/2021	14 MAIN	1.20	04/08/2021	
21-03-03489-037	185.4-40	03/11/2021	14	<1.00	04/08/2021	
21-03-03489-038	185.4-41	03/11/2021	14 LAV	<1.00	04/08/2021	
21-03-03489-039	185.4-42	03/11/2021	10 MAIN	1.82	04/08/2021	
21-03-03489-040	185.4-43	03/11/2021	10	1.84	04/08/2021	
21-03-03489-041	185.4-44	03/11/2021	10 LAV	1.05	04/08/2021	
21-03-03489-042	185.4-45	03/11/2021	12 MAIN	1.35	04/08/2021	
21-03-03489-043	185.4-46	03/11/2021	12	1.39	04/08/2021	
21-03-03489-044	185.4-47	03/11/2021	12 LAV	<1.00	04/08/2021	
21-03-03489-045	185.4-48	03/11/2021	8 MAIN	1.94	04/08/2021	
21-03-03489-046	185.4-49	03/11/2021	8	4.81	04/08/2021	
21-03-03489-047	185.4-50	03/11/2021	8 LAV	<1.00	04/08/2021	
21-03-03489-048	185.4-51	03/11/2021	WOMEN'S STAFF BATHROOM	<1.00	04/08/2021	
21-03-03489-049	185.4-52A	03/11/2021	HALLWAY BETWEEN STAFF LAVS	1.20	04/08/2021	
21-03-03489-050	185.4-53	03/11/2021	MEN'S STAFF BATHROOM	1.73	04/08/2021	
21-03-03489-051	185.4-54	03/11/2021	FACULTY LOUNGE	5.81	04/08/2021	
21-03-03489-052	185.4-55A	03/11/2021	HALLWAY OUTSIDE FACULTY LOUNGE	<1.00	04/08/2021	
21-03-03489-053	185.4-55B	03/11/2021	HALLWAY OUTSIDE FACULTY LOUNGE	<1.00	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03489

Project/Test Address: 2020L-185.4; Drake Elementary; 388 Drake Drive; North  
Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03489-054	185.4-56	03/11/2021	MAIN OFFICE BATHROOM	4.44	04/08/2021	
21-03-03489-055	185.4-57	03/11/2021	1 MAIN	7.17	04/08/2021	
21-03-03489-056	185.4-59	03/11/2021	1 LAV	2.67	04/08/2021	
21-03-03489-057	185.4-60	03/11/2021	HEALTH OFFICE	2.30	04/08/2021	
21-03-03489-058	185.4-61	03/11/2021	HEALTH OFFICE LAV	2.78	04/08/2021	
21-03-03489-059	185.4-62	03/11/2021	2 MAIN	14.1	04/08/2021	
21-03-03489-060	185.4-63	03/11/2021	2 LAV	3.85	04/08/2021	
21-03-03489-061	185.4-64	03/11/2021	3 MAIN	4.48	04/08/2021	
21-03-03489-062	185.4-65	03/11/2021	3	40.2	04/08/2021	
21-03-03489-063	185.4-66	03/11/2021	3 LAV	3.41	04/08/2021	
21-03-03489-064	185.4-67	03/11/2021	5 MAIN	2.40	04/09/2021	
21-03-03489-065	185.4-68	03/11/2021	5 LAV	3.91	04/08/2021	
21-03-03489-066	185.4-69	03/11/2021	4 MAIN	852	04/12/2021	
21-03-03489-067	185.4-70	03/11/2021	4 LAV	3.16	04/08/2021	
21-03-03489-068	185.4-71	03/11/2021	7 MAIN	4.52	04/08/2021	
21-03-03489-069	185.4-73	03/11/2021	7 LAV	6.56	04/08/2021	
21-03-03489-070	185.4-74	03/11/2021	6 SPEECH ROOM LAV	5.27	04/08/2021	
21-03-03489-071	185.4-75	03/11/2021	KITCHEN SERVING SINGLE BAY	4.38	04/08/2021	
21-03-03489-072	185.4-76	03/11/2021	KITCHEN DISH ROOM 3 BAY	2.26	04/08/2021	
21-03-03489-073	185.4-77	03/11/2021	KITCHEN DISH ROOM SPRAYER	2.33	04/09/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03489

Project/Test Address: 2020L-185.4; Drake Elementary; 388 Drake Drive; North  
Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03489-074	185.4-78	03/11/2021	KITCHEN HANDWASH	3.35	04/08/2021	
21-03-03489-075	185.4-79	03/11/2021	KITCHEN LAV	6.24	04/08/2021	
21-03-03489-076	185.4-80	03/11/2021	SINGLE LAV OUTSIDE GYM BOYS LOCKER SIDE	5.18	04/08/2021	

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion

## 1.5 Laboratory Certifications



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022  
Issued April 01, 2021  
Revised April 02, 2021

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MS. JULIE DICKERSON  
ENVIRONMENTAL HAZARDS SERVICES, LLC  
7469 WHITEPINE ROAD  
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK  
STATE OF  
OPPORTUNITY.

Department  
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





**1.6 Chains of Custody**



### Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.4

1000 Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLNENVIRONMENTAL.COM

Client: North Tonawanda CSD Contact: Jim Hart

Building: Drake Elementary Location: 388 Drake Drive, North Tonawanda, NY

#### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X Turnaround 20 Days

Sample #	Location	Outlet Type	Time
185.4-3	24	s	2:12
185.4-4	24	b	2:13
185.4-5	25	s	2:14
185.4-6	25	b	2:15
185.4-7	22	s	2:16
185.4-8	22	b	2:17
185.4-9	23	s	2:18
185.4-11	21	s	2:19
185.4-13	20 Large	s	2:20
185.4-14	20	b	2:21
185.4-14.5	20 by Bub	s	2:22
185.4-15	girls bathroom left	s	2:23
185.4-16	girls Bathroom Center	s	2:24
185.4-17	girls bathroom right	s	2:25
185.4-18A	hallway	df	2:26
185.4-18B	hallway	dfb	2:27
185.4-19	boys bathroom left	s	2:28
185.4-20	boys bathroom center	s	2:29

21-03-03489



Due Date:  
04/13/2021  
(Tuesday)  
AE

#### Notes:

Please e-mail lab results to labs@stohlenv.com ☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT-TARRIS JAG Date: 3.16.21 Time: 4:25 pm

Sample Login (Name / Lab): Tina Bloom / Tina Bloom Date: 4/6/21 Time: 8:21 AM

Analysis (Name / Lab): Young Ode Date: 4/12/21 Time: 5:06 pm

QA/QC Review (Name / Lab): M. Chisholm Date: 4/13/21 Time: 3 pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_



## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.4

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Drake Elementary

Location: 388 Drake Drive, North Tonawanda, NY

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.4-21	boys bathroom right	s	2:30
185.4-22	boys locker room	s	2:31
185.4-23	boys locker room bathroom	s	2:32
185.4-25	Old girls locker room bathroom	s	2:33
185.4-26	17	s	2:34
185.4-27	15	s	2:35
185.4-28	13 lav	s	2:36
185.4-28.5	13	s	2:37
185.4-29	11 main	s	2:38
185.4-30	11	b	2:39
185.4-32	18 main	s	2:40
185.4-33	18	b	2:41
185.4-34	18 lav	s	2:42
185.4-35	storage lav sink	s	2:43
185.4-36	16 Main	s	2:44
185.4-37	16	b	2:45
185.4-38	16 lav	s	2:46
185.4-39	14 main	s	2:47

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3.16.21 Time: 4:25 pm

Sample Login (Name / Lab): Tracy Bloom / Tracy Bloom Date: 4/6/21 Time: 7:43 AM

Analysis (Name / Lab): Young Co Date: 4/12/21 Time: 5:06 pm

QA/QC Review (Name / Lab): M. H. Date: 4/13/21 Time: 3 pm

Archived / Released:            QA/QC InterLAB Use:            Date:            Time:



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.4

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Drake Elementary

Location: 388 Drake Drive, North Tonawanda, NY

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.4-40	14	b	2:48
185.4-41	14 lav	s	2:49
185.4-42	10 main	s	2:50
185.4-43	10	b	2:51
185.4-44	10 lav	s	2:52
185.4-45	12 main	s	2:53
185.4-46	12	b	2:54
185.4-47	12 lav	s	2:55
185.4-48	8 main	s	2:56
185.4-49	8	b	2:57
185.4-50	8 lav	s	2:58
185.4-51	women's staff bathroom	s	2:59
185.4-52A	hallway between staff lavs	df	3:00
185.4-52B	hallway between staff lavs	dfb	3:01
185.4-53	men's staff bathroom	s	3:02
185.4-54	faculty lounge	s	3:03
185.4-55A	hallway outside faculty lounge	df	3:04
185.4-55B	hallway outside faculty lounge	dfb	3:05

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT Harris Date: 3.16.21 Time: 4:25 pm

Sample Login (Name / Lab): Toni Bloom / Jan Bloom Date: 4/6/21 Time: 8:46 AM

Analysis (Name / Lab): Long Drel Date: 4/12/21 Time: 5:11 pm

QA/QC Review (Name / Lab): Munkel Date: 4/13/21 Time: 3 pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.4

Client: North Tonawanda CSD Contact: Jim Hart

Building: Drake Elementary Location: 388 Drake Drive, North Tonawanda, NY

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.4-56	Main office bathroom	s	3:06
185.4-57	1 Main	s	3:07
185.4-59	1 Lav	s	3:08
185.4-60	health office	s	3:09
185.4-61	health office lav	s	3:10
185.4-62	2 Main	s	3:11
185.4-63	2 Lav	s	3:12
185.4-64	3 Main	s	3:13
185.4-65	3	b	3:14
185.4-66	3 Lav	s	3:15
185.4-67	5 Main	s	3:16
185.4-68	5 Lav	s	3:17
185.4-69	4 Main	s	3:18
185.4-70	4 Lav	s	3:19
185.4-71	7 Main	s	3:20
185.4-73	7 Lav	s	3:21
185.4-74	6 speech room lav	s	3:22
185.4-75	kitchen serving single bay	s	3:23

### Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3-16-21 Time: 4:25 pm

Sample Login (Name / Lab): Traci Brown / Lisa Brown Date: 4/6/21 Time: 8:49 AM

Analysis (Name / Lab): Young D Date: 4/12/21 Time: 5:12 pm

QA/QC Review (Name / Lab): Meluh Date: 4/13/21 Time: 3pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



BLANK

BLANK



**3860 California Road, Orchard Park, New York 14127**

**PHONE (716) 312-0070 FAX (716) 312-8092**

**[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**