

May 13, 2021

Mr. James Hart
North Tonawanda City School District
Director of Facilities
176 Walck Road
North Tonawanda, New York 14120

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Hart:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the North Tonawanda City School District, including:

- Spruce Elementary – 195 Spruce Street, North Tonawanda, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 11, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 22 sources of potable water in Spruce Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to North Tonawanda City School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

North Tonawanda City School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of March 11, 2021

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Spruce Elementary – 195 Spruce Street, North Tonawanda, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Spruce Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***”, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Spruce Elementary	3/11/2021	81	59	22	N/A	N/A

** Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.7-4	Girls Locker Room Office	Sink	26.2
185.7-10	Boys Locker Room Office	Sink	15.6
185.7-20	Women's Bathroom in Receiving	Sink	21.3
185.7-21	Principal Office	Sink	33.0
185.7-22	Main Office	Sink	22.5
185.7-28	Faculty Room	Sink	15.8
185.7-31	Room 111	Bubbler	195
185.7-33	Room 113	Bubbler	20.6
185.7-34	Room 113 Bathroom	Sink	32.7
185.7-48	Room 137	Sink	23.5
185.7-64	Room 104 Bathroom	Sink	15.2
185.7-65	Room 104	Bubbler	66.1
185.7-66	Room 104	Sink	35.5
185.7-76	Room 212	Sink	53.1
185.7-78	Room 215	Sink	28.7
185.7-95	Room 206	Bubbler	25.2
185.7-96	Room 203	Sink	20.5
185.7-97	Room 203	Bubbler	25.5
185.7-98	Room 204	Sink	16.8
185.7-99	Room 204	Bubbler	25.0
185.7-100	Room 201	Sink	15.3
185.7-101	Room 201	Bubbler	32.1

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-03-03428

Received Date: 03/16/2021
Reported Date: 04/09/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-185.7; Spruce Elementary; 195 Spruce Street

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03428-001	185.7-3	03/11/2021	SINGLE LAV OUTSIDE GIRLS LOCKER ROOM	3.40	04/08/2021	
21-03-03428-002	185.7-4	03/11/2021	GIRLS LOCKER ROOM OFFICE	26.2	04/08/2021	
21-03-03428-003	185.7-5	03/11/2021	GIRLS LOCKER ROOM	10.7	04/08/2021	
21-03-03428-004	185.7-6A	03/11/2021	HALL NEAR STAGE	<1.00	04/08/2021	
21-03-03428-005	185.7-6B	03/11/2021	HALL NEAR STAGE	<1.00	04/08/2021	
21-03-03428-006	185.7-8	03/11/2021	MEN'S BATHROOM BY GYM LEFT	8.06	04/08/2021	
21-03-03428-007	185.7-9	03/11/2021	MEN'S BATHROOM BY GYM RIGHT	6.99	04/08/2021	
21-03-03428-008	185.7-10	03/11/2021	BOYS LOCKER ROOM OFFICE	15.6	04/08/2021	
21-03-03428-009	185.7-12	03/11/2021	BOYS LOCKER ROOM	4.02	04/08/2021	
21-03-03428-010	185.7-13	03/11/2021	KITCHEN 3 BAY	4.86	04/08/2021	
21-03-03428-011	185.7-14	03/11/2021	KITCHEN 2 BAY	12.2	04/08/2021	
21-03-03428-012	185.7-15	03/11/2021	KITCHEN DISH SPRAYER	7.33	04/08/2021	
21-03-03428-013	185.7-17	03/11/2021	WOMEN'S BATHROOM BY GYM/RECEIVING LEFT	4.69	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03428

Project/Test Address: 2020L-185.7; Spruce Elementary; 195 Spruce Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03428-014	185.7-18	03/11/2021	WOMEN'S BATHROOM BY GYM/RECIEVING RIGHT	4.83	04/08/2021	
21-03-03428-015	185.7-20	03/11/2021	WOMEN'S BATHROOM IN RECIEVING	21.3	04/08/2021	
21-03-03428-016	185.7-21	03/11/2021	PRINCIPAL OFFICE	33.0	04/08/2021	
21-03-03428-017	185.7-22	03/11/2021	MAIN OFFICE	22.5	04/08/2021	
21-03-03428-018	185.7-23	03/11/2021	NURSE LAV	2.04	04/08/2021	
21-03-03428-019	185.7-25A	03/11/2021	HALL OUTSIDE NURSE OFFICE	1.49	04/08/2021	
21-03-03428-020	185.7-25B	03/11/2021	HALL OUTSIDE NURSE OFFICE	1.18	04/08/2021	
21-03-03428-021	185.7-28	03/11/2021	FACULTY ROOM	15.8	04/08/2021	
21-03-03428-022	185.7-29	03/11/2021	FACULTY ROOM BATHROOM	<1.00	04/08/2021	
21-03-03428-023	185.7-30	03/11/2021	111	7.70	04/08/2021	
21-03-03428-024	185.7-31	03/11/2021	111	195	04/08/2021	
21-03-03428-025	185.7-32	03/11/2021	113	6.38	04/08/2021	
21-03-03428-026	185.7-33	03/11/2021	113	20.6	04/08/2021	
21-03-03428-027	185.7-34	03/11/2021	113 BATHROOM	32.7	04/08/2021	
21-03-03428-028	185.7-35	03/11/2021	115	<1.00	04/08/2021	
21-03-03428-029	185.7-36	03/11/2021	115	2.07	04/08/2021	
21-03-03428-030	185.7-36.5	03/11/2021	115 LAV	9.45	04/08/2021	
21-03-03428-031	185.7-37	03/11/2021	114	1.10	04/08/2021	
21-03-03428-032	185.7-38	03/11/2021	114	1.87	04/08/2021	
21-03-03428-033	185.7-39	03/11/2021	114 BATHROOM	1.39	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03428

Project/Test Address: 2020L-185.7; Spruce Elementary; 195 Spruce Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03428-034	185.7-40	03/11/2021	117	<1.00	04/08/2021	
21-03-03428-035	185.7-41	03/11/2021	117	1.94	04/08/2021	
21-03-03428-036	185.7-41.5	03/11/2021	117 LAV	1.53	04/08/2021	
21-03-03428-037	185.7-42	03/11/2021	116	2.69	04/08/2021	
21-03-03428-038	185.7-43	03/11/2021	116	2.09	04/08/2021	
21-03-03428-039	185.7-44	03/11/2021	116 LAV	2.18	04/08/2021	
21-03-03428-040	185.7-45	03/11/2021	109 LAV	6.75	04/08/2021	
21-03-03428-041	185.7-47	03/11/2021	109	11.6	04/08/2021	
21-03-03428-042	185.7-48	03/11/2021	137	23.5	04/08/2021	
21-03-03428-043	185.7-49	03/11/2021	107 LAV	9.25	04/08/2021	
21-03-03428-044	185.7-52	03/11/2021	108 LAV	7.66	04/08/2021	
21-03-03428-045	185.7-52B	03/11/2021	EXTRA SAMPLE	<1.00	04/08/2021	
21-03-03428-046	185.7-55	03/11/2021	105 LAV	8.88	04/08/2021	
21-03-03428-047	185.7-58	03/11/2021	106 LAV	4.20	04/08/2021	
21-03-03428-048	185.7-61	03/11/2021	103 LAV	12.3	04/08/2021	
21-03-03428-049	185.7-64	03/11/2021	104 LAV	15.2	04/08/2021	
21-03-03428-050	185.7-65	03/11/2021	104	66.1	04/08/2021	
21-03-03428-051	185.7-66	03/11/2021	104	35.5	04/08/2021	
21-03-03428-052	185.7-67	03/11/2021	101	10.3	04/08/2021	
21-03-03428-053	185.7-70	03/11/2021	102 LAV	6.64	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03428

Project/Test Address: 2020L-185.7; Spruce Elementary; 195 Spruce Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03428-054	185.7-72	03/11/2021	209	9.82	04/08/2021	
21-03-03428-055	185.7-74A	03/11/2021	HALL NEAR STOCK ROOM	5.39	04/08/2021	
21-03-03428-056	185.7-74B	03/12/2021	HALL NEAR STOCK ROOM	9.35	04/08/2021	
21-03-03428-057	185.7-76	03/12/2021	212	53.1	04/08/2021	
21-03-03428-058	185.7-78	03/12/2021	215	28.7	04/08/2021	
21-03-03428-059	185.7-79	03/12/2021	210	9.76	04/08/2021	
21-03-03428-060	185.7-80	03/12/2021	FACULTY MEN'S BATHROOM	<1.00	04/08/2021	
21-03-03428-061	185.7-81	03/12/2021	FACULTY WOMEN'S BATHROOM	3.99	04/08/2021	
21-03-03428-062	185.7-82	03/12/2021	2ND FLOOR GIRLS LAV LEFT	3.19	04/08/2021	
21-03-03428-063	185.7-83	03/12/2021	2ND FLOOR GIRLS LAV CENTER	7.53	04/08/2021	
21-03-03428-064	185.7-84	03/12/2021	2ND FLOOR GIRLS LAV RIGHT	10.0	04/08/2021	
21-03-03428-065	185.7-85	03/12/2021	2ND FLOOR BOYS LAV LEFT	9.59	04/08/2021	
21-03-03428-066	185.7-86	03/12/2021	2ND FLOOR BOYS LAV CENTER	6.53	04/08/2021	
21-03-03428-067	185.7-87	03/12/2021	2ND FLOOR BOYS LAV RIGHT	5.96	04/08/2021	
21-03-03428-068	185.7-89	03/12/2021	207	12.0	04/08/2021	
21-03-03428-069	185.7-90	03/12/2021	208	11.2	04/08/2021	
21-03-03428-070	185.7-92	03/12/2021	205	14.7	04/08/2021	
21-03-03428-071	185.7-94	03/12/2021	206	7.56	04/08/2021	
21-03-03428-072	185.7-95	03/12/2021	206	25.2	04/08/2021	
21-03-03428-073	185.7-96	03/12/2021	203	20.5	04/08/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03428

Project/Test Address: 2020L-185.7; Spruce Elementary; 195 Spruce Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03428-074	185.7-97	03/12/2021	203	25.5	04/08/2021	
21-03-03428-075	185.7-98	03/12/2021	204	16.8	04/08/2021	
21-03-03428-076	185.7-99	03/12/2021	204	25.0	04/08/2021	
21-03-03428-077	185.7-100	03/12/2021	201	15.3	04/08/2021	
21-03-03428-078	185.7-101	03/12/2021	201	32.1	04/08/2021	
21-03-03428-079	185.7-102	03/12/2021	202	14.0	04/08/2021	
21-03-03428-080	185.7-103	03/12/2021	202	12.9	04/08/2021	
21-03-03428-081	185.7-112	03/12/2021	BASEMENT BATHROOM	5.50	04/08/2021	

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND

ug/L= micrograms per liter

ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021
Revised April 02, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK
STATE OF
OPPORTUNITY.

Department
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name)

EHS

STOHL Job #

2020L-185.7

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Spruce Elementary

Location: 195 Spruce Street

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.7-3	Single Lav Outside Girls Locker Room	S	23:06
185.7-4	Girls locker room Office	S	23:07
185.7-5	Girls Locker room	S	23:08
185.7-6A	Hall near stage	DF	23:09
185.7-6B	Hall near stage	DFB	23:10
185.7-8	Men's bathroom by gym left	S	23:11
185.7-9	Men's bathroom by gym right	S	23:12
185.7-10	Boys locker room Office	S	23:13
185.7-12	Boys locker room	S	23:14
185.7-13	Kitchen 3 Bay	S	23:15
185.7-14	Kitchen 2 Bay	S	23:16
185.7-15	Kitchen Dish Sprayer	S	23:17
185.7-17	Women's bathroom by gym/recieving left	S	23:18
185.7-18	Women's bathroom by gym/recieving right	S	23:19
185.7-20	Women's bathroom in recieving	S	23:20
185.7-21	Principal office	S	23:21
185.7-22	Main office	S	23:22
185.7-23	nurse lav	S	23:23

21-03-03428



Due Date:
04/13/2021
(Tuesday)
AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): RT HARRIS K. Glau Date: 3.16.21 Time: 2:50 pm

Sample Login (Name / Lab): Trae Bloom / Jaci Bloom Date: 4/6/21 Time: 8:07 AM

Analysis (Name / Lab): Yanyou Date: 4/12/21 Time: 10:28 AM

QA/QC Review (Name / Lab): M. H. Date: 4/12/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLNENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.7

Client: North Tonawanda CSD Contact: Jim Hart

Building: Spruce Elementary Location: 195 Spruce Street

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

Sample #	Location	Outlet Type	Time
185.7-25A	Hall outside nurse office	DF	23:24
185.7-25B	Hall outside nurse office	DFB	23:25
185.7-28	Faculty Room	S	23:26
185.7-29	Faculty Room bathroom	S	23:27
185.7-30	111	S	23:28
185.7-31	111	B	23:29
185.7-32	113	S	23:30
185.7-33	113	B	23:31
185.7-34	113 bathroom	S	23:32
185.7-35	115	S	23:33
185.7-36	115	B	23:34
185.7-36.5	115 Lav	S	23:35
185.7-37	114	S	23:36
185.7-38	114	B	23:37
185.7-39	114 bathroom	S	23:38
185.7-40	117	S	23:39
185.7-41	117	B	23:40
185.7-41.5	117 Lav	S	23:41

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KTHARRIS KJL Date: 3/16/21 Time: 2:50 pm

Sample Login (Name / Lab): Tina Bloom / Haverhill Date: 4/6/21 Time: 8:10 AM

Analysis (Name / Lab): Young Ode Date: 4/7/21 Time: 4:27 PM

QA/QC Review (Name / Lab): M. Lutz Date: 4/8/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.7

Client: North Tonawanda CSD Contact: Jim Hart

Building: Spruce Elementary Location: 195 Spruce Street

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
37 185.7-42	116	S	23:42
38 185.7-43	116	B	23:43
39 185.7-44	116 Lav	S	23:44
40 185.7-45	109 Lav	S	23:45
41 185.7-47	109	S	23:46
42 185.7-48	137	S	23:47
43 185.7-49	107 Lav	S	23:48
44 185.7-52	108 Lav <u>45 / EXTRA 52 B</u>	S	23:49
45 185.7-55	105 Lav	S	23:50
46 185.7-58	106 Lav	S	23:51
47 185.7-61	103 Lav	S	23:52
48 185.7-64	104 Lav	S	23:53
49 185.7-65	104	B	23:54
50 185.7-66	104	S	23:55
51 185.7-67	101	S	23:56
52 185.7-70	102 Lav	S	23:57
53 185.7-72	209	S	23:58
54 185.7-74A	Hall near stock room	DF	23:59

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS ORCA Date: 3/16/21 Time: 2:50 pm

Sample Login (Name / Lab): Tracey Brown / Fluor Date: 4/16/21 Time: 8:12 AM

Analysis (Name / Lab): Green Oa Date: 4/17/21 Time: 4:27 pm

QA/QC Review (Name / Lab): Melinda Date: 4/18/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.7

Client: North Tonawanda CSD Contact: Jim Hart
 Building: Spruce Elementary Location: 195 Spruce Street

LEAD	
Water by SM 19, 21 - 23 3113B (-04, -10)	<u>X</u>
	Turnaround 20 Days

Sample #	Location	Outlet Type	Time
56 185.7-74B	Hall near stock room	DFB	0:00
57 185.7-76	212	S	0:01
58 185.7-78	215	S	0:02
59 185.7-79	210	S	0:03
60 185.7-80	Faculty men's bathroom	S	0:04
61 185.7-81	Faculty women's bathroom	S	0:05
62 185.7-82	2nd Floor Girls Lav Left	S	0:06
63 185.7-83	2nd Floor Girls Lav Center	S	0:07
64 185.7-84	2nd Floor Girls Lav Right	S	0:08
65 185.7-85	2nd Floor Boys Lav Left	S	0:09
66 185.7-86	2nd Floor Boys Lav Center	S	0:10
67 185.7-87	2nd Floor Boys Lav Right	S	0:11
68 185.7-89	207	S	0:12
69 185.7-90	208	S	0:13
70 185.7-92	205	S	0:14
71 185.7-94	206	S	0:15
72 185.7-95	206	B	0:16
73 185.7-96	203	S	0:17

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): RT HARRIS ORCA Date: 3/16/21 Time: 2:50 pm

Sample Login (Name / Lab): Tina Bloom / Fair Bl Date: 4/6/21 Time: 8:15 AM

Analysis (Name / Lab): Young Oca Date: 4/7/21 Time: 6:20 pm

QA/QC Review (Name / Lab): Melinda Date: 4/14/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2020L-185.7

Contact: Jim Hart

Location: 195 Spruce Street

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Notes:

Please e-mail lab results to labs@stohlenv.com

Archived / Released: QA/QC InterLAB Use: Date: Time:

BLANK

BLANK



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM