Lead in School Drinking Water Report

Cedarhome Elementary School

Date(s) collected: 2024-04-16, 2024-04-18
Date(s) analyzed: 2024-04-24, 2024-04-25, 2024-04-26

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391007	Main Building	Fountain/Tap Combo	Rm8 Farthest From Door	2 of 2	Tap	left	33
391528	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	29
391006	Main Building	Fountain/Tap Combo	Rm8 Closest To Door	1 of 2	Tap	left	17
391503	Main Building	Sink	Kitchen	Across from dishwashing + handwashing station	Tap	center	15
391005	Main Building	Fountain/Tap Combo	Rm7	1 of 1	Tap	left	14
391545	Main	Fountain/Tap	Rm28	1 of 1	Tap	left	13

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Combo					
391021	Main Building	Fountain/Tap Combo	Rm28	1 of 1	Water Fountain	right	12
391003	Main Building	Sink - Multi-Compartment	Kitchen	Across from fridge	Tap	center	10
391010	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	10
391029	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	6
391525	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Tap	left	6
391014	Main Building	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	5
391015	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Tap	left	5
391011	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Tap	left	4
391004	Main Building	Fountain - Multi-Level	Hallway Right Of Gym	1 of 2	Water Fountain	left	3
391017	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Tap	left	3
391027	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Water Fountain	right	2
391008	Main Building	Sink	Health Room	1 of 1	Tap	center	1
391016	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Tap	left	1
391505	Main Building	Fountain/Tap Combo	Rm7	1 of 1	Water Fountain	right	1
391507	Main Building	Fountain/Tap Combo	Rm8 Farthest From Door	2 of 2	Water Fountain	right	1
391522	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Tap	left	1
391009	Main	Fountain -	Hallway	2 of 2	Water	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Multi-Level with Bottle Filler	Across From Elevator		Fountain		
391012	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	<1
391013	Main Building	Fountain - Multi-Level	Hallway Between 12 And14	1 of 2	Water Fountain	left	<1
391018	Main Building	Fountain/Tap Combo	Rm18	1 of 1	Tap	left	<1
391019	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	<1
391020	Main Building	Fountain/Tap Combo	Rm27	1 of 1	Tap	left	<1
391022	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Water Fountain	right	<1
391023	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Water Fountain	right	<1
391024	Main Building	Fountain - Multi-Level	2nd Floor Hallway	2 of 2	Water Fountain	right	<1
391025	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Water Fountain	right	<1
391026	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Water Fountain	right	<1
391028	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Water Fountain	right	<1
391504	Main Building	Fountain - Multi-Level	Hallway Right Of Gym	2 of 2	Water Fountain	right	<1
391506	Main Building	Fountain/Tap Combo	Rm8 Closest To Door	1 of 2	Water Fountain	right	<1
391508	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across From Elevator	1 of 2	Water Fountain	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391509	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across From Elevator	2 of 2	Water Bottle Filler	right	<1
391510	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Water Fountain	right	<1
391511	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Water Fountain	right	<1
391512	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	<1
391513	Main Building	Fountain - Multi-Level	Hallway Between 12 And14	2 of 2	Water Fountain	right	<1
391514	Main Building	Fountain/Tap Combo	Rm14	1 of 1	Water Fountain	right	<1
391515	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Water Fountain	right	<1
391516	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Water Fountain	right	<1
391517	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Water Fountain	right	<1
391518	Main Building	Fountain/Tap Combo	Rm18	1 of 1	Water Fountain	right	<1
391519	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	<1
391520	Main Building	Fountain/Tap Combo	Rm27	1 of 1	Water Fountain	right	<1
391521	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Tap	left	<1
391523	Main Building	Fountain - Multi-Level	2nd Floor Hallway	1 of 2	Water Fountain	left	<1
391524	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Tap	left	<1
391526	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391527	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Tap	left	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**