Lead in School Drinking Water Report

Utsalady Elementary School

Date(s) collected: 2024-04-20
Date(s) analyzed: 2024-05-09

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391583	Main Building	Fountain/Tap Combo	Kitchen Between 18 And 19	1 of 1	Water Fountain	right	42
391083	Main Building	Fountain/Tap Combo	Kitchen Between 18 And 19	1 of 1	Tap	left	27
391588	Main Building	Fountain/Tap Combo	Rm27	1 of 1	Water Fountain	right	14
391590	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Water Fountain	right	11
391599	Main Building	Fountain/Tap Combo	Pbs-2	1 of 1 (fountain turned off)	Tap	left	6
391077	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	3
391093	Main	Fountain/Tap	Rm24	1 of 1	Water	right	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Combo			Fountain		
391099	Main Building	Fountain/Tap Combo	Pbs-1	1 of 1	Water Fountain	right	3
391076	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Water Fountain	right	2
391085	Main Building	Fountain/Tap Combo	Rm29	1 of 1	Water Fountain	right	2
391094	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Water Fountain	right	2
391096	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Water Fountain	right	2
391097	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	2
391100	Main Building	Sink - Multi-Compartment	Kitchen	1 of 1	Tap	center	2
391580	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Water Fountain	right	2
391582	Main Building	Fountain/Tap Combo	Rm18	1 of 1	Water Bottle Filler	right	2
391585	Main Building	Fountain/Tap Combo	Rm29	1 of 1	Tap	left	2
391586	Main Building	Fountain/Tap Combo	Rm30	1 of 1	Water Fountain	right	2
391594	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Tap	left	2
391598	Main Building	Fountain/Tap Combo	Pbs-1	1 of 1	Tap	left	2
391086	Main Building	Fountain/Tap Combo	Rm30	1 of 1	Tap	left	1
391087	Main Building	Fountain/Tap Combo	Rm28	1 of 1	Tap	left	1
391088	Main Building	Fountain/Tap Combo	Rm27	1 of 1	Tap	left	1
391095	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Water Fountain	right	1
391578	Main	Fountain/Tap	Rm14	1 of 1	Water	right	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Combo			Fountain		
391584	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	1
391587	Main Building	Fountain/Tap Combo	Rm28	1 of 1	Water Fountain	right	1
391589	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Water Fountain	right	1
391592	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Tap	left	1
391073	Main Building	Fountain - Multi-Level with Bottle Filler	Main Entrance Hallway	1 of 2	Water Fountain	left	<1
391074	Main Building	Fountain - Multi-Level with Bottle Filler	Main Entrance Hallway	2 of 2	Water Bottle Filler	right	<1
391075	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Water Fountain	right	<1
391078	Main Building	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	<1
391079	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Tap	left	<1
391080	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Tap	left	<1
391081	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Tap	left	<1
391082	Main Building	Fountain/Tap Combo	Fm18	1 of 1	Tap	left	<1
391084	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	<1
391089	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Tap	left	<1
391090	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Tap	left	<1
391091	Main Building	Fountain - Multi-Level	23-26 Hallway	1 of 2	Water Fountain	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
		with Bottle Filler					
391092	Main Building	Fountain - Multi-Level with Bottle Filler	23-26 Hallway	2 of 2	Water Bottle Filler	right	<1
391098	Main Building	Sink	Health Room	1 of 1	Tap	center	<1
391101	Main Building	Fountain - Multi-Level	Kitchen/Gym Hallway	2 of 2	Water Fountain	right	<1
391573	Main Building	Fountain - Multi-Level with Bottle Filler	Main Entrance Hallway	2 of 2	Water Fountain	right	<1
391574	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	<1
391575	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Tap	left	<1
391576	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	<1
391577	Main Building	Fountain - Multi-Level	12-15 Hallway	2 of 2 (1of2 turned off)	Water Fountain	right	<1
391579	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Water Fountain	right	<1
391581	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Water Fountain	right	<1
391591	Main Building	Fountain - Multi-Level with Bottle Filler	23-26 Hallway	2 of 2	Water Fountain	right	<1
391593	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Tap	left	<1
391595	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Tap	left	<1
391596	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391597	Main Building	Fountain - Multi-Level	Hallway Left Of Music Room	1 of 2 (2of2 turned off)	Water Fountain	left	<1
391600	Main Building	Fountain - Multi-Level	Kitchen/Gym Hallway	1 of 2	Water Fountain	left	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**