









590 Traditions Grande Blvd, Wake Forest, North Carolina 27587



Envision Science Academy - 1st & 3rd Hallway

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
Gym exterior	Bottle Filler	Bottle Filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Bathroom by gym	Bottle Filler	Bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Bathroom by gym	Fountain	Fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Downstairs Teacher's Lounge	Faucet	Sink	Initial First Draw	May 27, 2024 / 0.12	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Gym exterior	Fountain	Water fountain with	Initial First Draw	May 24, 2024 / <0.10	

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
		bottle filler			
Bathroom by comons	Bottle Filler	bottle filler	Initial First Draw	May 24, 2024 / <0.10	
Bathroom by comons	Fountain	water fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	
Bathroom by comons	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
Bathroom by gym	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
-----------	----------	----------	-------------	------------------------	---------------------------------------



Gym exterior	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
--------------	----------	--------------------------------------	--------------------	----------------------	--

	Clean the faucet regularly		Communicate findings with parents, staff, and students
--	----------------------------	---	--



Envision Science Academy - 4th & 5th Hallway

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
-----------	----------	----------	-------------	------------------------	---------------------------------------



Bathroom by counselors	Bottle Filler	bottle filler	Initial First Draw	May 24, 2024 / <0.10	
------------------------	---------------	---------------	--------------------	----------------------	--

	Clean the faucet regularly		Communicate findings with parents, staff, and students
--	----------------------------	---	--







Bathroom by counselors	Fountain	fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	
------------------------	----------	-----------------------------	--------------------	----------------------	--











	Clean the faucet regularly		Communicate findings with parents, staff, and students
--	----------------------------	---	--





Bathroom by counselors	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
------------------------	----------	--------------------------------------	--------------------	----------------------	--

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
	Clean the faucet regularly			Clean Water for Use by Kids	Communicate findings with parents, staff, and students

Envision Science Academy - Commons

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
Commons	Bottle Filler	Bottle Filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly				Communicate findings with parents, staff, and students
Commons	Faucet	Sink by microwaves	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly				Communicate findings with parents, staff, and students
Commons	Fountain	Water Fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly				Communicate findings with parents, staff, and students
Commons	Fountain	Water fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
bathroom by band and art rooms	Bottle Filler	bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Bathroom by tech office	Bottle Filler	bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
bathroom by band and art rooms	Fountain	fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Bathroom by tech office	Fountain	fountain with bottle filler	Initial First Draw	May 24, 2024 / <0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		
Upstairs teacher's lounge	Faucet	sink	Initial First Draw	May 24, 2024 / 0.10	
	Clean the faucet regularly		Communicate findings with parents, staff, and students		

Area/Room	Tap Type	Tap Name	Sample Type	Analysis Date / Result	Mitigation Actions Listed by Facility
bathroom by band and art rooms	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
 Clean the faucet regularly				Communicate findings with parents, staff, and students	
Bathroom by tech office	Fountain	water fountain without bottle filler	Initial First Draw	May 24, 2024 / <0.10	
 Clean the faucet regularly				Communicate findings with parents, staff, and students	