
June 20, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Chinn Elementary
8804 NW 45 Highway, Parkville, MO 64152
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Chinn Elementary in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

METHODOLOGY

On 05/11/2024 Mr. Jay Hurst of OCCU-TEC completed testing of eighty-six (86) sources throughout Chinn Elementary. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, fifteen (15) of the eighty-six (86) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
386-CE-30	Room 116	Sink	8.74
386-CE-31	Room 116	Drinking Fountain Bubbler	24.2
386-CE-43	Room 120	Sink	19.0
386-CE-44	Room 122	Drinking Fountain Bubbler	85.7
386-CE-45	Room 122	Sink	48.5
386-CE-46	Room 124	Sink	16.3
386-CE-48	Room 125	Sink	65.8
386-CE-50	Room 123	Sink	35.1
386-CE-51	Room 123	Drinking Fountain Bubbler	5.8
386-CE-52	Room 121	Sink	12.9
386-CE-53	Room 121	Drinking Fountain Bubbler	27.4
386-CE-80	Room 110	Sink	5.49
386-CE-84	Room 109	Drinking Fountain Bubbler	6.13
386-CE-85	Room 107	Sink	17.5
386-CE-92	Office Work Room	Sink	14.6

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
386-CE-39	Men's RR by Room 117	Right Side, Left Handwashing Sink
386-CE-47	Room 124	Drinking Fountain Bubbler
386-CE-49	Room 125	Drinking Fountain Bubbler

Sample ID	Location	Type
386-CE-57	Room 117	Drinking Fountain Bubbler
386-CE-88	Room 105	Drinking Fountain Bubbler
386-CE-91	Room 101	Drinking Fountain Bubbler

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random "Flush" sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations





Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-01	Location:	Kitchen Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Handwashing Sink		
		Result:	1.86	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Sink 044, Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-03	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Sink 043 Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-04	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Sink 042 Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-05	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Sink 041 Kitchen Dish Sprayer		
		Result:	3.35	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-06	Location:	Kitchen	
Photo:		Manufacturer:	Advance Tabco	
		Description:		
		CH Sink 047 Handwashing Sink		
		Result:	3.5	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-07	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		CH Sink 046 Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-08	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Sink 046 Kitchen Dish Sprayer		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-09	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CH Tilt 001 Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-10	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-11	Location:	Multi-Purpose	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler CH DF 006		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-12	Location:	Hall outside Multi	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler CH DF 005		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-13	Location:	Women's RR by Room 12	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, left handwashing Sink		
		Result:	1.37	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-14	Location:	Women's RR by Room 12	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, right handwashing sink		
		Result:	1.72	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-15	Location:	Mens RR by Room 10	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, left handwashing sink		
		Result:	1.3	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-16	Location:	Mens RR by Room 10	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, left handwashing sink		
		Result:	1.26	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-17	Location:	Room 10	
Photo:		Manufacturer:	Delta	
		Description:		
		CH Sink 001 Sink		
		Result:	2.6	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-18	Location:	Room 10 Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		CH Sink 006 Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-19	Location:	Room 12	
Photo:		Manufacturer:	Delta	
		Description:		
		CH Sink 004 Sink		
		Result:	3.19	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-20	Location:	Room 12 Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		CH Sink 005 Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-21	Location:	Hall by Room 12	
Photo:		Manufacturer:	Murdock	
		Description:		
		CH DF 002 Left drinking fountain bubbler		
		Bad flow		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-22	Location:	Hall by Room 12	
Photo:		Manufacturer:	Murdock	
		Description:		
		CH DF 002 Right drinking fountain bubbler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-23	Location:	Hall by Room 12	
Photo:		Manufacturer:	Murdock	
		Description:		
		CH DF 002 Right drinking fountain bottle filler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-24	Location:	Room 13	
Photo:		Manufacturer:	Unknown	
		Description:		
		CH Sink 007 Sink		
		Result:	1.13	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-25	Location:	Room 13 Restroom		
Photo:		Manufacturer:	Unknown		
		Description:			
		CH Sink 008 Handwashing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-CE-26	Location:	Room 14		
Photo:		Manufacturer:	Chicago Faucet Co.		
		Description:			
		CH Sink 009 Sink			
		Result:	3.99	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-CE-27	Location:	Room 14 Restroom		
Photo:		Manufacturer:	Unknown		
		Description:			
		CH Sink 010 Handwashing Sink			
		Result:	2.44	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-28	Location:	Hall by Gym	
Photo:		Manufacturer:	Elkay	
		Description:		
		CH DF 0003 Left drinking fountain bubbler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-29	Location:	Hall by Gym	
Photo:		Manufacturer:	Elkay	
		Description:		
		CH DF 003 Right drinking fountain bubbler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-30	Location:	Room 116	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 030 Sink		
		Result:	8.74	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-31	Location:	Room 116	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 030 Drinking Fountain bubbler		
		Result:	24.2	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service		


ID:	386-CE-32	Location:	Room 118	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 029 Sink		
		Result:	1.11	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-33	Location:	Women's RR by RM 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, left handwashing sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-34	Location:	Women's RR by RM 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-35	Location:	Women's RR by RM 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, left handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-36	Location:	Women's RR by RM 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-37	Location:	Men's RR by Room 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, left handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-38	Location:	Men's RR by Room 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-39	Location:	Men's RR by Room 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, left handwashing sink		
		Not functional at time of test.		
Date Sampled:		5/11/2024	By:	JH
Recommended Action:		Label as Non-Drinking Water		


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-40	Location:	Men's RR by Room 117	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, right handwashing sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-41	Location:	Hall by Room 119	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CH DF 001 Drinking Fountain bubbler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-42	Location:	Hall by Room 119	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CH DF 001 Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-43	Location:	Room 120		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 024 Sink			
		Result:	19	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water			


ID:	386-CE-44	Location:	Room 122		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 023 Drinking Fountain Bubbler			
		Result:	85.7	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:		Remove from Service			

ID:	386-CE-45	Location:	Room 122		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 023 Sink			
		Result:	48.5	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water			


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-46	Location:	Room 124	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 022, Sink		
		Result:	16.3	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		


ID:	386-CE-47	Location:	Room 124	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 022, Drinking fountain bubbler		
		Not functional at time of test.		
		Result:	N/A	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service		

ID:	386-CE-48	Location:	Room 125	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sin 021 Sink		
		Result:	65.8	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-49	Location:	Room 125	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 021 Drinking Fountain Bubbler		
		Not functional at time of test.		
		Result:	N/A	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service		


ID:	386-CE-50	Location:	Room 123	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 020 Sink		
		Result:	35.1	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		

ID:	386-CE-51	Location:	Room 123	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 020 Drinking Fountain Bubbler		
		Result:	5.8	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service		


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-52	Location:	Room 121		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 019 Sink			
		Result:	12.9	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water			


ID:	386-CE-53	Location:	Room 121		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 019 Drinking Fountain Bubbler			
		Result:	27.4	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:		Remove from Service			

ID:	386-CE-54	Location:	Room 119		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 018 Sink			
		Result:	1.74	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-55	Location:	Room 119	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 018 Drinking Fountain Bubbler		
		Bad Flow		
		Result:	4.91	ppb
Date Sampled:	5/11/2024	By:	JH	
Recommended Action:				


ID:	386-CE-56	Location:	Room 117		
Photo:		Manufacturer:	Central		
		Description:			
		CH Sink 017 Sink			
		Result:	1.46	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-CE-57	Location:	Room 117	
Photo:		Manufacturer:	Central	
		Description:		
		Drinking Fountain Bubbler		
		Not functional at time of test.		
		Result:	N/A	ppb
Date Sampled:	5/11/2024	By:	JH	
Recommended Action:		Remove from Service		


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-58	Location:	Room 115	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 016 Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-59	Location:	Health Room	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-60	Location:	Health Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Handwashing Sink, CH Sink 014		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-61	Location:	Staff Restroom	
Photo:		Manufacturer:	Chicaog Faucet Co.	
		Description:		
		CH Sink 011 Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-62	Location:	Staff Restroom	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		CH Sink 012 Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-63	Location:	Staff Dining Room	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		CH Sink 015		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-64	Location:	Staff Dining Room	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		CH Ice Machine 001		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-65	Location:	Women's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, left handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-66	Location:	Women's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-67	Location:	Women's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-68	Location:	Women's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, right handwashing sink		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-69	Location:	Hall by Room 101	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CH DF 004 Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-70	Location:	Hall by Room 101	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CH DF 004 Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-71	Location:	Men's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, left handwashing sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-72	Location:	Men's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left side, right handwashing sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-73	Location:	Men's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, left handwashing sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	5/11/2024	By: JH


ID:	386-CE-74	Location:	Men's RR by RM 101	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right side, right handwashing sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	5/11/2024	By: JH

ID:	386-CE-75	Location:	Room 102	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 041, sink		
		Result:	3.54	ppb
Recommended Action:		Date Sampled:	5/11/2024	By: JH


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-76	Location:	Room 104	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 040, Sink		
		Result:	2.33	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-77	Location:	Room 106	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 039, Sink		
		Result:	2.21	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-78	Location:	Room 106	
Photo:		Manufacturer:	Central	
		Description:		
		CHS Sink 039, Drinking Fountain Bubbler		
		Result:	1.44	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-79	Location:	Room 108	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 038, Sink		
		Result:	4.01	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-CE-80	Location:	Room 110	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 037, Sink		
		Result:	5.49	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		

ID:	386-CE-81	Location:	Room 110	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 037, Drinking Fountain Bubbler		
		Bad flow		
		Result:	1.55	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-82	Location:	Room 111	
Photo:		Manufacturer:	Central	
		Description:		
		CHS Sink 036, Sink		
		Result:	4.86	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-CE-83	Location:	Room 111	
Photo:		Manufacturer:	Central	
		Description:		
		CHS Sink, 036 Drinking Fountain Bubbler		
		Result:	6.13	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:		Remove from Service		

ID:	386-CE-84	Location:	Room 109	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 035, Sink		
		Result:	3.11	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-85	Location:	Room 107	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 034, Sink		
		Result:	17.5	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service / Label as Non-Drinking Water		


ID:	386-CE-86	Location:	Room 107	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 034, Drinking Fountain bubbler		
		Result:	1.73	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-CE-87	Location:	Room 105	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 033 Sink		
		Result:	2.3	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Chinn Elementary
Park Hill School District


ID:	386-CE-88	Location:	Room 105	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 033 Drinking Fountain Bubbler		
		Not functional at time of test.		
		Result:	N/A	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:		Remove from Service		

ID:	386-CE-89	Location:	Room 103	
Photo:		Manufacturer:	Elkay	
		Description:		
		CH Sink 032		
		Result:		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-CE-90	Location:	Room 101	
Photo:		Manufacturer:	Central	
		Description:		
		CH Sink 031, Sink		
		Result:		
		Result:	2.34	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

Drinking Water Assessment
Chinn Elementary
Park Hill School District

ID:	386-CE-91	Location:	Room 101
Photo:		Manufacturer:	Central
		Description:	
		CH Sink 031 Drinking Fountain Bubbler	
		Not Functional at time of test.	
		Result:	N/A
	Date Sampled:	5/11/2024	By: JH
Recommended Action:		Remove from Service	

ID:	386-CE-92	Location:	Office Work Room	
Photo:		Manufacturer:	Delta	
		Description:		
		Sink		
		Result:	14.6	ppb
			Date Sampled:	5/11/2024
Recommended Action:		Replace Fixture/Unit and Resample		



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

May 31, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386 - CHINN ELEMENTARY SCHOOL

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **86** sample(s) the laboratory received on **5/13/24 5:47 pm** and logged in under work order **HE02777**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order HE02777

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HE02777-01
Name: 386-CE-01
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.86	ug/L		05/22/24 09:07	1	1.00	05/22/24 11:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-02
Name: 386-CE-02
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:01
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 11:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-03
Name: 386-CE-03
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:03
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 11:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-04
Name: 386-CE-04
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:04
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-05
Name: 386-CE-05
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:06
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.35	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:01	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-06
Name: 386-CE-06
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:08
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.50	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:03	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-07
Name: 386-CE-07
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:11
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-08
Name: 386-CE-08
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:11
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-09
Name: 386-CE-09
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:14
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-10
Name: 386-CE-10
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:14
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-11
Name: 386-CE-11
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:15
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:15	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-12
Name: 386-CE-12
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:17
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-13
Name: 386-CE-13
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:21
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.37	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:18	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-14
Name: 386-CE-14
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:21
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.72	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:19	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-15
Name: 386-CE-15
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:23
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.30	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:21	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-16
Name: 386-CE-16
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:23
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.26	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-17
Name: 386-CE-17
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:25
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.60	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:23	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-18
Name: 386-CE-18
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:26
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-19
Name: 386-CE-19
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:29
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.19	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:32	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-20
Name: 386-CE-20
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:29
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-21
Name: 386-CE-21
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:31
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-22
Name: 386-CE-22
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:31
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-23
Name: 386-CE-23
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:31
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-24
Name: 386-CE-24
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:36
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.13	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:39	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-25
Name: 386-CE-25
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:36
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-26
Name: 386-CE-26
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:37
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.99	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:44	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-27
Name: 386-CE-27
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:38
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.44	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:46	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-28
Name: 386-CE-28
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:40
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-29
Name: 386-CE-29
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:40
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:51	BRS	EPA 200.8 REV 5.4

Sample: HE02777-30
Name: 386-CE-30
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:47
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	8.74	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:53	BRS	EPA 200.8 REV 5.4

Sample: HE02777-31
Name: 386-CE-31
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:47
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	24.2	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:54	BRS	EPA 200.8 REV 5.4

Sample: HE02777-32
Name: 386-CE-32
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:50
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.11	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:56	BRS	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HE02777-33
Name: 386-CE-33
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:56
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 12:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-34
Name: 386-CE-34
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:56
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-35
Name: 386-CE-35
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:56
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-36
Name: 386-CE-36
Matrix: Drinking Water - Grab

Sampled: 05/11/24 09:56
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-37
Name: 386-CE-37
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-38
Name: 386-CE-38
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-39
Name: 386-CE-40
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-40
Name: 386-CE-41
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:04
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-41
Name: 386-CE-42
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:04
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-42
Name: 386-CE-43
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:06
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	19.0	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:18	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-43
Name: 386-CE-44
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:08
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	85.7	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:19	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-44
Name: 386-CE-45
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:08
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	48.5	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:21	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-45
Name: 386-CE-46
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:11
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	16.3	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-46
Name: 386-CE-48
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:12
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	65.8	ug/L		05/28/24 11:35	1	1.00	05/28/24 16:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-47
Name: 386-CE-50
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:14
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	35.1	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:24	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-48
Name: 386-CE-51
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:14
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.80	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:25	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-49
Name: 386-CE-52
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:16
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	12.9	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-50
Name: 386-CE-53
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:16
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	27.4	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:31	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-51
Name: 386-CE-54
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:18
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.74	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:35	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-52
Name: 386-CE-55
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:18
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.91	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:36	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-53
Name: 386-CE-56
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:22
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.46	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:38	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-54
Name: 386-CE-58
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:24
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-55
Name: 386-CE-59
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:26
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-56
Name: 386-CE-60
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:27
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-57
Name: 386-CE-61
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:29
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-58
Name: 386-CE-62
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:30
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-59
Name: 386-CE-63
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:33
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-60
Name: 386-CE-64
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:33
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-61
Name: 386-CE-65
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:52
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-62
Name: 386-CE-66
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:53
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:56	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-63
Name: 386-CE-67
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:53
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-64
Name: 386-CE-68
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:53
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 13:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-65
Name: 386-CE-69
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:59
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-66
Name: 386-CE-70
Matrix: Drinking Water - Grab

Sampled: 05/11/24 10:59
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-67
Name: 386-CE-71
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-68
Name: 386-CE-72
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-69
Name: 386-CE-73
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-70
Name: 386-CE-74
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:00
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-71
Name: 386-CE-75
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:06
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.54	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:15	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-72
Name: 386-CE-76
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:08
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.33	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:19	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-73
Name: 386-CE-77
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:10
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.21	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:20	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-74
Name: 386-CE-78
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:10
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.44	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-75
Name: 386-CE-79
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:13
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.01	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:26	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-76
Name: 386-CE-80
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:18
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.49	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:27	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-77
Name: 386-CE-81
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:18
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.55	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-78
Name: 386-CE-82
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:20
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.86	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:30	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-79
Name: 386-CE-83
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:20
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	6.13	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:31	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-80
Name: 386-CE-84
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:22
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.11	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:33	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-81
Name: 386-CE-85
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:23
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	17.5	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:34	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-82
Name: 386-CE-86
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:23
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.73	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:38	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-83
Name: 386-CE-87
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:25
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.30	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:43	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-84
Name: 386-CE-89
Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:27
Received: 05/13/24 17:47
PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE02777-85

Name: 386-CE-90

Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:29

Received: 05/13/24 17:47

PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.34	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:45	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE02777-86

Name: 386-CE-92

Matrix: Drinking Water - Grab

Sampled: 05/11/24 11:30

Received: 05/13/24 17:47

PO #: 23015936

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	14.6	ug/L		05/22/24 09:07	1	1.00	05/22/24 14:47	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

HE0277 HE0290T

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler	PROJECT NUMBER 923386 PHONE NUMBER 8163596731	PROJECT LOCATION Chinn Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us	PURCHASE ORDER # 23015936 DATE SHIPPED 5/14/2024	3 ANALYSIS REQUESTED <div style="display: flex; flex-direction: column; align-items: center;"> <div style="margin-bottom: 10px;">+ DW Lead</div> <div>+ Turb Check</div> </div>	4 (FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____																																																																																																																																																																																																																																					
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED TIME COLLECTED SAMPLER (PLEASE PRINT) Jay Hurst SAMPLER'S SIGNATURE 	MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCH- LEACHATE OIL- OIL SO- SOIL SOL- SOLID	REMARKS																																																																																																																																																																																																																																						
		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">DATE COLLECTED</th> <th rowspan="2">TIME COLLECTED</th> <th colspan="2">SAMPLE TYPE</th> <th rowspan="2">MATRIX TYPE</th> <th rowspan="2">BOTTLE COUNT</th> <th rowspan="2">PRES CODE CLIENT PROVIDED</th> <th rowspan="2">DW Lead</th> <th rowspan="2">Turb Check</th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> <th rowspan="2"></th> </tr> <tr> <th>GRAB</th> <th>COMP</th> </tr> </thead> <tbody> <tr><td>386-CE- 01</td><td>5/11/2024</td><td>9:00</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 02</td><td>5/11/2024</td><td>9:01</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 03</td><td>5/11/2024</td><td>9:03</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 04</td><td>5/11/2024</td><td>9:04</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 05</td><td>5/11/2024</td><td>9:06</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 06</td><td>5/11/2024</td><td>9:08</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 07</td><td>5/11/2024</td><td>9:11</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 08</td><td>5/11/2024</td><td>9:11</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 09</td><td>5/11/2024</td><td>9:14</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 10</td><td>5/11/2024</td><td>9:14</td><td>X</td><td></td><td>DW</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>386-CE- 11</td><td>5/11/2024</td><td>9:15</td><td>X</td><td></td><td>Dw</td><td>1</td><td>6</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check											GRAB	COMP	386-CE- 01	5/11/2024	9:00	X		DW	1	6	X											386-CE- 02	5/11/2024	9:01	X		DW	1	6	X											386-CE- 03	5/11/2024	9:03	X		DW	1	6	X											386-CE- 04	5/11/2024	9:04	X		DW	1	6	X											386-CE- 05	5/11/2024	9:06	X		DW	1	6	X											386-CE- 06	5/11/2024	9:08	X		DW	1	6	X											386-CE- 07	5/11/2024	9:11	X		DW	1	6	X											386-CE- 08	5/11/2024	9:11	X		DW	1	6	X											386-CE- 09	5/11/2024	9:14	X		DW	1	6	X											386-CE- 10	5/11/2024	9:14	X		DW	1	6	X											386-CE- 11	5/11/2024	9:15	X		Dw	1	6	X												
DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE			MATRIX TYPE	BOTTLE COUNT																PRES CODE CLIENT PROVIDED	DW Lead	Turb Check																																																																																																																																																																																																																		
		GRAB	COMP																																																																																																																																																																																																																																							
386-CE- 01	5/11/2024	9:00	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 02	5/11/2024	9:01	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 03	5/11/2024	9:03	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 04	5/11/2024	9:04	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 05	5/11/2024	9:06	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 06	5/11/2024	9:08	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 07	5/11/2024	9:11	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 08	5/11/2024	9:11	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 09	5/11/2024	9:14	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 10	5/11/2024	9:14	X		DW	1	6	X																																																																																																																																																																																																																																		
386-CE- 11	5/11/2024	9:15	X		Dw	1	6	X																																																																																																																																																																																																																																		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER		5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL <u>RUSH</u> RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____							6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____																																																																																																																																																																																																																																	
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) _____ RELINQUISHED BY: (SIGNATURE) _____		DATE 5/13/24 TIME 5:00pm		RECEIVED BY: (SIGNATURE) _____ RECEIVED BY: (SIGNATURE) _____ RECEIVED BY: (SIGNATURE) 				DATE 5/16/24 TIME 1020		8 COMMENTS: (FOR LAB USE ONLY) _____ SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____																																																																																																																																																																																																																																

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District <hr/> ADDRESS 9501 N. Seymour Ave. <hr/> CITY STATE ZIP Kansas City, MO 64153 <hr/> CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 <hr/> PHONE NUMBER 8163596731 <hr/> SAMPLER (PLEASE PRINT) Jay Hurst <hr/> SAMPLER'S SIGNATURE 		PROJECT LOCATION Chinn Elementary School <hr/> E-MAIL KahlerJ@parkhill.k12.mo.us <hr/> MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWBL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> + DW Lead </div> <div style="width: 45%;"> + Turb Check </div> </div>		4 (FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____ <hr/> REMARKS			
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead Turb Check		REMARKS	
386-CE- <u>12</u>		5/11/2024	<u>917</u>	X	DW	1	6	X			
386-CE- <u>13</u>		5/11/2024	<u>921</u>	X	DW	1	6	X			
386-CE- <u>14</u>		5/11/2024	<u>921</u>	X	DW	1	6	X			
386-CE- <u>15</u>		5/11/2024	<u>923</u>	X	DW	1	6	X			
386-CE- <u>16</u>		5/11/2024	<u>923</u>	X	DW	1	6	X			
386-CE- <u>17</u>		5/11/2024	<u>925</u>	X	DW	1	6	X			
386-CE- <u>18</u>		5/11/2024	<u>926</u>	X	DW	1	6	X			
386-CE- <u>19</u>		5/11/2024	<u>929</u>	X	DW	1	6	X			
386-CE- <u>20</u>		5/11/2024	<u>929</u>	X	DW	1	6	X			
386-CE- <u>21</u>		5/11/2024	<u>931</u>	X	DW	1	6	X			
386-CE- <u>22</u>		5/11/2024	<u>931</u>	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL RUSH DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE <u>5/13/24</u> TIME <u>5:00pm</u> DATE TIME DATE TIME DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) 		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____					



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Chinn Elementary School		PURCHASE ORDER # 23015936		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024		+ +		LOGIN # _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead Turb Check		LOGGED BY: _____	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
2 (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
386-CE- 23		5/11/2024		931		X		DW		1 6	
386-CE- 24		5/11/2024		936		X		DW		1 6	
386-CE- 25		5/11/2024		936		X		DW		1 6	
386-CE- 26		5/11/2024		937		X		DW		1 6	
386-CE- 27		5/11/2024		938		X		DW		1 6	
386-CE- 28		5/11/2024		940		X		DW		1 6	
386-CE- 29		5/11/2024		940		X		DW		1 6	
386-CE- 30		5/11/2024		947		X		DW		1 6	
386-CE- 31		5/11/2024		947		X		DW		1 6	
386-CE- 32		5/11/2024		950		X		DW		1 6	
386-CE- 33		5/11/2024		956		X		Dw		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6		I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24		TIME 5:00pm		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE 5/16/24		TIME 1020	
										SAMPLE TEMPERATURE UPON RECEIPT _____ °C	
										CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N	
										SAMPLE(S) RECEIVED ON ICE Y OR N	
										SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N	
										DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	






FEDEX

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Chinn Elementary School		PURCHASE ORDER # 23015936		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024		<input checked="" type="checkbox"/> DW Lead <input checked="" type="checkbox"/> Turb Check		LOGIN # _____ LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
386-CE- 34		5/11/2024	956	X		DW	1	6	X		
386-CE- 35		5/11/2024	956	X		DW	1	6	X		
386-CE- 36		5/11/2024	956	X		DW	1	6	X		
386-CE- 37		5/11/2024	1000	X		DW	1	6	X		
386-CE- 38		5/11/2024	1000	X		DW	1	6	X		
386-CE- 40		5/11/2024	1000	X		DW	1	6	X		
386-CE- 41		5/11/2024	1004	X		DW	1	6	X		
386-CE- 42		5/11/2024	1004	X		DW	1	6	X		
386-CE- 43		5/11/2024	1006	X		DW	1	6	X		
386-CE- 44		5/11/2024	1008	X		DW	1	6	X		
386-CE- 45		5/11/2024	1008	X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24	RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)				
RELINQUISHED BY: (SIGNATURE) 		TIME 5:00pm	RECEIVED BY: (SIGNATURE)		TIME		SAMPLE TEMPERATURE UPON RECEIPT _____ °C				
RELINQUISHED BY: (SIGNATURE) 		DATE	RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N				
		TIME			5/16/24 1020		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____				

FEDER

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Chinn Elementary School		PURCHASE ORDER # 23015936		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)		
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024		+		LOGIN #		
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check		
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE								LOGGED BY: CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:		
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT		
										PRES CODE CLIENT PROVIDED		
386-CE- 46		5/11/2024		1011		X		DW		1 6 X		
386-CE- 48		5/11/2024		1012		X		DW		1 6 X		
386-CE- 50		5/11/2024		1014		X		DW		1 6 X		
386-CE- 51		5/11/2024		1014		X		DW		1 6 X		
386-CE- 52		5/11/2024		1016		X		DW		1 6 X		
386-CE- 53		5/11/2024		1016		X		DW		1 6 X		
386-CE- 54		5/11/2024		1018		X		DW		1 6 X		
386-CE- 55		5/11/2024		1018		X		DW		1 6 X		
386-CE- 56		5/11/2024		1022		X		DW		1 6 X		
386-CE- 58		5/11/2024		1024		X		DW		1 6 X		
386-CE- 59		5/11/2024		1026		X		Dw		1 6 X		
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3		
										6 - UNPRESERVED		
										7 - OTHER		
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialling this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.				
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)				
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:										
RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24 TIME 5:00pm		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)				
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT				
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT				
		TIME				TIME		SAMPLE(S) RECEIVED ON ICE				
								SAMPLE ACCEPTANCE NONCONFORMANT				
								REPORT IS NEEDED				
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE				
								Y OR N				
								Y OR N				

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Chinn Elementary School		PURCHASE ORDER # 23015936		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____		
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024		+ +		REMARKS		
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWBL- SLUDGE HAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead Turb Check				
CONTACT PERSON Jeremie Kahler												
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED				
386-CE- 71		5/11/2024	1100	X		DW	1	6	X			
386-CE- 72		5/11/2024	1100	X		DW	1	6	X			
386-CE- 73		5/11/2024	1100	X		DW	1	6	X			
386-CE- 74		5/11/2024	1100	X		DW	1	6	X			
386-CE- 75		5/11/2024	1106	X		DW	1	6	X			
386-CE- 76		5/11/2024	1108	X		DW	1	6	X			
386-CE- 77		5/11/2024	1110	X		DW	1	6	X			
386-CE- 78		5/11/2024	1110	X		DW	1	6	X			
386-CE- 79		5/11/2024	1113	X		DW	1	6	X			
386-CE- 80		5/11/2024	1118	X		DW	1	6	X			
386-CE- 81		5/11/2024	1118	X		DW	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER				
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____								
7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24	RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)					
RELINQUISHED BY: (SIGNATURE)		TIME 500pm	RECEIVED BY: (SIGNATURE)		TIME		SAMPLE TEMPERATURE UPON RECEIPT _____ °C					
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT _____ Y OR N					
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE)		TIME		SAMPLE(S) RECEIVED ON ICE _____ Y OR N					
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE		SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED _____ Y OR N					
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE)		TIME		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____					

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
 STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler	PROJECT NUMBER 923386 PHONE NUMBER 8163596731 SAMPLER (PLEASE PRINT) Jay Hurst SAMPLER'S SIGNATURE 	PROJECT LOCATION Chinn Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWBL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID	PURCHASE ORDER # 23015936 DATE SHIPPED 5/14/2024	3 ANALYSIS REQUESTED <table style="width:100%; text-align: center;"> <tr> <td style="width:5%;">+</td><td style="width:5%;">+</td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td><td style="width:5%;"></td> </tr> <tr> <td>DW Lead</td><td>Turb Check</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>	+	+																	DW Lead	Turb Check																	4 (FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____
+	+																																								
DW Lead	Turb Check																																								
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS																																	
386-CE- <u>82</u>		5/11/2024	<u>1120</u>	X	DW	1	6	X																																	
386-CE- <u>83</u>		5/11/2024	<u>1120</u>	X	DW	1	6	X																																	
386-CE- <u>84</u>		5/11/2024	<u>1122</u>	X	DW	1	6	X																																	
386-CE- <u>85</u>		5/11/2024	<u>1123</u>	X	DW	1	6	X																																	
386-CE- <u>86</u>		5/11/2024	<u>1123</u>	X	DW	1	6	X																																	
386-CE- <u>87</u>		5/11/2024	<u>1125</u>	X	DW	1	6	X																																	
386-CE- <u>89</u>		5/11/2024	<u>1127</u>	X	DW	1	6	X																																	
386-CE- <u>90</u>		5/11/2024	<u>1129</u>	X	DW	1	6	X																																	
386-CE- <u>92</u>		5/11/2024	<u>1130</u>	X	DW	1	6	X																																	
386-CE-		5/11/2024		X	DW	1	6	X																																	
386-CE-		5/11/2024		X	DW	1	6	X																																	

CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:	6	I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____
---	----------	--

7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)	DATE <u>5/13/24</u> TIME <u>5:00pm</u>	RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)	DATE DATE DATE DATE <u>5/16/24</u> TIME <u>1020</u>	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____
---	---	---	---	---

FED EX