



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-01	Sample Name: A- 01 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-02	Sample Name: A- 02 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-03	Sample Name: A- 03 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-04	Sample Name: A- 04 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-05	Sample Name: A- 05 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-06	Sample Name: A- 06 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-07	Sample Name: A- 07 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-08	Sample Name: A- 08 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-09	Sample Name: A- 09 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/13/23 18:07
3345035-10	Sample Name: A- 10 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/13/23 18:07



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-11	Sample Name: A- 11		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-12	Sample Name: A- 12		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-13	Sample Name: A- 13		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-15	Sample Name: A- 15		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-16	Sample Name: A- 16		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-17	Sample Name: A- 17		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-18	Sample Name: A- 18		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-19	Sample Name: A- 19		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-20	Sample Name: A- 20		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/13/23 18:07
3345035-21	Sample Name: A- 21		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C Apex Environmental
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-22	Sample Name: A- 22						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-23	Sample Name: A- 23						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-24	Sample Name: A- 24						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/13/23 18:07
3345035-25	Sample Name: A- 25						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-26	Sample Name: A- 26						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-27	Sample Name: A- 27						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-28	Sample Name: A- 28						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-29	Sample Name: A- 29						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-30	Sample Name: A- 30						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-31	Sample Name: A- 31						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-32	Sample Name: A- 32						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-33	Sample Name: A- 33						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-34	Sample Name: A- 34						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-35	Sample Name: A- 35						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-36	Sample Name: A- 36						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-37	Sample Name: A- 37						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-38	Sample Name: A- 38						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-39	Sample Name: A- 39						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-40	Sample Name: A- 40						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-41	Sample Name: A- 41						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-42	Sample Name: A- 42						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-43	Sample Name: A- 43						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-44	Sample Name: A- 44						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-45	Sample Name: A- 45						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-46	Sample Name: A- 46						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-47	Sample Name: A- 47						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-48	Sample Name: A- 48						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-49	Sample Name: A- 49						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-50	Sample Name: A- 50						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-51	Sample Name: A- 51						Matrix: Water
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-52	Sample Name: A- 52		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-53	Sample Name: A- 53		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-54	Sample Name: A- 54		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-55	Sample Name: A- 55		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-56	Sample Name: A- 56		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-57	Sample Name: A- 57		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-58	Sample Name: A- 58		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-59	Sample Name: A- 59		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-60	Sample Name: A- 60		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-61	Sample Name: A- 61		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C Apex Environmental
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-62	Sample Name: A- 62 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-63	Sample Name: A- 63 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-64	Sample Name: A- 64 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-65	Sample Name: A- 65 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-66	Sample Name: A- 66 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-67	Sample Name: A- 67 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-68	Sample Name: A- 68 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-69	Sample Name: A- 69 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-70	Sample Name: A- 70 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/14/23 17:30
3345035-71	Sample Name: A- 71 Sampled: 12/2/23 18:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

C Apex Environmental
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Art Rutkin

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3345035-72	Sample Name: A- 72		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-73	Sample Name: A- 73		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-74	Sample Name: A- 74		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-75	Sample Name: A- 75		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-76	Sample Name: A- 76		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-77	Sample Name: A- 77		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-78	Sample Name: A- 78		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-79	Sample Name: A- 79		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-80	Sample Name: A- 80		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/14/23 17:30
3345035-81	Sample Name: A- 81		Matrix: Water				
	Sampled: 12/2/23 18:00						
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/14/23 17:30



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/20/2023
Received: 12/08/2023
Sampled By: Jose Godinez
Work Order: 3345035

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project #: N/A
Sample Type:

Sampling Location: Art Rutkin

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Contains two rows of data for samples 3345035-82 and 3345035-83, both showing ND for Lead.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director

Sample #	Date	Location	TIME
A-01	12/2/2023	Cafeteria	1800
A-02	12/2/2023	Cafeteria	1800
A-03	12/2/2023	Cafeteria	1800
A-04	12/2/2023	Cafeteria	1800
A-05	12/2/2023	Cafeteria	1800
A-06	12/2/2023	Health	1800
A-07	12/2/2023	Staff room	1800
A-08	12/2/2023	Staff room 2	1800
A-09	12/2/2023	Music 119	1800
A-10	12/2/2023	Music 119	1800
A-11	12/2/2023	Kitchen	1800
A-12	12/2/2023	Kitchen	1800
A-13	12/2/2023	Kitchen	1800
A-14	12/2/2023	Kitchen	1800
A-15	12/2/2023	Kitchen	1800
A-16	12/2/2023	Kitchen	1800
A-17	12/2/2023	SPED	1800
A-18	12/2/2023	SPED	1800
A-19	12/2/2023	CR105	1800
A-20	12/2/2023	CR105	1800
A-21	12/2/2023	CR106	1800
A-22	12/2/2023	CR106	1800
A-23	12/2/2023	CR104	1800
A-24	12/2/2023	CR104	1800
A-25	12/2/2023	CR103	1800
A-26	12/2/2023	CR103	1800
A-27	12/2/2023	CR102	1800
A-28	12/2/2023	CR102	1800
A-29	12/2/2023	CR101	1800
A-30	12/2/2023	CR101	1800
A-31	12/2/2023	CR113	1800
A-32	12/2/2023	CR113	1800
A-33	12/2/2023	ELL	1800
A-34	12/2/2023	ELL	1800
A-35	12/2/2023	CR115	1800
A-36	12/2/2023	CR115	1800
A-37	12/2/2023	CR117	1800
A-38	12/2/2023	CR117	1800
A-39	12/2/2023	CR118	1800
A-40	12/2/2023	CR118	1800
A-41	12/2/2023	CR116	1800
A-42	12/2/2023	CR116	1800

A. no sample recvd
12-11-23

A.

A-43	12/2/2023	MAKER SPACE	1800
A-44	12/2/2023	MAKER SPACE	1800
A-45	12/2/2023	MAKER SPACE	1800
A-46	12/2/2023	MAKER SPACE	1800
A-47	12/2/2023	MAKER SPACE	1800
A-48	12/2/2023	CR202	1800
A-49	12/2/2023	CR202	1800
A-50	12/2/2023	CR201	1800
A-51	12/2/2023	CR201	1800
A-52	12/2/2023	CR203	1800
A-53	12/2/2023	CR203	1800
A-54	12/2/2023	CR204	1800
A-55	12/2/2023	CR204	1800
A-56	12/2/2023	CR206	1800
A-57	12/2/2023	CR206	1800
A-58	12/2/2023	CR205	1800
A-59	12/2/2023	CR205	1800
A-60	12/2/2023	CR208	1800
A-61	12/2/2023	CR208	1800
A-62	12/2/2023	CR207	1800
A-63	12/2/2023	CR207	1800
A-64	12/2/2023	2ND FLOOR HALL	1800
A-65	12/2/2023	2ND FLOOR HALL	1800
A-66	12/2/2023	CR212	1800
A-67	12/2/2023	CR212	1800
A-68	12/2/2023	CR211	1800
A-69	12/2/2023	CR211	1800
A-70	12/2/2023	CR213	1800
A-71	12/2/2023	CR213	1800
A-72	12/2/2023	CR214	1800
A-73	12/2/2023	CR214	1800
A-74	12/2/2023	CR216	1800
A-75	12/2/2023	CR216	1800
A-76	12/2/2023	CR215	1800
A-77	12/2/2023	CR215	1800
A-78	12/2/2023	CR217	1800
A-79	12/2/2023	CR217	1800
A-80	12/2/2023	CR218	1800
A-81	12/2/2023	CR218	1800
A-82	12/2/2023	GYM VESTIBULE	1800
A-83	12/2/2023	GYM VESTIBULE	1800

B. Sample was labeled
81 12-11-23 MS

B.